

# VENTILATION AUDIT REPORT

SCHOOL:	Gundagai High School (8442)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Cootamundra
LOCAL GOVERNMENT AREA:	Cootamundra-Gundagai



8442 - Gundagai High School  
Site Plan (12700)



1:1,027

Printed: 11-May-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0008 - General Assistants - (13.09 SQM)	Office (3)	
B00A - R0012 - Movement - (17.87 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Staff Study - (28.51 SQM)	Office (7)	
B00A - R0014 - Darkroom Space - (27.78 SQM)	Office (6)	
B00A - R0019 - Seminar - (24.59 SQM)	Office (6)	
B00A - R0022 - Art Learning Space - (62.17 SQM) - Teaching Space: 1	Student Space (28)	
B00A - R0030 - Movement - (5.31 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Staff Study - (22.43 SQM)	Office (5)	
B00A - R1003 - Laboratory L.S. - (92.45 SQM) - Teaching Space: 1	Student Space (42)	
B00A - R1004 - Preparation - (35.15 SQM)	Not Applicable	Circulation or storage space.
B00A - R1006 - Laboratory L.S. - (94.14 SQM) - Teaching Space: 1	Student Space (43)	
B00A - R1010 - Interview/Office - Type 1 - (13.65 SQM)	Office (3)	
B00B - M0003 - Movement - (5.48 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Movement - (103.19 SQM)	Not Applicable	Circulation or storage space.
B00B - R0005 - Seminar - (29.16 SQM)	Office (7)	
B00B - R0010 - General Learning Space - (51.9 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0011 - Science Laboratory - (39.25 SQM)	Student Space (18)	
B00B - R0016 - Computer Learning Space - (78.49 SQM) - Teaching Space: 1	Student Space (36)	
B00B - R1001 - Movement - (79.73 SQM)	Not Applicable	Circulation or storage space.
B00B - R1002 - General Learning Space - (52.11 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1004 - General Learning Space - (52.47 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1006 - Computer Learning Space - (52.92 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1007 - General Learning Space - (51.75 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R9006 - Staff Study - (25.14 SQM)	Office (6)	
B00B - R9008 - Movement - (10.77 SQM)	Not Applicable	Circulation or storage space.
B00B - R9015 - Wood Technology Bay - (113.33 SQM)	Not Applicable	Circulation or storage space.
B00B - R9016 - Movement - (20.35 SQM)	Not Applicable	Circulation or storage space.
B00B - R9017 - Movement - (26.43 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Movement - (44.07 SQM)	Not Applicable	Circulation or storage space.
B00C - R0005 - Design L.S. - (66.4 SQM) - Teaching Space: 1	Student Space (30)	
B00C - R1001 - General Learning Space - (52.63 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R1002 - General Learning Space - (52.92 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R1003 - Staff Study - (26.28 SQM)	Office (6)	
B00C - R1004 - Tiered Learning Area - (52.54 SQM)	Student Space (24)	
B00C - R1007 - Movement - (93.2 SQM)	Not Applicable	Circulation or storage space.
B00C - R1009 - Entry - (31.34 SQM)	Not Applicable	Circulation or storage space.
B00C - R1010 - Seminar - (13.04 SQM)	Office (3)	
B00C - R1011 - Seminar - (13.04 SQM)	Office (3)	
B00C - R1012 - Main Area - (178.71 SQM)	Not Applicable	Circulation or storage space.
B00C - R1013 - Audio Visual Workroom - (17.76 SQM)	Student Space (8)	
B00C - R1014 - Workroom - (21.16 SQM)	Office (5)	
B00C - R1016 - Interview/Office - Type 1 - (11.82 SQM)	Office (2)	
B00C - R1019 - Computer Learning Space - (69.15 SQM) - Teaching Space: 1	Student Space (32)	
B00C - R1020 - General Learning Space - (45.35 SQM) - Teaching Space: 1	Student Space (21)	
B00C - R1024 - Staff Study - (22.33 SQM)	Office (5)	
B00C - R1035 - Senior Study - (48.59 SQM)	Office (12)	
B00C - R1036 - Movement - (12.03 SQM)	Not Applicable	Circulation or storage space.
B00C - R1041 - Food Technology L.S. - (104 SQM) - Teaching Space: 1	Student Space (48)	
B00C - R1044 - Preparation - Materials - (16.02 SQM)	Not Applicable	Circulation or storage space.
B00C - R1046 - Movement - (25.77 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R0003 - Music Learning Space - (88.24 SQM) - Teaching Space: 1	● Student Space (40)	
B00D - R0004 - Practice/Seminar - (26.5 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Movement - (68.85 SQM)	Not Applicable	Circulation or storage space.
B00E - R0008 - Student Canteen - (28.43 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Clinic - Boys - (15.89 SQM)	● Office (3)	
B00F - R0003 - Deputy Principal Office - (16.42 SQM)	● Office (4)	
B00F - R0004 - Interview/Office - Type 1 - (12.74 SQM)	● Office (3)	
B00F - R0005 - Movement - (59.35 SQM)	Not Applicable	Circulation or storage space.
B00F - R0007 - Seminar - (13.28 SQM)	● Office (3)	
B00F - R0008 - Principal Office - (19.63 SQM)	● Office (4)	
B00F - R0011 - Duplicating Workroom - (18.98 SQM)	● Office (4)	
B00F - R0012 - Administration - Clerical - (23.13 SQM)	● Office (5)	
B00F - R0013 - Clinic - Girls - (14.23 SQM)	● Office (3)	
B00F - R1002 - Duplicating Workroom - (13.47 SQM)	● Office (3)	
B00F - R1003 - Commonroom - (84.96 SQM)	● Office (21)	
B00H - R0011 - Staff Kitchen - (13.82 SQM)	● Office (3)	
B00H - R0013 - Staff Study - (11.61 SQM)	● Office (2)	
B00H - R0015 - Multi-Purpose Space - (455.43 SQM)	● Student Space (211)	
B00H - R0017 - Stage - (63.58 SQM)	Not Applicable	Circulation or storage space.
B00H - R0019 - Movement - (5.95 SQM)	Not Applicable	Circulation or storage space.
B00H - R0020 - Movement - (17.98 SQM)	Not Applicable	Circulation or storage space.
B0A1 - R0001 - Welding Area - (13.75 SQM)	Not Applicable	Circulation or storage space.
B0A1 - R0026 - Metal Technology Bay - (26.43 SQM)	Not Applicable	Circulation or storage space.
B0A1 - R0027 - Metal Technology Bay - (93.49 SQM)	Not Applicable	Circulation or storage space.
B0A1 - R0028 - Metal Technology Bay - (62.53 SQM)	Not Applicable	Circulation or storage space.