


VENTILATION AUDIT REPORT

SCHOOL:	Gundagai South Public School (2103)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Cootamundra
LOCAL GOVERNMENT AREA:	Cootamundra-Gundagai

2103 - Gundagai South Public School
Site Plan (10417)



1:1,184

Printed: 17-Jun-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0004 - Duplicating Workroom - (9.48 SQM)	Office (2)	
B00A - R0008 - Movement - (25.36 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Home Base - (50.26 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R0010 - Reading Area - (40.37 SQM) - Teaching Space: 1	Student Space (18)	
B00A - R0011 - Home Base - (43.92 SQM) - Teaching Space: 1	Student Space (20)	
B00A - R0015 - Home Base - (85.94 SQM)	Student Space (39)	
B00A - R0019 - Entry Vestibule - (16.09 SQM)	Not Applicable	Circulation or storage space.
B00A - R0020 - Movement - (6.94 SQM)	Not Applicable	Circulation or storage space.
B00A - R0023 - Reading Area - (14.83 SQM)	Student Space (6)	
B00A - R0024 - Reading Area - (12.57 SQM)	Student Space (5)	
B00A - R0025 - Reading Area - (12.49 SQM)	Student Space (5)	
B00A - R0026 - Reading Area - (10.83 SQM)	Student Space (5)	
B00A - R0033 - Movement - (6.9 SQM)	Not Applicable	Circulation or storage space.
B00A - R0034 - Staff Room Annexe - (14.66 SQM)	Office (3)	
B00A - R0035 - Staff Room Annexe - (16.82 SQM)	Office (4)	
B00A - R0037 - Principal - (14.48 SQM)	Office (3)	
B00A - R0039 - Entry Vestibule - (5.88 SQM)	Not Applicable	Circulation or storage space.
B00A - R0040 - Clerical Office/Workroom - (15.68 SQM)	Office (3)	
B00A - R0041 - Sick Bay - (7.39 SQM)	Student Space (3)	
B00A - R0042 - Staff Room - (13.54 SQM)	Office (3)	
B00A - R0043 - Staff Kitchen - (5.22 SQM)	Office (1)	
B00A - R0044 - Staff Room - (19.31 SQM)	Office (4)	
B00A - R0045 - Staff Kitchen - (7.73 SQM)	Office (1)	
B00B - R0003 - Communal Space - (36.49 SQM)	Student Space (16)	
B00B - R0006 - Canteen - (9.41 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Movement - (6.82 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Reading Area - (91.98 SQM) - Teaching Space: 1	Student Space (42)	