


VENTILATION AUDIT REPORT

SCHOOL:	Gunnedah South Public School (4018)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Tamworth
LOCAL GOVERNMENT AREA:	Gunnedah
























4018 - Gunnedah South Public School
Site Plan (12705)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R0003 - Home Base - (57.05 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0005 - Interview - (8.42 SQM)	Office (2)	
B00B - R0006 - Sick Bay - (9.17 SQM)	Student Space (4)	
B00B - R0007 - Interview - (9.17 SQM)	Office (2)	
B00B - R0008 - Clerical Office - (12.16 SQM)	Office (3)	
B00B - R0009 - Movement - (16.9 SQM)	Not Applicable	Circulation or storage space.
B00B - R0010 - Movement - (5.69 SQM)	Not Applicable	Circulation or storage space.
B00B - R0011 - Entry Vestibule - (12.13 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Principal - (20.63 SQM)	Office (5)	
B00B - R0014 - Reading Area - (229.94 SQM)	Student Space (106)	
B00B - R0017 - Special Programs Room - (43.59 SQM)	Student Space (20)	
B00B - R0027 - Movement - (20.88 SQM)	Not Applicable	Circulation or storage space.
B00B - R0028 - Deputy Principal - (12.7 SQM)	Office (3)	
B00B - R0029 - Interview - (12.38 SQM)	Office (3)	
B00B - R0032 - Duplicating Workroom - (33.33 SQM)	Office (8)	
B00B - R0033 - Interview - (12.66 SQM)	Office (3)	
B00B - R0034 - Movement - (168.51 SQM)	Not Applicable	Circulation or storage space.
B00B - R0041 - Special Programs Room - (31.36 SQM)	Student Space (14)	
B00C - R0001 - Movement - (100.06 SQM)	Not Applicable	Circulation or storage space.
B00C - R0006 - Special Programs Room - (60.07 SQM)	Student Space (27)	
B00C - R0007 - Home Base - (57.43 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0012 - Home Base - (57.44 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R1001 - Movement - (97.6 SQM)	Not Applicable	Circulation or storage space.
B00C - R1002 - Staff Room - (85.85 SQM)	Office (21)	
B00C - R1004 - Practical Activities - 1hb - (16.28 SQM)	Student Space (7)	
B00C - R1005 - Home Base - (62.35 SQM) - Teaching Space: 1	Student Space (28)	
B00C - R1006 - Home Base - (57.45 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R1011 - Home Base - (56.9 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0001 - Withdrawal Space - 1hb - (16.47 SQM)	Student Space (7)	
B00D - R0002 - Home Base - (51.84 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0006 - Home Base - (51.99 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0010 - Home Base - (51.99 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0011 - Home Base - (71.61 SQM) - Teaching Space: 1	Student Space (33)	
B00D - R0015 - Movement - (107.7 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Home Base - (86.87 SQM) - Teaching Space: 1	Student Space (40)	
B00E - R0005 - Home Base - (57.21 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R0008 - Movement - (42.05 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Practical Activities - 1hb - (14.64 SQM)	Student Space (6)	
B00F - R0003 - Home Base - (53.75 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R0004 - Home Base - (67.49 SQM) - Teaching Space: 1	Student Space (31)	
B00F - R0006 - Practical Activities - 1hb - (17.68 SQM)	Student Space (8)	
B00F - R0008 - Movement - (45.66 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Movement - (20.17 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Canteen - (36.58 SQM)	Not Applicable	Circulation or storage space.
B00K - R0001 - Communal Space - (223.06 SQM)	Student Space (103)	
B00K - R0002 - Raised Platform - (65.63 SQM)	Not Applicable	Circulation or storage space.
B00K - R0015 - Canteen - (42.37 SQM)	Not Applicable	Circulation or storage space.
B00K - R0016 - Movement - (6.69 SQM)	Not Applicable	Circulation or storage space.
B00M - R0002 - Practical Activities - 1hb - (18.94 SQM)	Student Space (8)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00M - R0004 - Home Base - (59.5 SQM) - Teaching Space: 1	 Student Space (27)	
B00M - R0005 - Withdrawal Space - 2hb - (11.59 SQM)	 Student Space (5)	
B00M - R0006 - Home Base - (60.28 SQM) - Teaching Space: 1	 Student Space (27)	
B00M - R0008 - Practical Activities - 1hb - (18.94 SQM)	 Student Space (8)	
B00M - R0011 - Special Programs Room - (38.39 SQM)	 Student Space (17)	
B00N - R0002 - Practical Activities - 1hb - (19.06 SQM)	 Student Space (8)	
B00N - R0004 - Home Base - (60.31 SQM) - Teaching Space: 1	 Student Space (27)	
B00N - R0005 - Withdrawal Space - 2hb - (11.62 SQM)	 Student Space (5)	
B00N - R0006 - Home Base - (60.9 SQM) - Teaching Space: 1	 Student Space (28)	
B00N - R0008 - Practical Activities - 1hb - (19.04 SQM)	 Student Space (8)	
B00N - R0009 - Practical Activities - 1hb - (18.99 SQM)	 Student Space (8)	
B00N - R0011 - Home Base - (60.33 SQM) - Teaching Space: 1	 Student Space (27)	
B00N - R0012 - Withdrawal Space - 2hb - (11.62 SQM)	 Student Space (5)	
B00N - R0013 - Home Base - (60.24 SQM) - Teaching Space: 1	 Student Space (27)	
B00N - R0015 - Practical Activities - 1hb - (19.04 SQM)	 Student Space (8)	
B00O - R0001 - Special Programs Room - (96.29 SQM)	 Student Space (44)	
OS 602 10569 - OS 602 10569 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 12668 - OS 602 12668 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 14315 - OS 602 14315 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 603 10437 - OS 603 10437 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	 Student Space (35)	
OS 603 10942 - OS 603 10942 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	 Student Space (35)	
OS 603 11033 - OS 603 11033 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	 Student Space (35)	
OS 606 19156 - OS 606 19156 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	