

VENTILATION AUDIT REPORT

SCHOOL:	Gunning Public School (2111)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Goulburn
LOCAL GOVERNMENT AREA:	Upper Lachlan

2111 - Gunning Public School
Site Plan (12778)



1:873

Printed: 23-Feb-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0007 - Movement - (27.01 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Canteen - (19.99 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Home Base - (53.14 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0005 - Movement - (9.77 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Movement - (6.76 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Special Programs Room - (53.14 SQM)	● Student Space (24)	
B00B - R0011 - Movement - (5.95 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Movement - (5.55 SQM)	Not Applicable	Circulation or storage space.
B00C - R0003 - Withdrawal Space - 1hb - (7.65 SQM)	● Student Space (3)	
B00C - R0004 - Withdrawal Space - 1hb - (19.95 SQM)	● Student Space (9)	
B00C - R0006 - Home Base - (88.15 SQM) - Teaching Space: 1	● Student Space (40)	
B00C - R0007 - Practical Activities - 1hb - (9.39 SQM)	● Student Space (4)	
B00C - R0010 - Movement - (41.57 SQM)	Not Applicable	Circulation or storage space.
B00C - R0011 - Home Base - (102.85 SQM) - Teaching Space: 1	● Student Space (47)	
B00C - R0013 - Movement - (5.46 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Communal Space - (105.26 SQM)	● Student Space (48)	
B00D - R0002 - Movement - (27.09 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Home Base - (53.14 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0003 - Movement - (8.6 SQM)	Not Applicable	Circulation or storage space.
B00F - R0011 - Principal - (23.62 SQM)	● Office (5)	
B00F - R0012 - Movement - (16.99 SQM)	Not Applicable	Circulation or storage space.
B00F - R0013 - Clerical Office - (23.76 SQM)	● Office (5)	
B00F - R0014 - Movement - (9.94 SQM)	Not Applicable	Circulation or storage space.
B00F - R0015 - Sick Bay - (9.61 SQM)	● Student Space (4)	
B00F - R0017 - Staff Room - (29.45 SQM)	● Office (7)	
B00G - R0001 - Withdrawal Space - 1hb - (11.61 SQM)	● Student Space (5)	
B00G - R0004 - Home Base - (47.32 SQM) - Teaching Space: 1	● Student Space (21)	
B00G - R0005 - Special Programs Room - (43.42 SQM)	● Student Space (20)	
B00G - R0007 - Movement - (18.19 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Movement - (19.86 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Entry Vestibule - (10.7 SQM)	Not Applicable	Circulation or storage space.
B00H - R0003 - Clerical Office/Workroom - (14.53 SQM)	● Office (3)	
B00H - R0004 - Duplicating Workroom - (11.17 SQM)	● Office (2)	
B00H - R0006 - Sick Bay - (10.8 SQM)	● Student Space (5)	
B00H - R0007 - Movement - (5.09 SQM)	Not Applicable	Circulation or storage space.
B00H - R0010 - Staff Room - (15.55 SQM)	● Office (3)	
B00H - R0011 - Staff Room Annexe - (15.24 SQM)	● Office (3)	
B00H - R0012 - Movement - (8.67 SQM)	Not Applicable	Circulation or storage space.
B00H - R0013 - Principal - (16.32 SQM)	● Office (4)	
B00K - R0005 - Reading Area - (91.78 SQM)	● Student Space (42)	
OS 606 19260 - OS 606 19260 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	