

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Gymea Bay Public School (2116)</b>
<b>AMU REGION:</b>	<b>Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Cronulla</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Sutherland</b>

2116 - Gymea Bay Public School  
Site Plan (12641)




## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Home Base - (67.59 SQM) - Teaching Space: 1	Student Space (31)	
B00A - R0006 - Home Base - (67.43 SQM) - Teaching Space: 1	Student Space (31)	
B00A - R0009 - Movement - (17.51 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Special Programs Room - (19.39 SQM)	Student Space (8)	
B00A - R0015 - Special Programs Room - (67.45 SQM)	Student Space (31)	
B00A - R0016 - Staff Room Annexe - (13.22 SQM)	Office (3)	
B00A - R0017 - Duplicating Workroom - (13.14 SQM)	Office (3)	
B00A - R0018 - Sick Bay - (6.65 SQM)	Student Space (3)	
B00A - R0019 - Deputy Principal - (18.98 SQM)	Office (4)	
B00A - R0022 - Principal - (18.06 SQM)	Office (4)	
B00A - R0023 - Entry Vestibule - (22.43 SQM)	Not Applicable	Circulation or storage space.
B00A - R0025 - Clerical Office - (14.42 SQM)	Office (3)	
B00A - R0026 - Clerical Office/Workroom - (17.32 SQM)	Office (4)	
B00A - R0027 - Movement - (5.81 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Movement - (73.71 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Special Programs Room - (42.72 SQM)	Student Space (19)	
B00B - R0008 - Reading Area - (219.64 SQM)	Student Space (101)	
B00B - R0009 - Movement - (13.99 SQM)	Not Applicable	Circulation or storage space.
B00B - R0010 - Movement - (13.98 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Movement - (13.51 SQM)	Not Applicable	Circulation or storage space.
B00C - R0005 - Staff Kitchen - (15.47 SQM)	Office (3)	
B00C - R0007 - Movement - (18.09 SQM)	Not Applicable	Circulation or storage space.
B00C - R0012 - Raised Platform - (85.9 SQM)	Not Applicable	Circulation or storage space.
B00C - R0016 - Communal Space - (314.66 SQM)	Student Space (145)	
B00D - R0002 - Staff Room Annexe - (18.1 SQM)	Office (4)	
B00D - R0005 - Movement - (19.77 SQM)	Not Applicable	Circulation or storage space.
B00D - R0008 - Home Base - (45.83 SQM) - Teaching Space: 1	Student Space (21)	
B00E - R0001 - Withdrawal Space - 1hb - (29.52 SQM)	Student Space (13)	
B00E - R0003 - Home Base - (83.27 SQM) - Teaching Space: 1	Student Space (38)	
B00G - R0001 - Home Base - (57.09 SQM) - Teaching Space: 1	Student Space (26)	
B00G - R0004 - Movement - (5.03 SQM)	Not Applicable	Circulation or storage space.
B00G - R0007 - Home Base - (56.4 SQM) - Teaching Space: 1	Student Space (26)	
B00G - R0008 - Home Base - (56.4 SQM) - Teaching Space: 1	Student Space (26)	
B00H - R0001 - Home Base - (66.05 SQM) - Teaching Space: 1	Student Space (30)	
B00H - R0004 - Movement - (17.61 SQM)	Not Applicable	Circulation or storage space.
B00H - R0005 - Movement - (5.18 SQM)	Not Applicable	Circulation or storage space.
B00H - R0007 - Withdrawal Space - 1hb - (19.38 SQM)	Student Space (8)	
B00H - R0010 - Home Base - (65.87 SQM) - Teaching Space: 1	Student Space (30)	
B00H - R0011 - Home Base - (65.87 SQM) - Teaching Space: 1	Student Space (30)	
B00H - R0015 - Movement - (7.86 SQM)	Not Applicable	Circulation or storage space.
B00H - R0016 - Movement - (5.22 SQM)	Not Applicable	Circulation or storage space.
B00H - R0018 - Home Base - (67.35 SQM) - Teaching Space: 1	Student Space (31)	
B00I - R0001 - Home Base - (55.42 SQM) - Teaching Space: 1	Student Space (25)	
B00I - R0004 - Movement - (19.44 SQM)	Not Applicable	Circulation or storage space.
B00I - R0005 - Movement - (8.42 SQM)	Not Applicable	Circulation or storage space.
B00I - R0011 - Home Base - (55.43 SQM) - Teaching Space: 1	Student Space (25)	
B00I - R1001 - Home Base - (55.44 SQM) - Teaching Space: 1	Student Space (25)	
B00I - R1004 - Movement - (19.16 SQM)	Not Applicable	Circulation or storage space.
B00I - R1009 - Home Base - (55.44 SQM) - Teaching Space: 1	Student Space (25)	
B00J - R0001 - Outdoor Learning Area - (31.96 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00J - R0002 - Outdoor Learning Area - (31.96 SQM)	Not Applicable	Circulation or storage space.
B00J - R0003 - Home Base - (66.82 SQM) - Teaching Space: 1	● Student Space (31)	
B00J - R0006 - Home Base - (53.45 SQM) - Teaching Space: 1	● Student Space (24)	
B00J - R0008 - Home Base - (64.73 SQM) - Teaching Space: 1	● Student Space (30)	
B00J - R0012 - Home Base - (53.61 SQM) - Teaching Space: 1	● Student Space (24)	
B00J - R0013 - Home Base - (53.61 SQM) - Teaching Space: 1	● Student Space (24)	
B00J - R0016 - Home Base - (53.61 SQM) - Teaching Space: 1	● Student Space (24)	
B00J - R0019 - Movement - (6.87 SQM)	Not Applicable	Circulation or storage space.
B00J - R0022 - Staff Room Annexe - (13.95 SQM)	● Office (3)	
B00J - R0024 - Staff Room Annexe - (14.85 SQM)	● Office (3)	
B00J - R0025 - Movement - (6.85 SQM)	Not Applicable	Circulation or storage space.
B00J - R0026 - Movement - (6.56 SQM)	Not Applicable	Circulation or storage space.
B00J - R0027 - Home Base - (53.61 SQM) - Teaching Space: 1	● Student Space (24)	
B00J - R0028 - Home Base - (53.61 SQM) - Teaching Space: 1	● Student Space (24)	
B00J - R0030 - Home Base - (53.6 SQM) - Teaching Space: 1	● Student Space (24)	
B00J - R0031 - Home Base - (53.61 SQM) - Teaching Space: 1	● Student Space (24)	
B00J - R0035 - Home Base - (65.28 SQM) - Teaching Space: 1	● Student Space (30)	
B00J - R0040 - Movement - (138.27 SQM)	Not Applicable	Circulation or storage space.
B00J - R0041 - Home Base - (67 SQM) - Teaching Space: 1	● Student Space (31)	
B00J - R0042 - Movement - (260.48 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Movement - (19.76 SQM)	Not Applicable	Circulation or storage space.
B00L - R0005 - Canteen - (51.42 SQM)	Not Applicable	Circulation or storage space.
B00L - R0006 - Special Programs Room - (23.71 SQM)	● Student Space (11)	
B00L - R0015 - Movement - (136.45 SQM)	Not Applicable	Circulation or storage space.
B00M - R0002 - Movement - (6.55 SQM)	Not Applicable	Circulation or storage space.
B00M - R0009 - Movement - (7.35 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0013 - Movement - (9.66 SQM)	Not Applicable	Circulation or storage space.
B00R - R0001 - Movement - (38.49 SQM)	Not Applicable	Circulation or storage space.
B00R - R0002 - Practical Activities - 1hb - (19.4 SQM)	● Student Space (9)	
B00R - R0004 - Home Base - (59.21 SQM) - Teaching Space: 1	● Student Space (27)	
B00R - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	● Student Space (5)	
B00R - R0006 - Home Base - (59.22 SQM) - Teaching Space: 1	● Student Space (27)	
B00R - R0008 - Practical Activities - 1hb - (19.41 SQM)	● Student Space (9)	
B00S - R0001 - Home Base - (59.82 SQM) - Teaching Space: 1	● Student Space (27)	
B00S - R0002 - Practical Activities - 1hb - (18.65 SQM)	● Student Space (8)	
B00S - R0003 - Withdrawal Space - 1hb - (8.95 SQM)	● Student Space (4)	
B00S - R0005 - Home Base - (60.55 SQM) - Teaching Space: 1	● Student Space (28)	
B00S - R0007 - Practical Activities - 1hb - (18.84 SQM)	● Student Space (8)	
B00S - R0008 - Withdrawal Space - 2hb - (12.52 SQM)	● Student Space (5)	
B00S - R0009 - Home Base - (60.48 SQM) - Teaching Space: 1	● Student Space (28)	
B00S - R0011 - Practical Activities - 1hb - (18.47 SQM)	● Student Space (8)	
B00S - R1001 - Home Base - (59.46 SQM) - Teaching Space: 1	● Student Space (27)	
B00S - R1002 - Practical Activities - 1hb - (18.59 SQM)	● Student Space (8)	
B00S - R1003 - Withdrawal Space - 1hb - (8.87 SQM)	● Student Space (4)	
B00S - R1005 - Home Base - (60.09 SQM) - Teaching Space: 1	● Student Space (27)	
B00S - R1007 - Practical Activities - 1hb - (18.86 SQM)	● Student Space (8)	
B00S - R1008 - Withdrawal Space - 2hb - (12.52 SQM)	● Student Space (5)	
B00S - R1009 - Home Base - (60.19 SQM) - Teaching Space: 1	● Student Space (27)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00S - R1011 - Practical Activities - 1hb - (18.54 SQM)	 Student Space (8)	