

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Gymea North Public School (4389)</b>
<b>AMU REGION:</b>	<b>Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Miranda</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Sutherland</b>

4389 - Gymea North Public School  
Site Plan (12711)




































1:920

Printed: 20-Aug-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Interview - (13.28 SQM)	 Office (3)	
B00A - R0003 - Clerical Office - (13.46 SQM)	 Office (3)	
B00A - R0004 - Duplicating Workroom - (12.99 SQM)	 Office (3)	
B00A - R0005 - Principal - (22.47 SQM)	 Office (5)	
B00A - R0006 - Sick Bay - (10.33 SQM)	 Student Space (4)	
B00A - R0008 - Staff Room Annexe - (14.47 SQM)	 Office (3)	
B00A - R0010 - Staff Room - (80.94 SQM)	 Office (20)	
B00A - R0017 - Deputy Principal - (15.07 SQM)	 Office (3)	
B00A - R0018 - Entry Vestibule - (17.17 SQM)	Not Applicable	Circulation or storage space.
B00A - R0019 - Movement - (27.53 SQM)	Not Applicable	Circulation or storage space.
B00A - R1002 - Reading Area - (54.58 SQM)	 Student Space (25)	
B00A - R1004 - Reading Area - (179.97 SQM)	 Student Space (83)	
B00A - R1013 - Movement - (5.16 SQM)	Not Applicable	Circulation or storage space.
B00A - R1014 - Movement - (13.05 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Practical Activities - 1hb - (13.19 SQM)	 Student Space (6)	
B00B - R0002 - Home Base - (57.43 SQM) - Teaching Space: 1	 Student Space (26)	
B00B - R0006 - Home Base - (56.88 SQM) - Teaching Space: 1	 Student Space (26)	
B00B - R0007 - Practical Activities - 1hb - (12.8 SQM)	 Student Space (5)	
B00B - R0009 - Practical Activities - 1hb - (12.64 SQM)	 Student Space (5)	
B00B - R0010 - Home Base - (58.31 SQM) - Teaching Space: 1	 Student Space (27)	
B00B - R0011 - Movement - (90.76 SQM)	Not Applicable	Circulation or storage space.
B00B - R0014 - Canteen - (23.7 SQM)	Not Applicable	Circulation or storage space.
B00B - R0016 - Movement - (88.7 SQM)	Not Applicable	Circulation or storage space.
B00B - R0023 - Practical Activities - 1hb - (12.88 SQM)	 Student Space (5)	
B00B - R0024 - Home Base - (57.04 SQM) - Teaching Space: 1	 Student Space (26)	
B00B - R1001 - Practical Activities - 1hb - (12 SQM)	 Student Space (5)	
B00B - R1002 - Home Base - (59.64 SQM) - Teaching Space: 1	 Student Space (27)	
B00B - R1004 - Home Base - (58.69 SQM) - Teaching Space: 1	 Student Space (27)	
B00B - R1005 - Practical Activities - 1hb - (11.21 SQM)	 Student Space (5)	
B00B - R1007 - Home Base - (59.71 SQM) - Teaching Space: 1	 Student Space (27)	
B00B - R1008 - Practical Activities - 1hb - (10.7 SQM)	 Student Space (4)	
B00B - R1009 - Practical Activities - 1hb - (11.1 SQM)	 Student Space (5)	
B00B - R1010 - Home Base - (59.08 SQM) - Teaching Space: 1	 Student Space (27)	
B00B - R1012 - Movement - (80.2 SQM)	Not Applicable	Circulation or storage space.
B00B - R1014 - Movement - (27.4 SQM)	Not Applicable	Circulation or storage space.
B00B - R1015 - Home Base - (60.83 SQM) - Teaching Space: 1	 Student Space (28)	
B00B - R1016 - Practical Activities - 1hb - (11.85 SQM)	 Student Space (5)	
B00B - R1017 - Home Base - (81.6 SQM) - Teaching Space: 1	 Student Space (37)	
B00B - R1018 - Home Base - (43.92 SQM) - Teaching Space: 1	 Student Space (20)	
B00B - R1019 - Practical Activities - 1hb - (16.27 SQM)	 Student Space (7)	
B00B - R1020 - Movement - (71.71 SQM)	Not Applicable	Circulation or storage space.
B00B - R1021 - Home Base - (55.74 SQM) - Teaching Space: 1	 Student Space (25)	
B00B - R1022 - Practical Activities - 1hb - (12.4 SQM)	 Student Space (5)	
B00C - R0002 - Movement - (5 SQM)	Not Applicable	Circulation or storage space.
B00C - R0003 - Movement - (43.48 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Movement - (5.05 SQM)	Not Applicable	Circulation or storage space.
B00C - R0010 - Movement - (32.27 SQM)	Not Applicable	Circulation or storage space.
B00C - R0011 - Movement - (43.12 SQM)	Not Applicable	Circulation or storage space.
B00C - R0012 - Movement - (28.21 SQM)	Not Applicable	Circulation or storage space.
B00C - R0016 - Movement - (20.43 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R0024 - Movement - (47.88 SQM)	Not Applicable	Circulation or storage space.
B00C - R0025 - Practical Activities - (144.16 SQM)	● Student Space (66)	
B00C - R0029 - Practical Activities - (59.34 SQM)	● Student Space (27)	
B00C - R0032 - Practical Activities - 1hb - (59.44 SQM)	● Student Space (27)	
B00D - R0001 - Communal Space - (143.34 SQM)	● Student Space (66)	
B00D - R0002 - Raised Platform - (62.07 SQM)	Not Applicable	Circulation or storage space.
B00D - R0017 - Canteen - (27.19 SQM)	Not Applicable	Circulation or storage space.
B00D - R0021 - Movement - (13.15 SQM)	Not Applicable	Circulation or storage space.
B00D - R0022 - Movement - (6.92 SQM)	Not Applicable	Circulation or storage space.
OS 601 10345 - OS 601 10345 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 602 13047 - OS 602 13047 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 606 19006 - OS 606 19006 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	