


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>GyMEA Technology High School (8386)</b>
<b>AMU REGION:</b>	<b>Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Miranda</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Sutherland</b>

8386 - GyMEA Technology High School  
Site Plan (12710)



1:2,231















Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Staff Study - (26.2 SQM)	Office (6)	
B00A - R0004 - Food Technology L.S. - (87.3 SQM) - Teaching Space: 1	Student Space (40)	
B00A - R0006 - Preparation - (25.1 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Food Technology L.S. - (87.3 SQM) - Teaching Space: 1	Student Space (40)	
B00A - R0010 - Movement - (6.6 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Food/Research Space - (19.37 SQM)	Not Applicable	Circulation or storage space.
B00A - R0015 - Art Learning Space - (75.86 SQM) - Teaching Space: 1	Student Space (35)	
B00A - R0017 - Multi Media Workshop - (24.6 SQM)	Not Applicable	Circulation or storage space.
B00A - R0018 - Art Learning Space - (67.2 SQM) - Teaching Space: 1	Student Space (31)	
B00A - R0023 - Movement - (102.24 SQM)	Not Applicable	Circulation or storage space.
B00A - R0025 - Movement - (19.94 SQM)	Not Applicable	Circulation or storage space.
B00A - R1004 - General Learning Space - (53.23 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1005 - Computer Learning Space - (60.31 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1007 - Music Learning Space - (59.77 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1012 - Music Learning Space - (52.13 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1014 - Computer Learning Space - (65.88 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R1016 - Design L.S. - (67.06 SQM) - Teaching Space: 1	Student Space (31)	
B00A - R1017 - Staff Study - (40.09 SQM)	Office (10)	
B00A - R1019 - Movement - (17.66 SQM)	Not Applicable	Circulation or storage space.
B00A - R1020 - Movement - (19.78 SQM)	Not Applicable	Circulation or storage space.
B00A - R1021 - Movement - (80.72 SQM)	Not Applicable	Circulation or storage space.
B00A - R1023 - Staff Study - (24.11 SQM)	Office (6)	
B00A - R1030 - Movement - (15.92 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - General Assistants - (11.52 SQM)	Office (2)	
B00B - R0009 - Multi-Purpose Space - (325.98 SQM)	Student Space (151)	
B00B - R0011 - Student Canteen - (49.04 SQM)	Not Applicable	Circulation or storage space.
B00B - R0015 - Movement - (14.47 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Design/Technology L.S. - (67.12 SQM) - Teaching Space: 1	Student Space (31)	
B00C - R0002 - Materials Technology L.S. - (80.21 SQM) - Teaching Space: 1	Student Space (37)	
B00C - R0006 - Materials Technology L.S. - (81.24 SQM) - Teaching Space: 1	Student Space (37)	
B00C - R0009 - Materials Technology L.S. - (95.76 SQM) - Teaching Space: 1	Student Space (44)	
B00C - R0010 - Welding Area - (8 SQM)	Not Applicable	Circulation or storage space.
B00C - R0014 - Design L.S. - (53.52 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0018 - Movement - (79.1 SQM)	Not Applicable	Circulation or storage space.
B00C - R0023 - Staff Study - (16.36 SQM)	Office (4)	
B00C - R0024 - Food Technology L.S. - (53.15 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0002 - Movement - (31.61 SQM)	Not Applicable	Circulation or storage space.
B00D - R0012 - General Learning Space - (67.14 SQM) - Teaching Space: 1	Student Space (31)	
B00D - R0015 - Interview/Meeting - (26.92 SQM)	Office (6)	
B00D - R0016 - General Learning Space - (53.08 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0030 - Public Entry - (71.98 SQM)	Not Applicable	Circulation or storage space.
B00D - R0031 - Administration - Clerical - (48.07 SQM)	Office (12)	
B00D - R0032 - Student Waiting - (12.07 SQM)	Not Applicable	Circulation or storage space.
B00D - R0033 - Clinic - (10.67 SQM)	Office (2)	
B00D - R0036 - Administration - Executive - (12.12 SQM)	Office (3)	
B00D - R0037 - Principal Office - (20.11 SQM)	Office (5)	
B00D - R0038 - Deputy Principal Office - (16.92 SQM)	Office (4)	
B00D - R0039 - Deputy Principal Office - (17.37 SQM)	Office (4)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R0040 - Movement - (69.97 SQM)	Not Applicable	Circulation or storage space.
B00D - R0046 - Interview/Office - Type 1 - (13.44 SQM)	Office (3)	
B00D - R0047 - Interview/Office - Type 1 - (8.89 SQM)	Office (2)	
B00D - R0048 - Commonroom - (50.37 SQM)	Office (12)	
B00D - R0049 - Staff Kitchen - (9.06 SQM)	Office (2)	
B00D - R1001 - General Learning Space - (40.49 SQM) - Teaching Space: 1	Student Space (18)	
B00D - R1002 - General Learning Space - (66.99 SQM) - Teaching Space: 1	Student Space (31)	
B00D - R1005 - General Learning Space - (53.15 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1007 - Computer Learning Space - (53.37 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1009 - Staff Study - (26.98 SQM)	Office (6)	
B00D - R1011 - General Learning Space - (53.22 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1012 - General Learning Space - (53.37 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1013 - General Learning Space - (53.22 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1014 - General Learning Space - (46.19 SQM) - Teaching Space: 1	Student Space (21)	
B00D - R1016 - Movement - (124.49 SQM)	Not Applicable	Circulation or storage space.
B00D - R1017 - Staff Study - (31.62 SQM)	Office (7)	
B00E - R0002 - General Learning Space - (53.45 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0003 - Laboratory L.S. - (87.18 SQM) - Teaching Space: 1	Student Space (40)	
B00E - R0004 - Preparation - Science - (38.52 SQM)	Not Applicable	Circulation or storage space.
B00E - R0009 - General Learning Space - (53.01 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0010 - General Learning Space - (52.48 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0012 - General Learning Space - (52.94 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0013 - General Learning Space - (53.45 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0014 - Movement - (116.41 SQM)	Not Applicable	Circulation or storage space.
B00E - R0019 - General Learning Space - (42.83 SQM) - Teaching Space: 1	Student Space (19)	
B00E - R0020 - Laboratory L.S. - (43.93 SQM) - Teaching Space: 1	Student Space (20)	
B00E - R1001 - General Learning Space - (53.23 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1002 - General Learning Space - (52.94 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1003 - General Learning Space - (52.31 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1004 - General Learning Space - (52.94 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1005 - General Learning Space - (53.23 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1008 - General Learning Space - (52.72 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1009 - General Learning Space - (52.49 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1013 - General Learning Space - (39.54 SQM) - Teaching Space: 1	Student Space (18)	
B00E - R1014 - General Learning Space - (53.45 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1016 - Movement - (118.79 SQM)	Not Applicable	Circulation or storage space.
B00E - R1020 - Staff Study - (24.48 SQM)	Office (6)	
B00F - R0001 - Stage - (94.49 SQM)	Not Applicable	Circulation or storage space.
B00F - R0003 - Multi-Purpose Space - (454.1 SQM)	Student Space (210)	
B00F - R0006 - Movement - (21.28 SQM)	Not Applicable	Circulation or storage space.
B00F - R0008 - Staff Kitchen - (15.79 SQM)	Office (3)	
B00G - M1002 - Interview/Office - Type 1 - (15.31 SQM)	Office (3)	
B00G - M1004 - Senior Study - (69.3 SQM)	Office (17)	
B00G - R0001 - Laboratory L.S. - (91.24 SQM) - Teaching Space: 1	Student Space (42)	
B00G - R0005 - Laboratory L.S. - (91.25 SQM) - Teaching Space: 1	Student Space (42)	
B00G - R0010 - Laboratory L.S. - (91.04 SQM) - Teaching Space: 1	Student Space (42)	
B00G - R0013 - Movement - (39.79 SQM)	Not Applicable	Circulation or storage space.
B00G - R0019 - Preparation - Science - (48.56 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0020 - Staff Study - (45.13 SQM)	 Office (11)	
B00G - R0022 - General Learning Space - (70.61 SQM) - Teaching Space: 1	 Student Space (32)	
B00G - R1009 - Audio Visual Workroom - (28.31 SQM)	 Student Space (13)	
B00G - R1016 - Computer Learning Space - (70.25 SQM) - Teaching Space: 1	 Student Space (32)	
B00G - R1020 - Main Entry - (33.97 SQM)	Not Applicable	Circulation or storage space.
B00G - R1021 - Main Area - (286.59 SQM)	Not Applicable	Circulation or storage space.
B00G - R1022 - Staff Kitchen - (12.36 SQM)	 Office (3)	
B00G - R1026 - Seminar - (25 SQM)	 Office (6)	
B00G - R1027 - Seminar - (24.95 SQM)	 Office (6)	
B00H - R0001 - Workshop - (71.61 SQM)	 Student Space (33)	
B00H - R0007 - Workshop - (81.78 SQM)	 Student Space (37)	
B00J - R0002 - Fitness Laboratory - (163.51 SQM)	 Student Space (75)	
B00J - R0007 - Staff Study - (19.45 SQM)	 Office (4)	
B00J - R0009 - Movement - (9.7 SQM)	Not Applicable	Circulation or storage space.
B00J - R0011 - Fitness Laboratory - (33.58 SQM)	 Student Space (15)	
B00K - R0002 - Music Learning Space - (53.67 SQM) - Teaching Space: 1	 Student Space (24)	
B00L - R0001 - Performance Workshop - (114.11 SQM)	 Student Space (52)	