

VENTILATION AUDIT REPORT

SCHOOL:	Hallidays Point Public School (4611)
AMU REGION:	North Coast
STATE ELECTORATE:	Myall Lakes
LOCAL GOVERNMENT AREA:	Mid-Coast

4611 - Hallidays Point Public School
Site Plan (13265)



1:1,272

Printed: 24-Dec-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0003 - Staff Room - (41.16 SQM)	Office (10)	
B00A - R0006 - Canteen - (16.62 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Movement - (7.22 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Sick Bay - (7.83 SQM)	Student Space (3)	
B00A - R0011 - Duplicating Workroom - (12.56 SQM)	Office (3)	
B00A - R0013 - Principal - (15.9 SQM)	Office (3)	
B00A - R0015 - Clerical Office - (49.19 SQM)	Office (12)	
B00B - R0001 - Movement - (167.61 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Practical Activities - 1hb - (18.32 SQM)	Student Space (8)	
B00B - R0005 - Home Base - (59.43 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0006 - Withdrawal Space - 1hb - (11.58 SQM)	Student Space (5)	
B00B - R0007 - Home Base - (59.36 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0009 - Practical Activities - 1hb - (17.51 SQM)	Student Space (8)	
B00B - R0011 - Home Base - (58.98 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0012 - Practical Activities - 1hb - (17.48 SQM)	Student Space (8)	
B00B - R0013 - Withdrawal Space - 1hb - (11.69 SQM)	Student Space (5)	
B00B - R0014 - Home Base - (60.14 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0016 - Practical Activities - 1hb - (17.96 SQM)	Student Space (8)	
B00C - R0001 - Reading Area - (162.58 SQM)	Student Space (75)	
B00C - R0004 - Movement - (46.83 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Communal Space - (145.1 SQM)	Student Space (67)	
B00D - R0002 - Raised Platform - (59.94 SQM)	Not Applicable	Circulation or storage space.
B00D - R0016 - Movement - (8.06 SQM)	Not Applicable	Circulation or storage space.
B00D - R0017 - Movement - (12.48 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Practical Activities - (19.03 SQM)	Student Space (8)	
B00E - R0004 - Home Base - (58.7 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0005 - Withdrawal Space - 2hb - (10.92 SQM)	Student Space (5)	
B00E - R0006 - Home Base - (58.67 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0008 - Practical Activities - (19.57 SQM)	Student Space (9)	
OS 601 13539 - OS 601 13539 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 14179 - OS 601 14179 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 602 12834 - OS 602 12834 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 13811 - OS 602 13811 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 606 13202 - OS 606 13202 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	Student Space (35)	
OS 606 19562 - OS 606 19562 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	Student Space (35)	