


VENTILATION AUDIT REPORT

SCHOOL:	Hamilton South Public School (3795)
AMU REGION:	Hunter/Central Coast
STATE ELECTORATE:	Newcastle
LOCAL GOVERNMENT AREA:	Newcastle

3795 - Hamilton South Public School
Site Plan (11090)



1:964

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Raised Platform - (19.25 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Communal Space - (155.7 SQM)	● Student Space (72)	
B00A - R0005 - Movement - (36.77 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Movement - (22.43 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Canteen - (26.18 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Practical Activities - 1hb - (18.69 SQM)	● Student Space (8)	
B00B - R0002 - Home Base - (50.85 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R0003 - Movement - (62.74 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Home Base - (50.85 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R0005 - Practical Activities - 1hb - (18.69 SQM)	● Student Space (8)	
B00B - R1001 - Practical Activities - 1hb - (18.78 SQM)	● Student Space (8)	
B00B - R1002 - Home Base - (50.96 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R1003 - Movement - (63.94 SQM)	Not Applicable	Circulation or storage space.
B00B - R1004 - Home Base - (51.2 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R1005 - Practical Activities - 1hb - (18.76 SQM)	● Student Space (8)	
B00C - R0001 - Movement - (65.23 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Practical Activities - 1hb - (18.76 SQM)	● Student Space (8)	
B00C - R0003 - Home Base - (50.88 SQM) - Teaching Space: 1	● Student Space (23)	
B00C - R0004 - Home Base - (50.88 SQM) - Teaching Space: 1	● Student Space (23)	
B00C - R0005 - Practical Activities - 1hb - (18.84 SQM)	● Student Space (8)	
B00C - R1001 - Movement - (52.9 SQM)	Not Applicable	Circulation or storage space.
B00C - R1002 - Practical Activities - 1hb - (18.78 SQM)	● Student Space (8)	
B00C - R1003 - Home Base - (51.34 SQM) - Teaching Space: 1	● Student Space (23)	
B00C - R1004 - Home Base - (51.1 SQM) - Teaching Space: 1	● Student Space (23)	
B00C - R1005 - Practical Activities - 1hb - (18.78 SQM)	● Student Space (8)	
B00D - R0002 - Movement - (48.99 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Principal - (14.61 SQM)	● Office (3)	
B00D - R0004 - Movement - (21.98 SQM)	Not Applicable	Circulation or storage space.
B00D - R0005 - Interview - (12.43 SQM)	● Office (3)	
B00D - R0006 - Staff Room - (70.57 SQM)	● Office (17)	
B00D - R0007 - Duplicating Workroom - (12.16 SQM)	● Office (3)	
B00D - R0011 - Clerical Office/Workroom - (22.9 SQM)	● Office (5)	
B00D - R0012 - Clerical Office - (13.52 SQM)	● Office (3)	
B00D - R0013 - Entry Vestibule - (12.97 SQM)	Not Applicable	Circulation or storage space.
B00D - R0014 - Deputy Principal - (12.59 SQM)	● Office (3)	
B00D - R0015 - Sick Bay - (6.98 SQM)	● Student Space (3)	
B00D - R0016 - Movement - (8.71 SQM)	Not Applicable	Circulation or storage space.
B00D - R0017 - Staff Room Annexe - (11.59 SQM)	● Office (2)	
B00D - R1001 - Movement - (36.42 SQM)	Not Applicable	Circulation or storage space.
B00D - R1002 - Reading Area - (174.62 SQM)	● Student Space (81)	
B00D - R1003 - Seminar/Study - (8.8 SQM)	● Office (2)	
B00D - R1004 - Seminar/Study - (7.65 SQM)	● Office (1)	
B00D - R1010 - Movement - (10.4 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Practical Activities - 1hb - (14.16 SQM)	● Student Space (6)	
B00E - R0002 - Home Base - (75.28 SQM) - Teaching Space: 1	● Student Space (34)	
B00E - R0003 - Movement - (35.83 SQM)	Not Applicable	Circulation or storage space.
B00E - R0005 - Practical Activities - 1hb - (14.13 SQM)	● Student Space (6)	
B00E - R0006 - Home Base - (75.65 SQM) - Teaching Space: 1	● Student Space (35)	
B00F - R0012 - Practical Activities - 1hb - (14.26 SQM)	● Student Space (6)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R0016 - Movement - (8.17 SQM)	Not Applicable	Circulation or storage space.
B00F - R0017 - Home Base - (78.85 SQM) - Teaching Space: 1	● Student Space (36)	
B00F - R0018 - Practical Activities - 1hb - (16.94 SQM)	● Student Space (7)	
B00F - R0020 - Withdrawal Space - 2hb - (17.15 SQM)	● Student Space (7)	
B00F - R0021 - Home Base - (65.43 SQM) - Teaching Space: 1	● Student Space (30)	
B00F - R0022 - Practical Activities - 1hb - (17.1 SQM)	● Student Space (7)	
B00F - R0024 - Movement - (9.58 SQM)	Not Applicable	Circulation or storage space.
B00G - R0003 - Movement - (16.9 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Movement - (5.37 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Staff Room Annexe - (8.55 SQM)	● Office (2)	
B00H - R0004 - Home Base - S - (58.28 SQM) - Teaching Space: 1	● Student Space (27)	
B00H - R0005 - Home Base - M - (58.74 SQM) - Teaching Space: 1	● Student Space (27)	
B00H - R0008 - Movement - (29.52 SQM)	Not Applicable	Circulation or storage space.
B00H - R0009 - Practical Activities - S - 1hb - (30.77 SQM)	● Student Space (14)	
B00H - R0014 - Home Base - M - (58.9 SQM) - Teaching Space: 1	● Student Space (27)	
B00H - R0019 - Movement - (74.31 SQM)	Not Applicable	Circulation or storage space.
B00J - R0003 - Practical Activities - 1hb - (18.67 SQM)	● Student Space (8)	
B00J - R0005 - Home Base - (61.11 SQM) - Teaching Space: 1	● Student Space (28)	
B00J - R0006 - Withdrawal Space - 2hb - (11.78 SQM)	● Student Space (5)	
B00J - R0007 - Practical Activities - 1hb - (19.24 SQM)	● Student Space (8)	
B00J - R0008 - Home Base - (61.1 SQM) - Teaching Space: 1	● Student Space (28)	
OS 602 16148 - OS 602 16148 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 603 14405 - OS 603 14405 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	