

VENTILATION AUDIT REPORT

SCHOOL:	Hannans Road Public School (4092)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Lakemba
LOCAL GOVERNMENT AREA:	Canterbury-Bankstown

4092 - Hannans Road Public School
Site Plan (11004)



































1:878

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R0004 - Home Base - (56.88 SQM) - Teaching Space: 1	 Student Space (26)	
B00F - R0005 - Home Base - (56.88 SQM) - Teaching Space: 1	 Student Space (26)	
B00F - R0007 - Entry Vestibule - (7.92 SQM)	Not Applicable	Circulation or storage space.
B00F - R0009 - Staff Room - (15.51 SQM)	 Office (3)	
B00F - R0013 - Practical Activities/Movement - 1hb - (6.06 SQM)	 Student Space (2)	
B00F - R0014 - Practical Activities/Movement - 1hb - (5.83 SQM)	 Student Space (2)	
B00J - R0017 - Entry Vestibule - (6.33 SQM)	Not Applicable	Circulation or storage space.
B00J - R0023 - Home Base - (80.58 SQM) - Teaching Space: 1	 Student Space (37)	
B00J - R0024 - Practical Activities/Movement - 2hb - (18.54 SQM)	 Student Space (8)	
B00J - R0025 - Home Base - (81.93 SQM) - Teaching Space: 1	 Student Space (38)	
B00J - R0028 - Home Base - (79.15 SQM) - Teaching Space: 1	 Student Space (36)	
B00J - R0029 - Home Base - (79.25 SQM) - Teaching Space: 1	 Student Space (36)	
B00J - R0030 - Practical Activities - (10.34 SQM)	 Student Space (4)	
B00J - R0031 - Practical Activities - (11.32 SQM)	 Student Space (5)	
B00K - R0016 - Movement - (5.65 SQM)	Not Applicable	Circulation or storage space.
B00K - R0020 - Practical Activities/Movement - 1hb - (16.55 SQM)	 Student Space (7)	
B00K - R0021 - Home Base - (49.74 SQM) - Teaching Space: 1	 Student Space (23)	
B00K - R0022 - Home Base - (49.2 SQM) - Teaching Space: 1	 Student Space (22)	
B00K - R0023 - Practical Activities/Movement - 1hb - (16.35 SQM)	 Student Space (7)	
B00K - R0024 - Practical Activities/Movement - 1hb - (13.4 SQM)	 Student Space (6)	
B00K - R0025 - Home Base - (39.66 SQM) - Teaching Space: 1	 Student Space (18)	
B00K - R0026 - Practical Activities - 1hb - (8.75 SQM)	 Student Space (4)	
B00K - R0027 - Home Base - (67.16 SQM) - Teaching Space: 1	 Student Space (31)	
B00K - R0028 - Practical Activities/Movement - 1hb - (13.4 SQM)	 Student Space (6)	
B00K - R0029 - Home Base - (40 SQM) - Teaching Space: 1	 Student Space (18)	
B00K - R0030 - Home Base - (39.98 SQM) - Teaching Space: 1	 Student Space (18)	
B00K - R0031 - Practical Activities/Movement - 1hb - (13.12 SQM)	 Student Space (6)	
B00L - R0003 - Reading Area - (157.62 SQM)	 Student Space (73)	
B00M - R0002 - Entry Vestibule - (10.36 SQM)	Not Applicable	Circulation or storage space.
B00M - R0003 - Clerical Office - (14.47 SQM)	 Office (3)	
B00M - R0005 - Sick Bay - (9.43 SQM)	 Student Space (4)	
B00M - R0006 - Clerical Office - (13.12 SQM)	 Office (3)	
B00M - R0010 - Movement - (17.71 SQM)	Not Applicable	Circulation or storage space.
B00M - R0011 - Duplicating Workroom - (20.04 SQM)	 Office (5)	
B00M - R0014 - Principal - (17.36 SQM)	 Office (4)	
B00M - R0015 - Staff Room - (48.82 SQM)	 Office (12)	
B00N - R0004 - Raised Platform - (39.69 SQM)	Not Applicable	Circulation or storage space.
B00N - R0005 - Communal Space - (148.96 SQM)	 Student Space (69)	
B00P - R0001 - Canteen - (26.74 SQM)	Not Applicable	Circulation or storage space.
B00R - R0002 - Movement - (7.25 SQM)	Not Applicable	Circulation or storage space.
B00R - R0003 - Movement - (7.25 SQM)	Not Applicable	Circulation or storage space.