

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Harrington Park Public School (4628)</b>
<b>AMU REGION:</b>	<b>South Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Camden</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Camden</b>

4628 - Harrington Park Public School  
Site Plan (14646)



1:1,106

Printed: 29-May-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Entry Vestibule - (17.23 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Movement - (36.79 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Clerical Office - (32.58 SQM)	Office (8)	
B00A - R0004 - Principal - (16.66 SQM)	Office (4)	
B00A - R0010 - Staff Room - (57.72 SQM)	Office (14)	
B00A - R0011 - Staff Room Annexe - (26.43 SQM)	Office (6)	
B00A - R0012 - Deputy Principal - (13.08 SQM)	Office (3)	
B00A - R0013 - Deputy Principal - (13.05 SQM)	Office (3)	
B00A - R0014 - Interview - (13.08 SQM)	Office (3)	
B00A - R0016 - Sick Bay - (8.24 SQM)	Student Space (3)	
B00A - R0017 - Duplicating Workroom - (17.65 SQM)	Office (4)	
B00A - R0021 - Movement - (10.54 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Practical Activities - 1hb - (19.92 SQM)	Student Space (9)	
B00B - R0003 - Home Base - (57.39 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0004 - Withdrawal Space - 2hb - (11.47 SQM)	Student Space (5)	
B00B - R0005 - Home Base - (57.39 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0006 - Practical Activities - 1hb - (19.92 SQM)	Student Space (9)	
B00B - R0009 - Practical Activities - 1hb - (19.94 SQM)	Student Space (9)	
B00B - R0011 - Home Base - (57.54 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0012 - Withdrawal Space - 2hb - (11.47 SQM)	Student Space (5)	
B00B - R0013 - Home Base - (57.54 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0014 - Practical Activities - 1hb - (19.92 SQM)	Student Space (9)	
B00B - R0019 - Practical Activities - 1hb - (20.02 SQM)	Student Space (9)	
B00B - R0021 - Home Base - (57.46 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0022 - Withdrawal Space - 2hb - (11.5 SQM)	Student Space (5)	
B00B - R0023 - Home Base - (57.32 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0024 - Practical Activities - 1hb - (20.06 SQM)	Student Space (9)	
B00C - R0001 - Practical Activities - 1hb - (19.94 SQM)	Student Space (9)	
B00C - R0003 - Home Base - (58.16 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0004 - Withdrawal Space - 2hb - (11.16 SQM)	Student Space (5)	
B00C - R0005 - Home Base - (58.08 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0006 - Practical Activities - 1hb - (19.94 SQM)	Student Space (9)	
B00C - R0008 - Practical Activities - 1hb - (19.97 SQM)	Student Space (9)	
B00C - R0010 - Home Base - (58.16 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0011 - Withdrawal Space - 2hb - (11.1 SQM)	Student Space (5)	
B00C - R0012 - Home Base - (57.93 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0013 - Practical Activities - 1hb - (19.94 SQM)	Student Space (9)	
B00C - R0016 - Reading Area - (223 SQM)	Student Space (103)	
B00C - R0019 - Special Programs Room - (45.04 SQM)	Student Space (20)	
B00D - R0001 - Practical Activities - 1hb - (19.97 SQM)	Student Space (9)	
B00D - R0003 - Home Base - (57.78 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0004 - Withdrawal Space - 2hb - (11.27 SQM)	Student Space (5)	
B00D - R0005 - Home Base - (57.62 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0006 - Practical Activities - 1hb - (20.09 SQM)	Student Space (9)	
B00D - R0008 - Practical Activities - 1hb - (19.94 SQM)	Student Space (9)	
B00D - R0010 - Home Base - (57.69 SQM) - Teaching Space: 1	Student Space (26)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R0011 - Withdrawal Space - 2hb - (11.27 SQM)	Student Space (5)	
B00D - R0012 - Home Base - (57.84 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0013 - Practical Activities - 1hb - (19.99 SQM)	Student Space (9)	
B00E - R0001 - Communal Space - (219.95 SQM)	Student Space (102)	
B00E - R0002 - Raised Platform - (40.38 SQM)	Not Applicable	Circulation or storage space.
B00E - R0010 - Movement - (9.11 SQM)	Not Applicable	Circulation or storage space.
B00E - R0017 - Movement - (23.61 SQM)	Not Applicable	Circulation or storage space.
B00E - R0018 - Movement - (7.39 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Canteen - (47.49 SQM)	Not Applicable	Circulation or storage space.
B00F - R0003 - Movement - (7.74 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Practical Activities - 1hb - (19.4 SQM)	Student Space (9)	
B00G - R0004 - Home Base - (59.21 SQM) - Teaching Space: 1	Student Space (27)	
B00G - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	Student Space (5)	
B00G - R0006 - Home Base - (59.21 SQM) - Teaching Space: 1	Student Space (27)	
B00G - R0008 - Practical Activities - 1hb - (19.41 SQM)	Student Space (9)	
B00H - R0002 - Practical Activities - 1hb - (19.4 SQM)	Student Space (9)	
B00H - R0004 - Home Base - (59.21 SQM) - Teaching Space: 1	Student Space (27)	
B00H - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	Student Space (5)	
B00H - R0006 - Home Base - (59.21 SQM) - Teaching Space: 1	Student Space (27)	
B00H - R0008 - Practical Activities - 1hb - (19.41 SQM)	Student Space (9)	
B00I - R0002 - Practical Activities - 1hb - (19.23 SQM)	Student Space (8)	
B00I - R0004 - Home Base - (61.05 SQM) - Teaching Space: 1	Student Space (28)	
B00I - R0005 - Withdrawal Space - 2hb - (11.78 SQM)	Student Space (5)	
B00I - R0006 - Home Base - (61.01 SQM) - Teaching Space: 1	Student Space (28)	
B00I - R0008 - Practical Activities/Movement - 1hb - (18.64 SQM)	Student Space (8)	
B00I - R0010 - Withdrawal Space - 1hb - (7.66 SQM)	Student Space (3)	
B00I - R0012 - Home Base - (59.92 SQM) - Teaching Space: 1	Student Space (27)	
B00I - R0013 - Practical Activities/Movement - 1hb - (18.5 SQM)	Student Space (8)	
B00J - R0002 - Practical Activities/Movement - 1hb - (19.14 SQM)	Student Space (8)	
B00J - R0004 - Home Base - (61.06 SQM) - Teaching Space: 1	Student Space (28)	
B00J - R0005 - Withdrawal Space - 2hb - (11.75 SQM)	Student Space (5)	
B00J - R0006 - Home Base - (61 SQM) - Teaching Space: 1	Student Space (28)	
B00J - R0008 - Practical Activities/Movement - 1hb - (18.46 SQM)	Student Space (8)	
B00J - R0010 - Withdrawal Space - 1hb - (7.66 SQM)	Student Space (3)	
B00J - R0012 - Special Programs Room - (60.1 SQM)	Student Space (27)	
B00J - R0013 - Practical Activities/Movement - 1hb - (18.39 SQM)	Student Space (8)	
NS 100 13177 - NS 100 13177 - Learning Unit - Single Primary/PAA - (76 SQM)	Student Space (35)	
OS 602 11067 - OS 602 11067 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 12893 - OS 602 12893 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 12916 - OS 602 12916 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 14068 - OS 602 14068 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 14069 - OS 602 14069 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 19823 - OS 602 19823 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 603 10851 - OS 603 10851 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	Student Space (35)	
OS 603 12559 - OS 603 12559 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	Student Space (35)	