



## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Practical Activities - 1hb - (21.09 SQM)	● Student Space (9)	
B00A - R0003 - Home Base - (64.51 SQM) - Teaching Space: 1	● Student Space (29)	
B00A - R0005 - Home Base - (59.91 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R0006 - Practical Activities - 1hb - (21.45 SQM)	● Student Space (9)	
B00A - R0008 - Withdrawal Space - 1hb - (12.38 SQM)	● Student Space (5)	
B00A - R0012 - Practical Activities - 1hb - (21.53 SQM)	● Student Space (9)	
B00A - R0013 - Home Base - (60.14 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R0014 - Practical Activities - 1hb - (21.47 SQM)	● Student Space (9)	
B00A - R0015 - Home Base - (67.51 SQM) - Teaching Space: 1	● Student Space (31)	
B00A - R0017 - Staff Room Annexe - (16.26 SQM)	● Office (4)	
B00A - R0020 - Movement - (91.22 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Movement - (86.96 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Home Base - (65.38 SQM) - Teaching Space: 1	● Student Space (30)	
B00B - R0005 - Practical Activities - 1hb - (21.33 SQM)	● Student Space (9)	
B00B - R0006 - Practical Activities - 1hb - (21.31 SQM)	● Student Space (9)	
B00B - R0007 - Home Base - (60.21 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R0009 - Withdrawal Space - 1hb - (12.42 SQM)	● Student Space (5)	
B00B - R0011 - Home Base - (60.22 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R0012 - Practical Activities - 1hb - (21.42 SQM)	● Student Space (9)	
B00B - R0015 - Practical Activities - 1hb - (21.21 SQM)	● Student Space (9)	
B00B - R0016 - Home Base - (66.81 SQM) - Teaching Space: 1	● Student Space (30)	
B00B - R0018 - Special Programs Room - (34.96 SQM)	● Student Space (16)	
B00C - R0005 - Home Base - (64.51 SQM) - Teaching Space: 1	● Student Space (29)	
B00C - R0006 - Practical Activities - 1hb - (21.07 SQM)	● Student Space (9)	
B00C - R0007 - Practical Activities - 1hb - (21.58 SQM)	● Student Space (10)	
B00C - R0008 - Home Base - (66.8 SQM) - Teaching Space: 1	● Student Space (30)	
B00C - R0012 - Entry Vestibule - (8.9 SQM)	Not Applicable	Circulation or storage space.
B00C - R0015 - Movement - (55.8 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Entry Vestibule - (19.36 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Interview - (13.9 SQM)	● Office (3)	
B00D - R0005 - Sick Bay - (10.03 SQM)	● Student Space (4)	
B00D - R0006 - Deputy Principal - (12.31 SQM)	● Office (3)	
B00D - R0007 - Deputy Principal - (13.36 SQM)	● Office (3)	
B00D - R0014 - Staff Room - (57.61 SQM)	● Office (14)	
B00D - R0015 - Staff Room Annexe - (23 SQM)	● Office (5)	
B00D - R0017 - Principal - (17.4 SQM)	● Office (4)	
B00D - R0018 - Duplicating Workroom - (34.76 SQM)	● Office (8)	
B00D - R0019 - Clerical Office - (18.27 SQM)	● Office (4)	
B00D - R0020 - Movement - (42.84 SQM)	Not Applicable	Circulation or storage space.
B00D - R0021 - Movement - (143.45 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Canteen - (43.32 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Home Base - (57.41 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R0002 - Practical Activities - 1hb - (22.31 SQM)	● Student Space (10)	
B00F - R0004 - Withdrawal Space - 1hb - (12.57 SQM)	● Student Space (5)	
B00F - R0005 - Home Base - (57.4 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R0007 - Practical Activities - 1hb - (22.67 SQM)	● Student Space (10)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R0009 - Movement - (65.52 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Home Base - (57.4 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0002 - Practical Activities - 1hb - (22.67 SQM)	● Student Space (10)	
B00G - R0004 - Withdrawal Space - 1hb - (12.57 SQM)	● Student Space (5)	
B00G - R0005 - Home Base - (57.4 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0007 - Practical Activities - 1hb - (22.31 SQM)	● Student Space (10)	
B00G - R0009 - Movement - (35.03 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Reading Area - (227.68 SQM)	● Student Space (105)	
B00H - R0004 - Movement - (42.9 SQM)	Not Applicable	Circulation or storage space.
B00I - R0001 - Movement - (65.29 SQM)	Not Applicable	Circulation or storage space.
B00I - R0002 - Movement - (7.15 SQM)	Not Applicable	Circulation or storage space.
B00I - R0003 - Raised Platform - (41.22 SQM)	Not Applicable	Circulation or storage space.
B00I - R0004 - Movement - (7.07 SQM)	Not Applicable	Circulation or storage space.
B00I - R0012 - Communal Space - (210.99 SQM)	● Student Space (97)	
B00J - R0002 - Practical Activities - 1hb - (19.4 SQM)	● Student Space (9)	
B00J - R0004 - Home Base - (59.19 SQM) - Teaching Space: 1	● Student Space (27)	
B00J - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	● Student Space (5)	
B00J - R0006 - Home Base - (59.19 SQM) - Teaching Space: 1	● Student Space (27)	
B00J - R0008 - Practical Activities - 1hb - (19.4 SQM)	● Student Space (9)	
B00K - R0002 - Practical Activities - 1hb - (19.4 SQM)	● Student Space (9)	
B00K - R0004 - Home Base - (59.2 SQM) - Teaching Space: 1	● Student Space (27)	
B00K - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	● Student Space (5)	
B00K - R0006 - Home Base - (59.19 SQM) - Teaching Space: 1	● Student Space (27)	
B00K - R0008 - Practical Activities - 1hb - (19.4 SQM)	● Student Space (9)	
B00M - R0001 - Home Base - (60.72 SQM) - Teaching Space: 1	● Student Space (28)	
B00M - R0003 - Practical Activities - 1hb - (18.69 SQM)	● Student Space (8)	
B00M - R0004 - Withdrawal Space - 2hb - (11.47 SQM)	● Student Space (5)	
B00M - R0006 - Practical Activities - 1hb - (19.02 SQM)	● Student Space (8)	
B00M - R0007 - Home Base - (60.55 SQM) - Teaching Space: 1	● Student Space (28)	
B00N - R0001 - Withdrawal Space - 1hb - (8.84 SQM)	● Student Space (4)	
B00N - R0003 - Home Base - (59.53 SQM) - Teaching Space: 1	● Student Space (27)	
B00N - R0004 - Practical Activities - 1hb - (18.83 SQM)	● Student Space (8)	
B00N - R0006 - Practical Activities/Movement - 1hb - (18.87 SQM)	● Student Space (8)	
B00N - R0008 - Home Base - (60.55 SQM) - Teaching Space: 1	● Student Space (28)	
B00N - R0009 - Withdrawal Space - 2hb - (11.56 SQM)	● Student Space (5)	
B00N - R0010 - Practical Activities - 1hb - (18.86 SQM)	● Student Space (8)	
B00N - R0011 - Home Base - (60.7 SQM) - Teaching Space: 1	● Student Space (28)	
B00Q - R0001 - Movement - (208.89 SQM)	Not Applicable	Circulation or storage space.
NS 100 11255 - NS 100 11255 - Learning Unit - Single Primary/PAA - (76 SQM)	● Student Space (35)	
OS 601 14289 - OS 601 14289 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 602 11700 - OS 602 11700 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 12938 - OS 602 12938 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 13404 - OS 602 13404 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 16199 - OS 602 16199 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 603 12143 - OS 603 12143 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	