


VENTILATION AUDIT REPORT

SCHOOL:	Hastings Public School (4524)
AMU REGION:	North Coast
STATE ELECTORATE:	Port Macquarie
LOCAL GOVERNMENT AREA:	Port Macquarie-Hastings

4524 - Hastings Public School
Site Plan (10398)




























1:1,058

Printed: 07-Jul-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B001 - R0003 - Movement - (5.22 SQM)	Not Applicable	Circulation or storage space.
B001 - R0004 - Deputy Principal - (13.6 SQM)	Office (3)	
B001 - R0007 - Interview - (9.65 SQM)	Office (2)	
B001 - R0008 - Interview - (16.38 SQM)	Office (4)	
B001 - R0009 - Sick Bay - (12.05 SQM)	Student Space (5)	
B001 - R0010 - Principal - (20.71 SQM)	Office (5)	
B001 - R0011 - Clerical Office - (13.25 SQM)	Office (3)	
B001 - R0012 - Staff Room - (71.25 SQM)	Office (17)	
B001 - R0014 - Entry Vestibule - (47.63 SQM)	Not Applicable	Circulation or storage space.
B001 - R0015 - Duplicating Workroom - (32.38 SQM)	Office (8)	
B001 - R0019 - Communal Space - (191.58 SQM)	Student Space (88)	
B001 - R0026 - Canteen - (47.62 SQM)	Not Applicable	Circulation or storage space.
B001 - R0029 - Movement - (5.67 SQM)	Not Applicable	Circulation or storage space.
B001 - R0036 - Movement - (67.27 SQM)	Not Applicable	Circulation or storage space.
B001 - R0037 - Raised Platform - (94.3 SQM)	Not Applicable	Circulation or storage space.
B001 - R0038 - Movement - (27 SQM)	Not Applicable	Circulation or storage space.
B002 - R0001 - Home Base - (66.65 SQM) - Teaching Space: 1	Student Space (30)	
B002 - R0005 - Staff Room Annexe - (15.24 SQM)	Office (3)	
B002 - R0006 - Practical Activities - 1hb - (47.91 SQM)	Student Space (22)	
B002 - R0008 - Home Base - (58.78 SQM) - Teaching Space: 1	Student Space (27)	
B002 - R0015 - Withdrawal Space - 1hb - (12.27 SQM)	Student Space (5)	
B002 - R0016 - Home Base - (61.8 SQM) - Teaching Space: 1	Student Space (28)	
B002 - R0018 - Movement - (83.81 SQM)	Not Applicable	Circulation or storage space.
B002 - R0024 - Home Base - (57.44 SQM) - Teaching Space: 1	Student Space (26)	
B002 - R0025 - Withdrawal Space - 1hb - (12.27 SQM)	Student Space (5)	
B002 - R0026 - Home Base - (64.7 SQM) - Teaching Space: 1	Student Space (30)	
B002 - R0028 - Practical Activities - 1hb - (46.48 SQM)	Student Space (21)	
B002 - R0029 - Home Base - (58.76 SQM) - Teaching Space: 1	Student Space (27)	
B002 - R0034 - Practical Activities - 1hb - (47.66 SQM)	Student Space (22)	
B002 - R0035 - Staff Room Annexe - (15.03 SQM)	Office (3)	
B002 - R0037 - Withdrawal Space - 1hb - (16.38 SQM)	Student Space (7)	
B002 - R0038 - Home Base - (58.77 SQM) - Teaching Space: 1	Student Space (27)	
B002 - R0041 - Home Base - (58.79 SQM) - Teaching Space: 1	Student Space (27)	
B002 - R0043 - Withdrawal Space - 1hb - (12.27 SQM)	Student Space (5)	
B002 - R0044 - Home Base - (59.02 SQM) - Teaching Space: 1	Student Space (27)	
B002 - R0045 - Movement - (20.92 SQM)	Not Applicable	Circulation or storage space.
B002 - R0046 - Movement - (7.73 SQM)	Not Applicable	Circulation or storage space.
B002 - R0047 - Movement - (9.76 SQM)	Not Applicable	Circulation or storage space.
B002 - R0050 - Movement - (29.27 SQM)	Not Applicable	Circulation or storage space.
B003 - R0004 - Reading Area - (236.81 SQM)	Student Space (109)	
B003 - R0009 - Home Base - (58.85 SQM) - Teaching Space: 1	Student Space (27)	
B003 - R0014 - Withdrawal Space - 1hb - (12.27 SQM)	Student Space (5)	
B003 - R0015 - Home Base - (64.13 SQM) - Teaching Space: 1	Student Space (29)	
B003 - R0017 - Practical Activities - 1hb - (47.13 SQM)	Student Space (21)	
B003 - R0018 - Staff Room Annexe - (14.94 SQM)	Office (3)	
B003 - R0023 - Home Base - (58.36 SQM) - Teaching Space: 1	Student Space (27)	
B003 - R0024 - Withdrawal Space - 1hb - (16.47 SQM)	Student Space (7)	
B003 - R0026 - Home Base - (59.78 SQM) - Teaching Space: 1	Student Space (27)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B003 - R0027 - Home Base - (59.01 SQM) - Teaching Space: 1	 Student Space (27)	
B003 - R0029 - Practical Activities - 1hb - (49.67 SQM)	 Student Space (23)	
B003 - R0031 - Home Base - (58.39 SQM) - Teaching Space: 1	 Student Space (27)	
B003 - R0032 - Withdrawal Space - 1hb - (12.27 SQM)	 Student Space (5)	
B003 - R0033 - Movement - (20.72 SQM)	Not Applicable	Circulation or storage space.
B003 - R0034 - Movement - (9.49 SQM)	Not Applicable	Circulation or storage space.
B003 - R0035 - Movement - (7.86 SQM)	Not Applicable	Circulation or storage space.
B003 - R0050 - Staff Room Annexe - (28.93 SQM)	 Office (7)	
B003 - R0055 - Movement - (144.07 SQM)	Not Applicable	Circulation or storage space.
B004 - R0002 - Practical Activities - 1hb - (19.3 SQM)	 Student Space (8)	
B004 - R0004 - Home Base - (60.47 SQM) - Teaching Space: 1	 Student Space (28)	
B004 - R0005 - Withdrawal Space - 2hb - (11.58 SQM)	 Student Space (5)	
B004 - R0006 - Home Base - (60.09 SQM) - Teaching Space: 1	 Student Space (27)	
B004 - R0008 - Practical Activities - 1hb - (18.61 SQM)	 Student Space (8)	
B004 - R0011 - Special Programs Room - (40.22 SQM)	 Student Space (18)	
B004 - R1002 - Practical Activities - 1hb - (19.28 SQM)	 Student Space (8)	
B004 - R1004 - Home Base - (60.52 SQM) - Teaching Space: 1	 Student Space (28)	
B004 - R1005 - Withdrawal Space - 2hb - (11.77 SQM)	 Student Space (5)	
B004 - R1006 - Home Base - (60.6 SQM) - Teaching Space: 1	 Student Space (28)	
B004 - R1008 - Practical Activities - 1hb - (18.64 SQM)	 Student Space (8)	
B004 - R1009 - Withdrawal Space - 1hb - (8.97 SQM)	 Student Space (4)	
B004 - R1011 - Home Base - (59.28 SQM) - Teaching Space: 1	 Student Space (27)	
B004 - R1012 - Practical Activities - 1hb - (19.58 SQM)	 Student Space (9)	
OS 602 12571 - OS 602 12571 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 12573 - OS 602 12573 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 14019 - OS 602 14019 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 14116 - OS 602 14116 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 14456 - OS 602 14456 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 15771 - OS 602 15771 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	