


VENTILATION AUDIT REPORT

SCHOOL:	Havenlee School (5698)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Kiama
LOCAL GOVERNMENT AREA:	Shoalhaven

5698 - Havenlee School
Site Plan (11805)



1:1,198

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R0001 - Movement - (39.92 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Home Base - S - (59.73 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R0004 - Withdrawal - S - (8.87 SQM)	● Student Space (4)	
B00E - R0008 - Practical Activities - S - 1hb - (53.25 SQM)	● Student Space (24)	
B00E - R0009 - Home Base - S - (59.92 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R0010 - Withdrawal - S - (8.97 SQM)	● Student Space (4)	
B00E - R0012 - Movement - (80.48 SQM)	Not Applicable	Circulation or storage space.
B00E - R0017 - Clerical Office - (18.88 SQM)	● Office (4)	
B00E - R0018 - Movement - (23.04 SQM)	Not Applicable	Circulation or storage space.
B00E - R0020 - Movement - (6.54 SQM)	Not Applicable	Circulation or storage space.
B00E - R0021 - Principal - (13.36 SQM)	● Office (3)	
B00E - R0022 - Interview - (13.72 SQM)	● Office (3)	
B00E - R0023 - Home Base - S - (59.66 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R0025 - Withdrawal - S - (8.99 SQM)	● Student Space (4)	
B00E - R0029 - Practical Activities - S - 1hb - (53.49 SQM)	● Student Space (24)	
B00E - R0030 - Home Base - S - (59.51 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R0031 - Withdrawal - S - (8.88 SQM)	● Student Space (4)	
B00E - R0033 - Movement - (40.09 SQM)	Not Applicable	Circulation or storage space.
B00E - R0034 - Hydrotherapy - Pool - (67.72 SQM)	Not Applicable	Circulation or storage space.
B00L - R0002 - Home Base - (60.94 SQM) - Teaching Space: 1	● Student Space (28)	
BOES - R0004 - Withdrawal Space - 1hb - (5.55 SQM)	● Student Space (2)	
BOES - R0004 - Adjoining School - (5.55 SQM)	Not Applicable	Circulation or storage space.
BOES - R0006 - Adjoining School - (51.44 SQM) - Teaching Space: 1	Not Applicable	Circulation or storage space.
BOES - R0006 - Home Base - (51.44 SQM) - Teaching Space: 1	● Student Space (23)	
BOES - R0007 - Practical Activities - (28.85 SQM)	● Student Space (13)	
BOES - R0007 - Adjoining School - (28.85 SQM)	Not Applicable	Circulation or storage space.
BOES - R0010 - Adjoining School - (51.73 SQM) - Teaching Space: 1	Not Applicable	Circulation or storage space.
BOES - R0010 - Home Base - (51.73 SQM) - Teaching Space: 1	● Student Space (24)	
BOES - R0012 - Withdrawal Space - 1hb - (5.54 SQM)	● Student Space (2)	
BOES - R0012 - Adjoining School - (5.54 SQM)	Not Applicable	Circulation or storage space.
BOES - R0015 - Adjoining School - (11.09 SQM)	Not Applicable	Circulation or storage space.
BOES - R0015 - Practical Activities - 1hb - (11.09 SQM)	● Student Space (5)	
OS 601 11318 - OS 601 11318 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 14893 - OS 601 14893 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 602 18353 - OS 602 18353 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	