


VENTILATION AUDIT REPORT

SCHOOL:	Hawkesbury High School (8565)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Hawkesbury
LOCAL GOVERNMENT AREA:	Hawkesbury



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Duplicating Workroom - (26.27 SQM)	Office (6)	
B00A - R0002 - Teachers Aides - (12.97 SQM)	Office (3)	
B00A - R0003 - Interview/Office - Type 1 - (12.97 SQM)	Office (3)	
B00A - R0006 - Deputy Principal Office - (15.59 SQM)	Office (3)	
B00A - R0008 - Interview/Office - Type 1 - (13.44 SQM)	Office (3)	
B00A - R0011 - Principal Office - (18.8 SQM)	Office (4)	
B00A - R0015 - Clinic - Girls - (12.07 SQM)	Office (3)	
B00A - R0018 - Clinic - Boys - (12.07 SQM)	Office (3)	
B00A - R0019 - Movement - (75.44 SQM)	Not Applicable	Circulation or storage space.
B00A - R0021 - Movement - (168.03 SQM)	Not Applicable	Circulation or storage space.
B00A - R0023 - Administration - Clerical - (56.55 SQM)	Office (14)	
B00A - R0024 - Public Reception - (29.76 SQM)	Not Applicable	Circulation or storage space.
B00A - R0025 - Interview/Meeting - (26.08 SQM)	Office (6)	
B00A - R0026 - Staff Lounge - (16.09 SQM)	Office (4)	
B00A - R0027 - Staff Kitchen - (5.69 SQM)	Office (1)	
B00B - R0001 - Movement - (33.74 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Movement - (27.32 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Laboratory L.S. - (93.13 SQM) - Teaching Space: 1	Student Space (43)	
B00B - R0004 - Laboratory L.S. - (92.61 SQM) - Teaching Space: 1	Student Space (42)	
B00B - R0007 - Laboratory L.S. - (92.91 SQM) - Teaching Space: 1	Student Space (43)	
B00B - R0008 - Preparation - (83.63 SQM)	Not Applicable	Circulation or storage space.
B00B - R0010 - Movement - (33.11 SQM)	Not Applicable	Circulation or storage space.
B00B - R0011 - Laboratory L.S. - (91.26 SQM) - Teaching Space: 1	Student Space (42)	
B00B - R0012 - Laboratory L.S. - (91.26 SQM) - Teaching Space: 1	Student Space (42)	
B00B - R0013 - Staff Study - (36.28 SQM)	Office (9)	
B00B - R1005 - Movement - (31.56 SQM)	Not Applicable	Circulation or storage space.
B00B - R1007 - Staff Study - (22.39 SQM)	Office (5)	
B00B - R1008 - Food Technology L.S. - (104.45 SQM) - Teaching Space: 1	Student Space (48)	
B00B - R1011 - Food Technology L.S. - (104.46 SQM) - Teaching Space: 1	Student Space (48)	
B00B - R1012 - Movement - (18.78 SQM)	Not Applicable	Circulation or storage space.
B00B - R1013 - Computer Learning Space - (74.35 SQM) - Teaching Space: 1	Student Space (34)	
B00B - R1014 - Movement - (72.53 SQM)	Not Applicable	Circulation or storage space.
B00B - R1015 - Design L.S. - (75.96 SQM) - Teaching Space: 1	Student Space (35)	
B00B - R1017 - Preparation - (15.83 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Serviced Learning Space - (51.62 SQM) - Teaching Space: 1	Student Space (23)	
B00C - R0002 - General Learning Space - (53.17 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0003 - Staff Study - (26.99 SQM)	Office (6)	
B00C - R0004 - General Learning Space - (48.03 SQM) - Teaching Space: 1	Student Space (22)	
B00C - R0009 - Study Space - (13.36 SQM)	Not Applicable	Circulation or storage space.
B00C - R0010 - Study Space - (15.17 SQM)	Not Applicable	Circulation or storage space.
B00C - R0011 - Seminar - (18.57 SQM)	Office (4)	
B00C - R0012 - Seminar - (19.73 SQM)	Office (4)	
B00C - R0013 - Main Area - (380.11 SQM)	Not Applicable	Circulation or storage space.
B00C - R0015 - Workroom - (34.79 SQM)	Office (8)	
B00C - R0016 - Audio Visual Workroom - (25.36 SQM)	Student Space (11)	
B00C - R0017 - General Learning Space - (48.03 SQM) - Teaching Space: 1	Student Space (22)	
B00C - R0018 - Computer Learning Space - (60.38 SQM) - Teaching Space: 1	Student Space (28)	
B00C - R0021 - Serviced Learning Space - (48.18 SQM) - Teaching Space: 1	Student Space (22)	
B00C - R0025 - Staff Study - (15.13 SQM)	Office (3)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R0026 - Senior Study - (13.36 SQM)	Office (3)	
B00C - R0032 - Movement - (21.17 SQM)	Not Applicable	Circulation or storage space.
B00C - R0033 - Movement - (22.16 SQM)	Not Applicable	Circulation or storage space.
B00C - R0034 - Movement - (42 SQM)	Not Applicable	Circulation or storage space.
B00C - R0036 - Movement - (43.23 SQM)	Not Applicable	Circulation or storage space.
B00C - R0040 - Movement - (49.93 SQM)	Not Applicable	Circulation or storage space.
B00C - R1001 - General Learning Space - (49.47 SQM) - Teaching Space: 1	Student Space (22)	
B00C - R1002 - General Learning Space - (39.79 SQM) - Teaching Space: 1	Student Space (18)	
B00C - R1003 - Staff Study - (39.79 SQM)	Office (9)	
B00C - R1004 - General Learning Space - (48.03 SQM) - Teaching Space: 1	Student Space (22)	
B00C - R1005 - General Learning Space - (48.27 SQM) - Teaching Space: 1	Student Space (22)	
B00C - R1007 - Study Space - (14.92 SQM)	Not Applicable	Circulation or storage space.
B00C - R1010 - Interview/Office - Type 1 - (14.71 SQM)	Office (3)	
B00C - R1011 - Interview/Office - Type 1 - (14.71 SQM)	Office (3)	
B00C - R1012 - Seminar - (12.52 SQM)	Office (3)	
B00C - R1013 - Seminar - (14.46 SQM)	Office (3)	
B00C - R1014 - General Learning Space - (80.21 SQM) - Teaching Space: 1	Student Space (37)	
B00C - R1016 - General Learning Space - (48.26 SQM) - Teaching Space: 1	Student Space (22)	
B00C - R1017 - General Learning Space - (48.02 SQM) - Teaching Space: 1	Student Space (22)	
B00C - R1018 - Staff Study - (39.77 SQM)	Office (9)	
B00C - R1019 - General Learning Space - (39.77 SQM) - Teaching Space: 1	Student Space (18)	
B00C - R1021 - Study Space - (14.72 SQM)	Not Applicable	Circulation or storage space.
B00C - R1024 - Darkroom Space - (27.07 SQM)	Office (6)	
B00C - R1025 - General Learning Space - (49.48 SQM) - Teaching Space: 1	Student Space (22)	
B00C - R1031 - Movement - (19.15 SQM)	Not Applicable	Circulation or storage space.
B00C - R1032 - Movement - (46.29 SQM)	Not Applicable	Circulation or storage space.
B00C - R1033 - Movement - (50.5 SQM)	Not Applicable	Circulation or storage space.
B00C - R1034 - Movement - (20.93 SQM)	Not Applicable	Circulation or storage space.
B00C - R1037 - Movement - (38.5 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Commonroom - (89.45 SQM)	Office (22)	
B00D - R0005 - Movement - (22.57 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Movement - (23.02 SQM)	Not Applicable	Circulation or storage space.
B00E - R0003 - Tiered Learning Area - (71.88 SQM)	Student Space (33)	
B00F - R0002 - Staff Study - (17.11 SQM)	Office (4)	
B00F - R0007 - Workshop - (60.55 SQM)	Student Space (28)	
B00F - R0008 - Workshop - (60.65 SQM)	Student Space (28)	
B00F - R0009 - Workshop - (60.73 SQM)	Student Space (28)	
B00F - R0012 - Art Learning Space - (61.26 SQM) - Teaching Space: 1	Student Space (28)	
B00G - R0005 - Materials Technology L.S. - (93.03 SQM) - Teaching Space: 1	Student Space (43)	
B00G - R0006 - Metal Technology Bay - (34.79 SQM)	Not Applicable	Circulation or storage space.
B00G - R0007 - Movement - (5.97 SQM)	Not Applicable	Circulation or storage space.
B00G - R0008 - Materials Technology L.S. - (93.02 SQM) - Teaching Space: 1	Student Space (43)	
B00G - R0010 - Materials Technology L.S. - (93.02 SQM) - Teaching Space: 1	Student Space (43)	
B00G - R0011 - Wood Technology Bay - (34.46 SQM)	Not Applicable	Circulation or storage space.
B00G - R0013 - Materials Technology L.S. - (93.02 SQM) - Teaching Space: 1	Student Space (43)	
B00G - R0014 - Movement - (6.26 SQM)	Not Applicable	Circulation or storage space.
B00G - R0016 - Staff Study - (22.94 SQM)	Office (5)	
B00G - R0021 - Design L.S. - (55.53 SQM) - Teaching Space: 1	Student Space (25)	
B00G - R0022 - Seminar/Technology Space - (25.64 SQM)	Office (6)	
B00G - R0023 - General Learning Space - (55.54 SQM) - Teaching Space: 1	Student Space (25)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0029 - Metal Technology Bay - (61.19 SQM)	Not Applicable	Circulation or storage space.
B00G - R1001 - Music Learning Space - (58.92 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R1002 - Study Space - (24.86 SQM)	Not Applicable	Circulation or storage space.
B00G - R1003 - Interview/Office - Type 1 - (12.46 SQM)	● Office (3)	
B00G - R1004 - Staff Study - (15.16 SQM)	● Office (3)	
B00G - R1008 - Practice/Seminar - (28.21 SQM)	Not Applicable	Circulation or storage space.
B00G - R1009 - Music Learning Space - (72.88 SQM) - Teaching Space: 1	● Student Space (33)	
B00G - R1010 - Movement - (75.9 SQM)	Not Applicable	Circulation or storage space.
B00G - R1011 - Movement - (33.94 SQM)	Not Applicable	Circulation or storage space.
B00G - R1013 - Movement - (22.96 SQM)	Not Applicable	Circulation or storage space.
B00G - R1015 - Student Canteen - (60.63 SQM)	Not Applicable	Circulation or storage space.
B00J - R0002 - General Assistants - (17.19 SQM)	● Office (4)	
B00J - R0008 - Multi-Purpose Space - (474.2 SQM)	● Student Space (220)	
B00J - R0010 - Movement - (18.45 SQM)	Not Applicable	Circulation or storage space.
B00J - R0021 - Movement - (58.44 SQM)	Not Applicable	Circulation or storage space.
B00J - R0023 - Stage - (96.15 SQM)	Not Applicable	Circulation or storage space.
B00J - R0024 - Movement - (18.45 SQM)	Not Applicable	Circulation or storage space.