

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Hay War Memorial High School (8119)</b>
<b>AMU REGION:</b>	<b>Southern NSW</b>
<b>STATE ELECTORATE:</b>	<b>Murray</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Hay</b>

8119 - Hay War Memorial High School  
Site Plan (13180)





















1:1,632

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0006 - Student Canteen - (39.95 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Staff Study - (14.99 SQM)	Office (3)	
B00A - R0014 - Movement - (76.24 SQM)	Not Applicable	Circulation or storage space.
B00A - R0015 - Movement - (45.51 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Art Learning Space - (76.95 SQM) - Teaching Space: 1	Student Space (35)	
B00A - R1004 - Movement - (54.9 SQM)	Not Applicable	Circulation or storage space.
B00A - R1005 - Materials Technology L.S. - (79.21 SQM) - Teaching Space: 1	Student Space (36)	
B00A - R1012 - Music Learning Space - (65.75 SQM) - Teaching Space: 1	Student Space (30)	
B00C - R0001 - General Learning Space - (55.12 SQM) - Teaching Space: 1	Student Space (25)	
B00C - R0002 - General Learning Space - (48.84 SQM) - Teaching Space: 1	Student Space (22)	
B00C - R0004 - Public Entry - (24.32 SQM)	Not Applicable	Circulation or storage space.
B00C - R0007 - Movement - (23.72 SQM)	Not Applicable	Circulation or storage space.
B00C - R0008 - Principal Office - (14.19 SQM)	Office (3)	
B00C - R0011 - Duplicating Workroom - (14.12 SQM)	Office (3)	
B00C - R0012 - Computer Learning Space - (48.83 SQM) - Teaching Space: 1	Student Space (22)	
B00C - R0013 - General Learning Space - (54.84 SQM) - Teaching Space: 1	Student Space (25)	
B00C - R0014 - Movement - (6 SQM)	Not Applicable	Circulation or storage space.
B00C - R0015 - General Learning Space - (54.85 SQM) - Teaching Space: 1	Student Space (25)	
B00C - R0016 - General Learning Space - (49.04 SQM) - Teaching Space: 1	Student Space (22)	
B00C - R0018 - Movement - (60.72 SQM)	Not Applicable	Circulation or storage space.
B00C - R0019 - Multi-Purpose Space - (121.7 SQM)	Student Space (56)	
B00C - R0023 - General Assistants - (17.09 SQM)	Office (4)	
B00C - R0027 - Staff Study - (22.31 SQM)	Office (5)	
B00C - R0028 - Commonroom - (59.21 SQM)	Office (14)	
B00C - R0029 - Staff Kitchen - (7.69 SQM)	Office (1)	
B00C - R0032 - Movement - (217.39 SQM)	Not Applicable	Circulation or storage space.
B00C - R0036 - Clerical Office - (26.61 SQM)	Office (6)	
B00C - R0037 - Audio Visual Workroom - (14.4 SQM)	Student Space (6)	
B00C - R0038 - Deputy Principal - (14.52 SQM)	Office (3)	
B00C - R1001 - Staff Study - (13.76 SQM)	Office (3)	
B00C - R1003 - Staff Study - (14.36 SQM)	Office (3)	
B00C - R1004 - Darkroom Space - (13.42 SQM)	Office (3)	
B00C - R1005 - Staff Study - (9.51 SQM)	Office (2)	
B00C - R1006 - Movement - (17.8 SQM)	Not Applicable	Circulation or storage space.
B00C - R1007 - Staff Study - (14.08 SQM)	Office (3)	
B00K - R0001 - Food Technology L.S. - (102.91 SQM) - Teaching Space: 1	Student Space (47)	
B00K - R0002 - Movement - (12.48 SQM)	Not Applicable	Circulation or storage space.
B00K - R0003 - Computer Learning Space - (50.12 SQM) - Teaching Space: 1	Student Space (23)	
B00K - R0004 - Staff Study - (20.52 SQM)	Office (5)	
B00K - R0005 - Computer Learning Space - (67.11 SQM) - Teaching Space: 1	Student Space (31)	
B00K - R0011 - Staff Study - (24.64 SQM)	Office (6)	
B00K - R0014 - General Learning Space - (45.81 SQM) - Teaching Space: 1	Student Space (21)	
B00K - R0015 - General Learning Space - (45.74 SQM) - Teaching Space: 1	Student Space (21)	
B00K - R0016 - General Learning Space - (45.95 SQM) - Teaching Space: 1	Student Space (21)	
B00K - R0017 - General Learning Space - (46.08 SQM) - Teaching Space: 1	Student Space (21)	
B00K - R0018 - Senior Study - (25.81 SQM)	Office (6)	
B00K - R0020 - Staff Study - (30.9 SQM)	Office (7)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00K - R0021 - Laboratory L.S. - (78.93 SQM) - Teaching Space: 1	 Student Space (36)	
B00K - R0022 - Growing/Breeding - (15.31 SQM)	Not Applicable	Circulation or storage space.
B00K - R0023 - Staff Study - (15.25 SQM)	 Office (3)	
B00K - R0025 - Food/Research Space - (10.05 SQM)	Not Applicable	Circulation or storage space.
B00K - R0027 - Movement - (116.16 SQM)	Not Applicable	Circulation or storage space.
B00K - R0028 - Movement - (7.35 SQM)	Not Applicable	Circulation or storage space.
B00K - R0030 - Movement - (9.27 SQM)	Not Applicable	Circulation or storage space.
B00K - R0031 - Movement - (7.76 SQM)	Not Applicable	Circulation or storage space.
B00K - R0032 - Movement - (10.99 SQM)	Not Applicable	Circulation or storage space.
B00L - R0003 - Staff Kitchen - (21.12 SQM)	 Office (5)	
B00L - R0004 - Movement - (14.46 SQM)	Not Applicable	Circulation or storage space.
B00L - R0005 - Movement - (38.77 SQM)	Not Applicable	Circulation or storage space.
B00L - R0006 - Movement - (27.53 SQM)	Not Applicable	Circulation or storage space.
B00L - R0007 - Movement - (14.59 SQM)	Not Applicable	Circulation or storage space.
B00L - R0010 - Stage - (76.95 SQM)	Not Applicable	Circulation or storage space.
B00L - R0011 - Multi-Purpose Space - (607.68 SQM)	 Student Space (281)	
B00L - R0018 - Movement - (80.18 SQM)	Not Applicable	Circulation or storage space.
B00L - R0019 - Movement - (49.15 SQM)	Not Applicable	Circulation or storage space.
B00N - R0001 - General Learning Space - Type 9 - (54.39 SQM) - Teaching Space: 1	 Student Space (25)	
B00N - R0002 - Practical Activities - (8.86 SQM)	 Student Space (4)	
B00N - R0003 - Practical Activities - (8.93 SQM)	 Student Space (4)	
B00N - R0004 - General Learning Space - Type 8 - (54.17 SQM) - Teaching Space: 1	 Student Space (25)	
B00N - R0005 - Metal Technology Bay - (11.86 SQM)	Not Applicable	Circulation or storage space.
B00N - R0012 - Materials Workshop - Type 2 - (84.39 SQM)	 Student Space (39)	
B00N - R0013 - Materials Workshop - Type 3 - (121.94 SQM)	 Student Space (56)	
B00O - R0001 - Science Laboratory - (100.45 SQM)	 Student Space (46)	
B00O - R0002 - General Learning Space - Type 3 - (49.11 SQM) - Teaching Space: 1	 Student Space (22)	
B00O - R0004 - General Learning Space - Type 3 - (49.11 SQM) - Teaching Space: 1	 Student Space (22)	
B00O - R0013 - Preparation - (30.23 SQM)	Not Applicable	Circulation or storage space.
B00P - R0001 - Main Area - (137.99 SQM)	Not Applicable	Circulation or storage space.
B00P - R0005 - Seminar/Study - (40.49 SQM)	 Office (10)	
B00P - R0006 - Seminar - (12.95 SQM)	 Office (3)	
B00P - R0007 - Seminar - (12.95 SQM)	 Office (3)	
B00P - R0011 - Entry - (26.45 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0001 - Computer Learning Space - (91.86 SQM) - Teaching Space: 1	 Student Space (42)	
B00Q - R0002 - Seminar - Type 2 - (19.12 SQM)	 Office (4)	