

VENTILATION AUDIT REPORT

SCHOOL:	Heathcote Public School (2149)
AMU REGION:	Sydney
STATE ELECTORATE:	Heathcote
LOCAL GOVERNMENT AREA:	Sutherland

2149 - Heathcote Public School
Site Plan (14570)



1:694

Printed: 20-May-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0005 - Movement - (15.95 SQM)	Not Applicable	Circulation or storage space.
B00A - R0008 - Practical Activities - 1hb - (6.23 SQM)	● Student Space (2)	
B00A - R0009 - Home Base - (55.95 SQM) - Teaching Space: 1	● Student Space (25)	
B00A - R0010 - Home Base - (55.94 SQM) - Teaching Space: 1	● Student Space (25)	
B00B - R0001 - Clerical Office - (13.01 SQM)	○ Office (3)	
B00B - R0002 - Duplicating Workroom - (32.79 SQM)	○ Office (8)	
B00B - R0003 - Deputy Principal - (12.42 SQM)	○ Office (3)	
B00B - R0005 - Staff Room Annexe - (12.98 SQM)	○ Office (3)	
B00B - R0011 - Movement - (15.1 SQM)	Not Applicable	Circulation or storage space.
B00B - R0013 - Principal - (20.33 SQM)	○ Office (5)	
B00B - R0014 - Interview - (12.05 SQM)	○ Office (3)	
B00B - R0015 - Sick Bay - (12.28 SQM)	● Student Space (5)	
B00B - R0016 - Entry Vestibule - (16.41 SQM)	Not Applicable	Circulation or storage space.
B00B - R0017 - Movement - (24.13 SQM)	Not Applicable	Circulation or storage space.
B00B - R0018 - Movement - (127.65 SQM)	Not Applicable	Circulation or storage space.
B00B - R0019 - Staff Kitchen - (9.2 SQM)	○ Office (2)	
B00B - R0020 - Staff Room - (59.03 SQM)	○ Office (14)	
B00C - R0003 - Movement - (11.03 SQM)	Not Applicable	Circulation or storage space.
B00C - R0012 - Movement - (150.36 SQM)	Not Applicable	Circulation or storage space.
B00C - R0013 - Reading Area - (211.6 SQM)	● Student Space (98)	
B00C - R0014 - Seminar/Study - (48.99 SQM)	○ Office (12)	
B00D - R0001 - Movement - (46.23 SQM)	Not Applicable	Circulation or storage space.
B00D - R0005 - Home Base - (54.42 SQM) - Teaching Space: 1	● Student Space (25)	
B00D - R0006 - Practical Activities - 1hb - (16.66 SQM)	● Student Space (7)	
B00D - R0007 - Home Base - (54.57 SQM) - Teaching Space: 1	● Student Space (25)	
B00D - R0008 - Practical Activities - 1hb - (16.68 SQM)	● Student Space (7)	
B00D - R0009 - Home Base - (54.5 SQM) - Teaching Space: 1	● Student Space (25)	
B00D - R0010 - Practical Activities - 1hb - (16.61 SQM)	● Student Space (7)	
B00D - R0011 - Home Base - (54.2 SQM) - Teaching Space: 1	● Student Space (25)	
B00D - R0012 - Practical Activities - 1hb - (16.61 SQM)	● Student Space (7)	
B00D - R0013 - Movement - (37.02 SQM)	Not Applicable	Circulation or storage space.
B00D - R0014 - Withdrawal Space - 1hb - (12.56 SQM)	● Student Space (5)	
B00D - R0021 - Home Base - (54.5 SQM) - Teaching Space: 1	● Student Space (25)	
B00D - R0022 - Practical Activities - 1hb - (16.77 SQM)	● Student Space (7)	
B00D - R0023 - Movement - (35.81 SQM)	Not Applicable	Circulation or storage space.
B00D - R0024 - Movement - (47.71 SQM)	Not Applicable	Circulation or storage space.
B00D - R0025 - Movement - (26.43 SQM)	Not Applicable	Circulation or storage space.
B00D - R0026 - Home Base - (53.75 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0027 - Practical Activities - 1hb - (16.47 SQM)	● Student Space (7)	
B00D - R0028 - Home Base - (53.75 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0029 - Practical Activities - 1hb - (16.47 SQM)	● Student Space (7)	
B00D - R0030 - Home Base - (54.57 SQM) - Teaching Space: 1	● Student Space (25)	
B00D - R0031 - Practical Activities - 1hb - (16.7 SQM)	● Student Space (7)	
B00D - R0032 - Home Base - (54.27 SQM) - Teaching Space: 1	● Student Space (25)	
B00D - R0033 - Practical Activities - 1hb - (16.63 SQM)	● Student Space (7)	
B00D - R0034 - Home Base - (54.5 SQM) - Teaching Space: 1	● Student Space (25)	
B00D - R0035 - Practical Activities - 1hb - (16.61 SQM)	● Student Space (7)	
B00D - R0039 - Movement - (167.56 SQM)	Not Applicable	Circulation or storage space.
B00E - R0015 - Raised Platform - (32.15 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R0017 - Communal Space - (185.76 SQM)	● Student Space (86)	
B00E - R0021 - Canteen - (44.98 SQM)	Not Applicable	Circulation or storage space.
B00E - R0025 - Movement - (23.42 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Movement - (24.42 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Practical Activities - 1hb - (6.16 SQM)	● Student Space (2)	
B00G - R0004 - Home Base - (85.42 SQM) - Teaching Space: 1	● Student Space (39)	
B00G - R0005 - Home Base - (56.82 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0007 - Practical Activities - 1hb - (5.93 SQM)	● Student Space (2)	
B00G - R0008 - Movement - (18.31 SQM)	Not Applicable	Circulation or storage space.
B00G - R0015 - Home Base - (77.45 SQM) - Teaching Space: 1	● Student Space (35)	
B00G - R0016 - Practical Activities - 1hb - (6.56 SQM)	● Student Space (3)	
B00G - R0017 - Home Base - (56.3 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0018 - Practical Activities - 1hb - (5.42 SQM)	● Student Space (2)	
B00G - R0022 - Movement - (77.82 SQM)	Not Applicable	Circulation or storage space.
OH 060 17032 - OH 060 17032 - OSHC Hub 60 - (SQM)	● Student Space ()	