


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Heaton Public School (4129)</b>
<b>AMU REGION:</b>	<b>Hunter/Central Coast</b>
<b>STATE ELECTORATE:</b>	<b>Wallsend</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Newcastle</b>

4129 - Heaton Public School  
Site Plan (11065)



1:2,126

Printed: 10-Jul-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R0016 - Canteen - (15.67 SQM)	Not Applicable	Circulation or storage space.
B00B - R0020 - Movement - (5.94 SQM)	Not Applicable	Circulation or storage space.
B00B - R0022 - Movement - (7.05 SQM)	Not Applicable	Circulation or storage space.
B00B - R0023 - Movement - (7.96 SQM)	Not Applicable	Circulation or storage space.
B00B - R0027 - Reading Area - (84.22 SQM)	● Student Space (39)	
B00B - R0028 - Special Programs Room - (41.09 SQM)	● Student Space (19)	
B00B - R0029 - Home Base - (69.49 SQM) - Teaching Space: 1	● Student Space (32)	
B00B - R0032 - Movement - (127.99 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Communal Space - (142.49 SQM)	● Student Space (66)	
B00G - R0003 - Movement - (5.94 SQM)	Not Applicable	Circulation or storage space.
B00G - R0004 - Raised Platform - (60.47 SQM)	Not Applicable	Circulation or storage space.
B00G - R0005 - Movement - (11.15 SQM)	Not Applicable	Circulation or storage space.
B00G - R0006 - Movement - (13.51 SQM)	Not Applicable	Circulation or storage space.
B0AA - R0004 - Staff Room Annexe - (13.22 SQM)	● Office (3)	
B0AA - R0005 - Staff Room - (32.77 SQM)	● Office (8)	
B0AA - R0010 - Deputy Principal - (12.88 SQM)	● Office (3)	
B0AA - R0012 - Duplicating Workroom - (20.94 SQM)	● Office (5)	
B0AA - R0013 - Clerical Office - (17.69 SQM)	● Office (4)	
B0AA - R0014 - Sick Bay - (8.23 SQM)	● Student Space (3)	
B0AA - R0016 - Principal - (12.56 SQM)	● Office (3)	
B0AA - R0017 - Interview - (12.45 SQM)	● Office (3)	
B0AA - R0018 - Movement - (47.73 SQM)	Not Applicable	Circulation or storage space.
B0AA - R0019 - Movement - (91.04 SQM)	Not Applicable	Circulation or storage space.
B0DD - R0001 - Practical Activities - 1hb - (20.29 SQM)	● Student Space (9)	
B0DD - R0003 - Home Base - (59.49 SQM) - Teaching Space: 1	● Student Space (27)	
B0DD - R0004 - Withdrawal Space - 2hb - (11.47 SQM)	● Student Space (5)	
B0DD - R0005 - Home Base - (58.45 SQM) - Teaching Space: 1	● Student Space (27)	
B0DD - R0006 - Practical Activities - 1hb - (20.11 SQM)	● Student Space (9)	
B0DD - R0009 - Practical Activities - 1hb - (20.18 SQM)	● Student Space (9)	
B0DD - R0010 - Home Base - (59.27 SQM) - Teaching Space: 1	● Student Space (27)	
B0DD - R0011 - Withdrawal Space - 2hb - (11.47 SQM)	● Student Space (5)	
B0DD - R0012 - Home Base - (59.69 SQM) - Teaching Space: 1	● Student Space (27)	
B0DD - R0013 - Practical Activities - 1hb - (20.38 SQM)	● Student Space (9)	
B0DD - R0016 - Movement - (169.5 SQM)	Not Applicable	Circulation or storage space.
B0EE - R0001 - Practical Activities - 1hb - (20.29 SQM)	● Student Space (9)	
B0EE - R0003 - Home Base - (59.38 SQM) - Teaching Space: 1	● Student Space (27)	
B0EE - R0004 - Withdrawal Space - 2hb - (11.44 SQM)	● Student Space (5)	
B0EE - R0005 - Home Base - (58.21 SQM) - Teaching Space: 1	● Student Space (27)	
B0EE - R0006 - Practical Activities - 1hb - (20.19 SQM)	● Student Space (9)	
B0EE - R0010 - Home Base - (59.31 SQM) - Teaching Space: 1	● Student Space (27)	
B0EE - R0011 - Withdrawal Space - 1hb - (5.6 SQM)	● Student Space (2)	
B0EE - R0013 - Movement - (96.17 SQM)	Not Applicable	Circulation or storage space.
B0EE - R0014 - Movement - (49.06 SQM)	Not Applicable	Circulation or storage space.
OS 602 13289 - OS 602 13289 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	