

VENTILATION AUDIT REPORT

SCHOOL:	Heckenberg Public School (4336)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Liverpool
LOCAL GOVERNMENT AREA:	Liverpool

4336 - Heckenberg Public School
Site Plan (10427)



1:1,049

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B001 - R0005 - Duplicating Workroom - (20.04 SQM)	Office (5)	
B001 - R0008 - Movement - (7.76 SQM)	Not Applicable	Circulation or storage space.
B001 - R0009 - Clerical Office/Workroom - (19.97 SQM)	Office (4)	
B001 - R0013 - Staff Room Annexe - (15.44 SQM)	Office (3)	
B001 - R0015 - Deputy Principal - (15.22 SQM)	Office (3)	
B001 - R0025 - Movement - (52.46 SQM)	Not Applicable	Circulation or storage space.
B001 - R0026 - Movement - (12.82 SQM)	Not Applicable	Circulation or storage space.
B001 - R0027 - Clerical Office - (25.92 SQM)	Office (6)	
B001 - R0028 - Sick Bay - (5.61 SQM)	Student Space (2)	
B002 - R0001 - Home Base - (56.76 SQM) - Teaching Space: 1	Student Space (26)	
B002 - R0009 - Home Base - (56.44 SQM) - Teaching Space: 1	Student Space (26)	
B002 - R0010 - Home Base - (56.76 SQM) - Teaching Space: 1	Student Space (26)	
B002 - R0018 - Staff Room - (56.92 SQM)	Office (14)	
B002 - R0019 - Practical Activities/Movement - 2hb - (13.12 SQM)	Student Space (6)	
B002 - R0020 - Practical Activities/Movement - 2hb - (13.14 SQM)	Student Space (6)	
B003 - R0020 - Movement - (35.64 SQM)	Not Applicable	Circulation or storage space.
B003 - R0023 - Reading Area - (168.97 SQM)	Student Space (78)	
B004 - R0002 - Home Base - (57.07 SQM) - Teaching Space: 1	Student Space (26)	
B004 - R0010 - Home Base - (56.76 SQM) - Teaching Space: 1	Student Space (26)	
B004 - R0011 - Home Base - (56.76 SQM) - Teaching Space: 1	Student Space (26)	
B004 - R0016 - Home Base - (57.7 SQM) - Teaching Space: 1	Student Space (26)	
B004 - R0020 - Practical Activities/Movement - 2hb - (13.79 SQM)	Student Space (6)	
B004 - R0021 - Practical Activities/Movement - 2hb - (14.03 SQM)	Student Space (6)	
B004 - R0022 - Movement - (11.24 SQM)	Not Applicable	Circulation or storage space.
B005 - R0001 - Home Base - (86.21 SQM) - Teaching Space: 1	Student Space (39)	
B005 - R0007 - Practical Activities/Movement - 2hb - (16.8 SQM)	Student Space (7)	
B005 - R0010 - Home Base - (71.74 SQM) - Teaching Space: 1	Student Space (33)	
B006 - R0001 - Movement - (15.56 SQM)	Not Applicable	Circulation or storage space.
B006 - R0002 - Canteen - (32.08 SQM)	Not Applicable	Circulation or storage space.
B009 - R0002 - Movement - (45.52 SQM)	Not Applicable	Circulation or storage space.
B009 - R0003 - Staff Room Annexe - (17.59 SQM)	Office (4)	
B009 - R0007 - Staff Room Annexe - (7.85 SQM)	Office (1)	
B009 - R0010 - Withdrawal Space - 1hb - (9.48 SQM)	Student Space (4)	
B009 - R0011 - Withdrawal Space - 1hb - (20.3 SQM)	Student Space (9)	
B010 - R0004 - Movement - (5.37 SQM)	Not Applicable	Circulation or storage space.
B010 - R0009 - Home Base - (56.59 SQM) - Teaching Space: 1	Student Space (26)	
B010 - R0010 - Home Base - (56.59 SQM) - Teaching Space: 1	Student Space (26)	
B010 - R0013 - Movement - (5.53 SQM)	Not Applicable	Circulation or storage space.
B010 - R0019 - Home Base - (56.98 SQM) - Teaching Space: 1	Student Space (26)	
B011 - R0007 - Home Base - (84.74 SQM) - Teaching Space: 1	Student Space (39)	
B011 - R0008 - Home Base - (56.07 SQM) - Teaching Space: 1	Student Space (26)	
B011 - R0017 - Home Base - (56.24 SQM) - Teaching Space: 1	Student Space (26)	
B011 - R0018 - Home Base - (84.63 SQM) - Teaching Space: 1	Student Space (39)	
B011 - R0026 - Practical Activities/Movement - 2hb - (15.29 SQM)	Student Space (7)	
B011 - R0027 - Practical Activities - 1hb - (6.39 SQM)	Student Space (2)	
B012 - R0002 - Staff Room - (57.2 SQM)	Office (14)	
B012 - R0003 - Staff Kitchen - (11.55 SQM)	Office (2)	
B012 - R0005 - Movement - (5.74 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B012 - R0009 - Movement - (30.26 SQM)	Not Applicable	Circulation or storage space.
B012 - R0011 - Special Programs Room - (19.91 SQM)	● Student Space (9)	
B013 - R0005 - Communal Space - (133.27 SQM)	● Student Space (61)	
B013 - R0006 - Raised Platform - (10.03 SQM)	Not Applicable	Circulation or storage space.
B013 - R0008 - Movement - (5.15 SQM)	Not Applicable	Circulation or storage space.
B015 - R0009 - Movement - (74.98 SQM)	Not Applicable	Circulation or storage space.