

VENTILATION AUDIT REPORT

SCHOOL:	Highlands School (5576)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Wollondilly
LOCAL GOVERNMENT AREA:	Wingecarribee

5576 - Highlands School
Site Plan (07830)



1:1,327

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0004 - General Learning Space - (53.65 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0005 - General Learning Space - (53.51 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0006 - Principal - (12.69 SQM)	● Office (3)	
B00A - R0007 - Interview - (9.32 SQM)	● Office (2)	
B00A - R0008 - Clerical Office - (14.02 SQM)	● Office (3)	
B00A - R0009 - Interview - (8.48 SQM)	● Office (2)	
B00A - R0010 - Commonroom - (30.36 SQM)	● Office (7)	
B00A - R0011 - Home Base - (53.65 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0012 - Duplicating Workroom - (9.36 SQM)	● Office (2)	
B00A - R0015 - Movement - (41.13 SQM)	Not Applicable	Circulation or storage space.
B00A - R0016 - Movement - (8.82 SQM)	Not Applicable	Circulation or storage space.
B00A - R0017 - Movement - (18.01 SQM)	Not Applicable	Circulation or storage space.
B00A - R0018 - Movement - (21.2 SQM)	Not Applicable	Circulation or storage space.
B00C - R0003 - Movement - (43.46 SQM)	Not Applicable	Circulation or storage space.
B00C - R0012 - Movement - (43.39 SQM)	Not Applicable	Circulation or storage space.
B00C - R0017 - Movement - (6.07 SQM)	Not Applicable	Circulation or storage space.
B00C - R0018 - Movement - (6.11 SQM)	Not Applicable	Circulation or storage space.
B00C - R0019 - Movement - (416.5 SQM)	Not Applicable	Circulation or storage space.
B00C - R9003 - Multi-Purpose Space - (579.52 SQM)	● Student Space (268)	
B00C - R9007 - Movement - (8.6 SQM)	Not Applicable	Circulation or storage space.
B00C - R9008 - Stage - (40.53 SQM)	Not Applicable	Circulation or storage space.
B00C - R9009 - Movement - (8.6 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Practical Activities - (78.84 SQM)	● Student Space (36)	
B00D - R0005 - Practical Activities - (36.97 SQM)	● Student Space (17)	
B00D - R0006 - Practical Activities - (58.82 SQM)	● Student Space (27)	
B00D - R0007 - Practical Activities - (7.45 SQM)	● Student Space (3)	
B00D - R0010 - Practical Activities - (82.84 SQM)	● Student Space (38)	
B00D - R0011 - Movement - (48.15 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Practical Activities - (46.53 SQM)	● Student Space (21)	
B00F - R0002 - Home Base - Bd/Cd/Ed - (76.87 SQM) - Teaching Space: 1	● Student Space (35)	
B00F - R0004 - Staff Kitchen - (14.28 SQM)	● Office (3)	
B00F - R0005 - Movement - (22.08 SQM)	Not Applicable	Circulation or storage space.
B00F - R0006 - Home Base - Bd/Cd/Ed - (53.44 SQM) - Teaching Space: 1	● Student Space (24)	
B00F - R0011 - Staff Room - (53.59 SQM)	● Office (13)	
B00F - R0018 - Movement - (28.48 SQM)	Not Applicable	Circulation or storage space.
B00F - R0019 - Movement - (11.24 SQM)	Not Applicable	Circulation or storage space.
B00F - R0020 - Home Base - (53.52 SQM) - Teaching Space: 1	● Student Space (24)	
B00F - R0021 - Movement - (6.33 SQM)	Not Applicable	Circulation or storage space.
B00F - R0024 - Clerical Office - (12.69 SQM)	● Office (3)	
B00I - R0002 - Reading Area - (61.22 SQM)	● Student Space (28)	
B00J - R0003 - Home Base - (39 SQM) - Teaching Space: 1	● Student Space (18)	
B00J - R0005 - Movement - (6.66 SQM)	Not Applicable	Circulation or storage space.
B00J - R0006 - Canteen - (10.84 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Practical Activities - (6.69 SQM)	● Student Space (3)	
B00M - R0001 - Practical Activities - (9.24 SQM)	● Student Space (4)	
B00N - R0002 - Practical Activities - (36.72 SQM)	● Student Space (17)	