

VENTILATION AUDIT REPORT

SCHOOL:	Hobartville Public School (4452)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Hawkesbury
LOCAL GOVERNMENT AREA:	Hawkesbury

4452 - Hobartville Public School
Site Plan (10431)



















1:1,027

Printed: 07-Apr-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (187.4 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Movement - (76.19 SQM)	Not Applicable	Circulation or storage space.
B00A - R0008 - Canteen - (36.23 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Movement - (76.03 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Principal - (16.08 SQM)	Office (4)	
B00B - R0006 - Movement - (20.5 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Staff Room - (71.05 SQM)	Office (17)	
B00B - R0014 - Staff Room Annexe - (14.78 SQM)	Office (3)	
B00B - R0017 - Clerical Office - (25.2 SQM)	Office (6)	
B00B - R0018 - Movement - (5.93 SQM)	Not Applicable	Circulation or storage space.
B00B - R0020 - Sick Bay - (14.2 SQM)	Student Space (6)	
B00B - R0022 - Entry Vestibule - (29.41 SQM)	Not Applicable	Circulation or storage space.
B00B - R0023 - Deputy Principal - (11.25 SQM)	Office (2)	
B00B - R0024 - Movement - (11.28 SQM)	Not Applicable	Circulation or storage space.
B00B - R0025 - Duplicating Workroom - (11.86 SQM)	Office (2)	
B00B - R0026 - Movement - (143.12 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Movement - (253.31 SQM)	Not Applicable	Circulation or storage space.
B00C - R0007 - Home Base - (88.76 SQM) - Teaching Space: 1	Student Space (41)	
B00C - R0012 - Home Base - (88.76 SQM) - Teaching Space: 1	Student Space (41)	
B00C - R0015 - Home Base - (88.13 SQM) - Teaching Space: 1	Student Space (40)	
B00D - R0001 - Movement - (29.64 SQM)	Not Applicable	Circulation or storage space.
B00D - R0005 - Movement - (46.99 SQM)	Not Applicable	Circulation or storage space.
B00D - R0013 - Withdrawal Space - 1hb - (15.2 SQM)	Student Space (7)	
B00D - R0016 - Movement - (10.5 SQM)	Not Applicable	Circulation or storage space.
B00D - R0018 - Home Base - M - (65.65 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R0019 - Home Base - M - (65.64 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R0020 - Movement - (44.85 SQM)	Not Applicable	Circulation or storage space.
B00D - R0027 - Special Programs Room - (31.43 SQM)	Student Space (14)	
B00D - R0029 - Movement - (24.41 SQM)	Not Applicable	Circulation or storage space.
B00D - R1001 - Movement - (44.23 SQM)	Not Applicable	Circulation or storage space.
B00D - R1003 - Home Base - (65.86 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R1005 - Movement - (27.17 SQM)	Not Applicable	Circulation or storage space.
B00D - R1014 - Withdrawal Space - 2hb - (12.33 SQM)	Student Space (5)	
B00D - R1017 - Home Base - (83.33 SQM) - Teaching Space: 1	Student Space (38)	
B00D - R1018 - Home Base - (84.13 SQM) - Teaching Space: 1	Student Space (39)	
B00E - R0001 - Movement - (73.75 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Home Base - (65.78 SQM) - Teaching Space: 1	Student Space (30)	
B00E - R0005 - Staff Room Annexe - (16.34 SQM)	Office (4)	
B00E - R0006 - Home Base - (65 SQM) - Teaching Space: 1	Student Space (30)	
B00E - R0007 - Home Base - (64.91 SQM) - Teaching Space: 1	Student Space (30)	
B00E - R0008 - Movement - (34.84 SQM)	Not Applicable	Circulation or storage space.
B00E - R0009 - Home Base - (65.87 SQM) - Teaching Space: 1	Student Space (30)	
B00E - R1001 - Home Base - (65.78 SQM) - Teaching Space: 1	Student Space (30)	
B00E - R1003 - Withdrawal Space - 1hb - (16.98 SQM)	Student Space (7)	
B00E - R1004 - Home Base - (65.82 SQM) - Teaching Space: 1	Student Space (30)	
B00E - R1005 - Home Base - (65.81 SQM) - Teaching Space: 1	Student Space (30)	
B00E - R1006 - Movement - (34.77 SQM)	Not Applicable	Circulation or storage space.
B00E - R1007 - Home Base - (65.78 SQM) - Teaching Space: 1	Student Space (30)	
B00G - R0001 - Movement - (38.48 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0002 - Practical Activities - 1hb - (19.4 SQM)	 Student Space (9)	
B00G - R0004 - Home Base - (59.2 SQM) - Teaching Space: 1	 Student Space (27)	
B00G - R0005 - Withdrawal Space - 2hb - (11.35 SQM)	 Student Space (5)	
B00G - R0006 - Home Base - (59.18 SQM) - Teaching Space: 1	 Student Space (27)	
B00G - R0008 - Practical Activities - 1hb - (19.4 SQM)	 Student Space (9)	
B00H - R0001 - Communal Space - (213.64 SQM)	 Student Space (99)	
B00H - R0007 - Movement - (6.79 SQM)	Not Applicable	Circulation or storage space.
B00H - R0011 - Raised Platform - (61.01 SQM)	Not Applicable	Circulation or storage space.
B00H - R0015 - Seminar/Study - (15.98 SQM)	 Office (3)	
B00H - R0020 - Movement - (15.45 SQM)	Not Applicable	Circulation or storage space.
B00I - R0001 - Home Base - (59.57 SQM) - Teaching Space: 1	 Student Space (27)	
B00I - R0002 - Practical Activities - 1hb - (19.62 SQM)	 Student Space (9)	
B00I - R0004 - Withdrawal Space - 1hb - (9.11 SQM)	 Student Space (4)	
B00I - R0005 - Home Base - (61.11 SQM) - Teaching Space: 1	 Student Space (28)	
B00I - R0007 - Practical Activities - 1hb - (18.89 SQM)	 Student Space (8)	
B00I - R0008 - Withdrawal Space - 2hb - (11.48 SQM)	 Student Space (5)	
B00I - R0009 - Home Base - (60.98 SQM) - Teaching Space: 1	 Student Space (28)	
B00I - R0011 - Practical Activities - 1hb - (19.02 SQM)	 Student Space (8)	
B00J - R0001 - Reading Area - (166.67 SQM)	 Student Space (77)	