

VENTILATION AUDIT REPORT

SCHOOL:	Holgate Public School (2171)
AMU REGION:	Hunter/Central Coast
STATE ELECTORATE:	Terrigal
LOCAL GOVERNMENT AREA:	Central Coast

2171 - Holgate Public School
Site Plan (11008)



1:796

Printed: 05-Dec-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R0001 - Movement - (9.44 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Canteen - (24.35 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Movement - (14.39 SQM)	Not Applicable	Circulation or storage space.
B00C - R0003 - Special Programs Room - (35.38 SQM)	● Student Space (16)	
B00C - R0006 - Staff Kitchen - (7.97 SQM)	● Office (1)	
B00E - R0003 - Home Base - (52.51 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0005 - Practical Activities - (18.06 SQM)	● Student Space (8)	
B00F - R0007 - Movement - (38.14 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Movement - (30.96 SQM)	Not Applicable	Circulation or storage space.
B00G - R0003 - Practical Activities - 1hb - (15.4 SQM)	● Student Space (7)	
B00G - R0004 - Practical Activities - 1hb - (15.4 SQM)	● Student Space (7)	
B00G - R0006 - Home Base - (61.37 SQM) - Teaching Space: 1	● Student Space (28)	
B00G - R0007 - Home Base - (61.37 SQM) - Teaching Space: 1	● Student Space (28)	
B00G - R0009 - Movement - (14 SQM)	Not Applicable	Circulation or storage space.
B00G - R0011 - Movement - (14 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Movement - (30.98 SQM)	Not Applicable	Circulation or storage space.
B00H - R0003 - Practical Activities - 1hb - (15.4 SQM)	● Student Space (7)	
B00H - R0004 - Practical Activities - 1hb - (15.41 SQM)	● Student Space (7)	
B00H - R0006 - Home Base - (61.37 SQM) - Teaching Space: 1	● Student Space (28)	
B00H - R0007 - Home Base - (61.37 SQM) - Teaching Space: 1	● Student Space (28)	
B00H - R0009 - Movement - (14 SQM)	Not Applicable	Circulation or storage space.
B00H - R0011 - Movement - (14 SQM)	Not Applicable	Circulation or storage space.
B00I - R0001 - Entry Vestibule - (15.43 SQM)	Not Applicable	Circulation or storage space.
B00I - R0002 - Clerical/Printing - (22.6 SQM)	Not Applicable	Circulation or storage space.
B00I - R0003 - Interview - (13.07 SQM)	● Office (3)	
B00I - R0004 - Principal - (13.13 SQM)	● Office (3)	
B00I - R0005 - Sick Bay - (9.07 SQM)	● Student Space (4)	
B00I - R0012 - Staff Room - (31.15 SQM)	● Office (7)	
B00I - R0013 - Staff Room Annexe - (16.26 SQM)	● Office (4)	
B00I - R0014 - Movement - (41.74 SQM)	Not Applicable	Circulation or storage space.
B00J - R0001 - Reading Area - (90.02 SQM)	● Student Space (41)	
B00K - R0001 - Communal Space - (207.81 SQM)	● Student Space (96)	
OS 601 12321 - OS 601 12321 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 602 12174 - OS 602 12174 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	