

VENTILATION AUDIT REPORT

| | |
|-------------------------------|------------------------------|
| SCHOOL: | Holroyd School (5633) |
| AMU REGION: | South Western Sydney |
| STATE ELECTORATE: | Granville |
| LOCAL GOVERNMENT AREA: | Cumberland |



5633 - Holroyd School
Site Plan (12653)



1:1,294

Printed: 26-Sep-2020

Ventilation Audit Key

| Category | Description |
|---|--|
|  | Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings. |
|  | Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces. |

| Entity Location | Audit Condition Classification (Capacity) | Comment |
|--|---|-------------------------------|
| B00A - R0003 - Duplicating Workroom - (12.22 SQM) | Office (3) | |
| B00A - R0019 - Principal - (19.72 SQM) | Office (4) | |
| B00A - R0022 - Special Programs Room - (13.4 SQM) | Student Space (6) | |
| B00A - R0023 - Home Base - M - (69.7 SQM) - Teaching Space: 1 | Student Space (32) | |
| B00A - R0027 - Movement - (5.69 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0028 - Staff Room Annexe - (10.12 SQM) | Office (2) | |
| B00B - R0006 - Home Base - M - (44.32 SQM) - Teaching Space: 1 | Student Space (20) | |
| B00B - R0007 - Home Base - M - (42.36 SQM) - Teaching Space: 1 | Student Space (19) | |
| B00C - R0002 - Canteen - (18.92 SQM) | Not Applicable | Circulation or storage space. |
| B00C - R0005 - Staff Kitchen - (8.82 SQM) | Office (2) | |
| B00C - R0006 - Practical Activities - S - 1hb - (28.13 SQM) | Student Space (13) | |
| B00C - R0007 - Home Base - S - (56.93 SQM) - Teaching Space: 1 | Student Space (26) | |
| B00C - R0016 - Home Base - S - (42.29 SQM) - Teaching Space: 1 | Student Space (19) | |
| B00C - R0020 - Staff Kitchen - (8.59 SQM) | Office (2) | |
| B00C - R0021 - Practical Activities - S - 1hb - (23.06 SQM) | Student Space (10) | |
| B00C - R0022 - Home Base - S - (42.61 SQM) - Teaching Space: 1 | Student Space (19) | |
| B00C - R0034 - Movement - (26.79 SQM) | Not Applicable | Circulation or storage space. |
| B00C - R0035 - Outdoor Learning Area - (38.4 SQM) | Not Applicable | Circulation or storage space. |
| B00C - R0041 - Practical Activities - M - 1hb - (6.69 SQM) | Student Space (3) | |
| B00C - R0042 - Practical Activities - M - 1hb - (6.69 SQM) | Student Space (3) | |
| B00C - R0044 - Special Programs Room - (7.6 SQM) | Student Space (3) | |
| B00C - R0046 - Home Base - (58.84 SQM) - Teaching Space: 1 | Student Space (27) | |
| B00F - R0003 - Staff Room Annexe - (7.02 SQM) | Office (1) | |
| B00F - R0005 - Home Base - M - (44.19 SQM) - Teaching Space: 1 | Student Space (20) | |
| B00F - R0008 - Practical Activities - M - 1hb - (52.71 SQM) | Student Space (24) | |
| B00F - R0013 - Outdoor Learning Area - (74.97 SQM) | Not Applicable | Circulation or storage space. |
| B00F - R0014 - Movement - (16.85 SQM) | Not Applicable | Circulation or storage space. |
| B00G - R0005 - Hydrotherapy - Pool - (175.28 SQM) | Not Applicable | Circulation or storage space. |
| B00G - R0011 - Hydrotherapy - Pool - (295.98 SQM) | Not Applicable | Circulation or storage space. |
| B00J - R0002 - Staff Room - (11.64 SQM) | Office (2) | |
| B00J - R0006 - Staff Room Annexe - (13.64 SQM) | Office (3) | |
| B00J - R0007 - Movement - (14.16 SQM) | Not Applicable | Circulation or storage space. |
| B00J - R0010 - Staff Kitchen - (21.42 SQM) | Office (5) | |
| B00M - R0001 - Reading Area - (179.96 SQM) | Student Space (83) | |
| B00N - R0002 - Raised Platform - (55.06 SQM) | Not Applicable | Circulation or storage space. |
| B00N - R0003 - Movement - (27.86 SQM) | Not Applicable | Circulation or storage space. |
| B00N - R0008 - Movement - (6.7 SQM) | Not Applicable | Circulation or storage space. |
| B00N - R0013 - Communal Space - (201 SQM) | Student Space (93) | |
| B00N - R0018 - Movement - (6.54 SQM) | Not Applicable | Circulation or storage space. |
| B00N - R0020 - Movement - (8.22 SQM) | Not Applicable | Circulation or storage space. |
| B00O - R0004 - Withdrawal - M - (9.47 SQM) | Student Space (4) | |
| B00O - R0005 - Withdrawal - M - (9.43 SQM) | Student Space (4) | |
| B00O - R0007 - Home Base - M - (59.57 SQM) - Teaching Space: 1 | Student Space (27) | |
| B00O - R0008 - Home Base - M - (59.64 SQM) - Teaching Space: 1 | Student Space (27) | |
| B00O - R0009 - Practical Activities - M - 1hb - (15.71 SQM) | Student Space (7) | |
| B00O - R0010 - Practical Activities - M - 1hb - (15.68 SQM) | Student Space (7) | |
| B00O - R0011 - Movement - (21.93 SQM) | Not Applicable | Circulation or storage space. |
| B00O - R0015 - Movement - (22.02 SQM) | Not Applicable | Circulation or storage space. |
| B00O - R0016 - Practical Activities - M - 1hb - (15.82 SQM) | Student Space (7) | |

| Entity Location | Audit Condition Classification (Capacity) | Comment |
|--|---|-------------------------------|
| B00O - R0017 - Practical Activities - M - 1hb - (15.68 SQM) | Student Space (7) | |
| B00O - R0018 - Home Base - M - (59.62 SQM) - Teaching Space: 1 | Student Space (27) | |
| B00O - R0019 - Home Base - M - (59.71 SQM) - Teaching Space: 1 | Student Space (27) | |
| B00O - R0021 - Withdrawal - M - (9.43 SQM) | Student Space (4) | |
| B00O - R0022 - Withdrawal - M - (9.41 SQM) | Student Space (4) | |
| B00O - R0025 - Home Base - P - (34 SQM) - Teaching Space: 1 | Student Space (15) | |
| B00O - R0026 - Home Base - P - (34.33 SQM) - Teaching Space: 1 | Student Space (15) | |
| B00Q - R0002 - Staff Room - (9.9 SQM) | Office (2) | |
| B00Q - R0003 - Staff Room - (10.04 SQM) | Office (2) | |
| B00Q - R0008 - Special Programs Room - (29.58 SQM) | Student Space (13) | |
| B00R - R0003 - Special Programs Room - (64.54 SQM) | Student Space (29) | |
| B00R - R0005 - Special Programs Room - (16.08 SQM) | Student Space (7) | |
| B00S - R0001 - Staff Room - (83.62 SQM) | Office (20) | |
| B00S - R0002 - Staff Room Annexe - (36.29 SQM) | Office (9) | |
| B00S - R0003 - Deputy Principal - (12.98 SQM) | Office (3) | |
| B00S - R0004 - Sick Bay - (9.12 SQM) | Student Space (4) | |
| B00S - R0005 - Clerical Office/Workroom - (52.65 SQM) | Office (13) | |
| B00S - R0006 - Movement - (52.02 SQM) | Not Applicable | Circulation or storage space. |
| B00S - R0011 - Entry Vestibule - (21.81 SQM) | Not Applicable | Circulation or storage space. |
| B00S - R0012 - Principal - (30.49 SQM) | Office (7) | |
| B00S - R0013 - Deputy Principal - (12.95 SQM) | Office (3) | |
| B00T - R0001 - Practical Activities - M - 1hb - (37.8 SQM) | Student Space (17) | |
| B00T - R0002 - Home Base - M - (34.21 SQM) - Teaching Space: 1 | Student Space (15) | |
| B00T - R0004 - Withdrawal - M - (8.81 SQM) | Student Space (4) | |
| B00T - R0005 - Practical Activities - M - 1hb - (37.8 SQM) | Student Space (17) | |
| B00T - R0006 - Home Base - M - (34.21 SQM) - Teaching Space: 1 | Student Space (15) | |
| B00T - R0008 - Withdrawal - M - (8.85 SQM) | Student Space (4) | |
| B00T - R0009 - Practical Activities - S - 1hb - (37.8 SQM) | Student Space (17) | |
| B00T - R0010 - Home Base - M - (34.21 SQM) - Teaching Space: 1 | Student Space (15) | |
| B00T - R0012 - Withdrawal - S - (8.84 SQM) | Student Space (4) | |
| B00T - R0013 - Practical Activities - S - 1hb - (37.8 SQM) | Student Space (17) | |
| B00T - R0014 - Home Base - S - (34.21 SQM) - Teaching Space: 1 | Student Space (15) | |
| B00T - R0016 - Withdrawal - S - (8.85 SQM) | Student Space (4) | |
| B00T - R0017 - Movement - (10.97 SQM) | Not Applicable | Circulation or storage space. |
| B00T - R0020 - Movement - (11.07 SQM) | Not Applicable | Circulation or storage space. |
| B00U - R0006 - Withdrawal Space - 1hb - (7.57 SQM) | Student Space (3) | |
| B00U - R0007 - Breakout Area - (11.73 SQM) | Not Applicable | Circulation or storage space. |
| B00U - R0010 - Home Base - (59.06 SQM) - Teaching Space: 1 | Student Space (27) | |
| B00U - R0011 - Practical Activities - 1hb - (18.98 SQM) | Student Space (8) | |
| B00U - R0012 - Practical Activities - 1hb - (18.98 SQM) | Student Space (8) | |
| B00U - R0013 - Home Base - (59.15 SQM) - Teaching Space: 1 | Student Space (27) | |
| B00U - R0014 - Breakout Area - (9.55 SQM) | Not Applicable | Circulation or storage space. |
| B00U - R0015 - Withdrawal Space - 1hb - (9.54 SQM) | Student Space (4) | |
| B00U - R0016 - Withdrawal Space - 1hb - (9.42 SQM) | Student Space (4) | |
| B00U - R0019 - Practical Activities - 1hb - (18.94 SQM) | Student Space (8) | |
| B00U - R0021 - Home Base - (59.15 SQM) - Teaching Space: 1 | Student Space (27) | |
| B00U - R0022 - Breakout Area - (9.57 SQM) | Not Applicable | Circulation or storage space. |

| Entity Location | Audit Condition Classification (Capacity) | Comment |
|--|---|-------------------------------|
| B00U - R0026 - Practical Activities - 1hb - (18.96 SQM) | ● Student Space (8) | |
| B00U - R0027 - Home Base - (59.15 SQM) - Teaching Space: 1 | ● Student Space (27) | |
| B00U - R0028 - Breakout Area - (9.53 SQM) | Not Applicable | Circulation or storage space. |
| B00U - R0029 - Withdrawal Space - 1hb - (9.51 SQM) | ● Student Space (4) | |
| B00U - R0030 - Withdrawal Space - 1hb - (9.45 SQM) | ● Student Space (4) | |
| B00U - R0033 - Practical Activities - 1hb - (18.94 SQM) | ● Student Space (8) | |
| B00U - R0034 - Home Base - (59.15 SQM) - Teaching Space: 1 | ● Student Space (27) | |
| B00U - R0035 - Breakout Area - (9.56 SQM) | Not Applicable | Circulation or storage space. |
| B00U - R0038 - Practical Activities - 1hb - (18.99 SQM) | ● Student Space (8) | |
| B00U - R0039 - Home Base - (59.01 SQM) - Teaching Space: 1 | ● Student Space (27) | |
| B00U - R0041 - Breakout Area - (13.89 SQM) | Not Applicable | Circulation or storage space. |
| B00U - R0042 - Withdrawal Space - 1hb - (10.03 SQM) | ● Student Space (4) | |
| B00V - R0002 - Practical Activities - 1hb - (29.69 SQM) | ● Student Space (13) | |
| B00V - R0003 - Home Base - (48.22 SQM) - Teaching Space: 1 | ● Student Space (22) | |
| B00V - R0007 - Withdrawal Space - 1hb - (9.53 SQM) | ● Student Space (4) | |
| B00V - R0008 - Breakout Area - (13.37 SQM) | Not Applicable | Circulation or storage space. |
| B00V - R0011 - Breakout Area - (9.55 SQM) | Not Applicable | Circulation or storage space. |
| B00V - R0012 - Withdrawal Space - 1hb - (9.5 SQM) | ● Student Space (4) | |
| B00V - R0014 - Home Base - (48.84 SQM) - Teaching Space: 1 | ● Student Space (22) | |
| B00V - R0015 - Practical Activities - 1hb - (29.54 SQM) | ● Student Space (13) | |
| B00V - R0017 - Practical Activities - 1hb - (29.42 SQM) | ● Student Space (13) | |
| B00V - R0018 - Home Base - (48.77 SQM) - Teaching Space: 1 | ● Student Space (22) | |
| B00V - R0020 - Withdrawal Space - 1hb - (9.45 SQM) | ● Student Space (4) | |
| B00V - R0021 - Breakout Area - (9.55 SQM) | Not Applicable | Circulation or storage space. |
| B00V - R0024 - Breakout Area - (13.32 SQM) | Not Applicable | Circulation or storage space. |
| B00V - R0025 - Withdrawal Space - 1hb - (9.54 SQM) | ● Student Space (4) | |
| B00V - R0029 - Home Base - (48.63 SQM) - Teaching Space: 1 | ● Student Space (22) | |
| B00V - R0030 - Practical Activities - 1hb - (29.33 SQM) | ● Student Space (13) | |
| B00W - R0002 - Practical Activities - 1hb - (28.73 SQM) | ● Student Space (13) | |
| B00W - R0007 - Withdrawal Space - 1hb - (9.54 SQM) | ● Student Space (4) | |
| B00W - R0008 - Home Base - (49.31 SQM) - Teaching Space: 1 | ● Student Space (22) | |
| B00W - R0009 - Breakout Area - (10.55 SQM) | Not Applicable | Circulation or storage space. |
| B00W - R0012 - Breakout Area - (13.37 SQM) | Not Applicable | Circulation or storage space. |
| B00W - R0014 - Withdrawal Space - 1hb - (9.9 SQM) | ● Student Space (4) | |
| B00W - R0017 - Home Base - (45.17 SQM) - Teaching Space: 1 | ● Student Space (20) | |
| B00W - R0018 - Practical Activities - 1hb - (32.71 SQM) | ● Student Space (15) | |
| B00X - R0002 - Practical Activities - 1hb - (33.14 SQM) | ● Student Space (15) | |
| B00X - R0003 - Home Base - (44.97 SQM) - Teaching Space: 1 | ● Student Space (20) | |
| B00X - R0007 - Withdrawal Space - 1hb - (9.54 SQM) | ● Student Space (4) | |
| B00X - R0008 - Breakout Area - (13.84 SQM) | Not Applicable | Circulation or storage space. |
| B00X - R0011 - Breakout Area - (10.39 SQM) | Not Applicable | Circulation or storage space. |
| B00X - R0012 - Withdrawal Space - 1hb - (9.45 SQM) | ● Student Space (4) | |
| B00X - R0014 - Home Base - (44.9 SQM) - Teaching Space: 1 | ● Student Space (20) | |
| B00X - R0015 - Practical Activities - 1hb - (33 SQM) | ● Student Space (15) | |
| B00X - R0016 - Practical Activities - 1hb - (33.01 SQM) | ● Student Space (15) | |
| B00X - R0017 - Home Base - (45.04 SQM) - Teaching Space: 1 | ● Student Space (20) | |
| B00X - R0018 - Withdrawal Space - 1hb - (9.57 SQM) | ● Student Space (4) | |
| B00X - R0019 - Breakout Area - (10.35 SQM) | Not Applicable | Circulation or storage space. |
| B00X - R0022 - Breakout Area - (14.7 SQM) | Not Applicable | Circulation or storage space. |

| Entity Location | Audit Condition Classification (Capacity) | Comment |
|---|--|---------|
| B00X- R0023 - Withdrawal Space - 1hb - (9.57 SQM) | ● Student Space (4) | |
| B00X- R0028 - Home Base - (44.97 SQM) - Teaching Space: 1 | ● Student Space (20) | |
| B00X- R0029 - Practical Activities - 1hb - (33.11 SQM) | ● Student Space (15) | |