


# VENTILATION AUDIT REPORT

|                               |  |
|-------------------------------|--|
| <b>SCHOOL:</b>                | <b>Holsworthy Public School (4288)</b> |
| <b>AMU REGION:</b>            | <b>South Western Sydney</b>            |
| <b>STATE ELECTORATE:</b>      | <b>Holsworthy</b>                      |
| <b>LOCAL GOVERNMENT AREA:</b> | <b>Liverpool</b>                       |

4288 - Holsworthy Public School  
Site Plan (11010)



1:2,320














Printed: 24-Nov-2020

## Ventilation Audit Key

| Category  | Description  |
|---|--|
|  | Category A<br>Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation.<br>NB. Circulation and storage areas should not be used for groups or gatherings.   |
|  | Category B<br>This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> .<br>The report details the number of people who can be accommodated safely in each of the identified spaces. |

| Entity Location  | Audit Condition Classification (Capacity) | Comment                       |
|--|---|-------------------------------|
| B00A - R0001 - Movement - (30.11 SQM)                      | Not Applicable                            | Circulation or storage space. |
| B00A - R0003 - Staff Room Annexe - (15.92 SQM)             | Office (3)                                |                               |
| B00A - R0004 - Entry Vestibule - (6.83 SQM)                | Not Applicable                            | Circulation or storage space. |
| B00A - R0005 - Deputy Principal - (13.75 SQM)              | Office (3)                                |                               |
| B00A - R0006 - Movement - (15.31 SQM)                      | Not Applicable                            | Circulation or storage space. |
| B00A - R0011 - Sick Bay - (9.11 SQM)                       | Student Space (4)                         |                               |
| B00A - R0012 - Duplicating Workroom - (20.94 SQM)          | Office (5)                                |                               |
| B00A - R0013 - Clerical Office - (12.46 SQM)               | Office (3)                                |                               |
| B00A - R0014 - Entry Vestibule - (41.01 SQM)               | Not Applicable                            | Circulation or storage space. |
| B00A - R0016 - Movement - (9.06 SQM)                       | Not Applicable                            | Circulation or storage space. |
| B00A - R0017 - Principal - (21.96 SQM)                     | Office (5)                                |                               |
| B00A - R0018 - Deputy Principal - (12.78 SQM)              | Office (3)                                |                               |
| B00A - R0019 - Staff Room Annexe - (11.19 SQM)             | Office (2)                                |                               |
| B00A - R0021 - Movement - (80.33 SQM)                      | Not Applicable                            | Circulation or storage space. |
| B00A - R0024 - Staff Room - (89.13 SQM)                    | Office (22)                               |                               |
| B00A - R0025 - Staff Kitchen - (15.34 SQM)                 | Office (3)                                |                               |
| B00A - R1001 - Reading Area - (286.86 SQM)                 | Student Space (133)                       |                               |
| B00A - R1002 - Seminar/Study - (12.68 SQM)                 | Office (3)                                |                               |
| B00A - R1003 - Seminar/Study - (12.85 SQM)                 | Office (3)                                |                               |
| B00A - R1011 - Entry Vestibule - (14.89 SQM)               | Not Applicable                            | Circulation or storage space. |
| B00A - R1012 - Movement - (34.12 SQM)                      | Not Applicable                            | Circulation or storage space. |
| B00A - R1013 - Movement - (20.72 SQM)                      | Not Applicable                            | Circulation or storage space. |
| B00B - R0001 - Communal Space - (205.57 SQM)               | Student Space (95)                        |                               |
| B00B - R0002 - Raised Platform - (63.77 SQM)               | Not Applicable                            | Circulation or storage space. |
| B00B - R0006 - Movement - (40.39 SQM)                      | Not Applicable                            | Circulation or storage space. |
| B00B - R0007 - Canteen - (43.47 SQM)                       | Not Applicable                            | Circulation or storage space. |
| B00B - R0017 - Movement - (86.73 SQM)                      | Not Applicable                            | Circulation or storage space. |
| B00B - R0018 - Movement - (23.45 SQM)                      | Not Applicable                            | Circulation or storage space. |
| B00C - R0004 - Withdrawal Space - 1hb - (10.48 SQM)        | Student Space (4)                         |                               |
| B00C - R0008 - Movement - (75.67 SQM)                      | Not Applicable                            | Circulation or storage space. |
| B00C - R0011 - Practical Activities - 1hb - (20.56 SQM)    | Student Space (9)                         |                               |
| B00C - R0012 - Home Base - (69.14 SQM) - Teaching Space: 1 | Student Space (32)                        |                               |
| B00C - R0013 - Home Base - (73.18 SQM) - Teaching Space: 1 | Student Space (33)                        |                               |
| B00C - R0014 - Practical Activities - 1hb - (21.04 SQM)    | Student Space (9)                         |                               |
| B00D - R0001 - Special Programs Room - (20.07 SQM)         | Student Space (9)                         |                               |
| B00D - R0002 - Withdrawal Space - 1hb - (21.68 SQM)        | Student Space (10)                        |                               |
| B00D - R0003 - Practical Activities - 1hb - (28.46 SQM)    | Student Space (13)                        |                               |
| B00D - R0004 - Home Base - (42.68 SQM) - Teaching Space: 1 | Student Space (19)                        |                               |
| B00D - R0005 - Outdoor Learning Area - (34.16 SQM)         | Not Applicable                            | Circulation or storage space. |
| B00E - R0003 - Movement - (5.28 SQM)                       | Not Applicable                            | Circulation or storage space. |
| B00E - R0006 - Home Base - (56.61 SQM) - Teaching Space: 1 | Student Space (26)                        |                               |
| B00E - R0007 - Home Base - (56.61 SQM) - Teaching Space: 1 | Student Space (26)                        |                               |
| B00E - R0011 - Movement - (6.23 SQM)                       | Not Applicable                            | Circulation or storage space. |
| B00E - R0015 - Home Base - (56.3 SQM) - Teaching Space: 1  | Student Space (26)                        |                               |
| B00E - R0016 - Home Base - (56.76 SQM) - Teaching Space: 1 | Student Space (26)                        |                               |
| B00E - R0020 - Movement - (6.36 SQM)                       | Not Applicable                            | Circulation or storage space. |
| B00E - R0022 - Movement - (10.95 SQM)                      | Not Applicable                            | Circulation or storage space. |
| B00E - R0027 - Practical Activities - 1hb - (12.69 SQM)    | Student Space (5)                         |                               |
| B00E - R0028 - Practical Activities - 1hb - (12.55 SQM)    | Student Space (5)                         |                               |
| B00E - R0031 - Practical Activities - 1hb - (12.61 SQM)    | Student Space (5)                         |                               |

| Entity Location  | Audit Condition Classification (Capacity) | Comment                       |
|--|---|-------------------------------|
| B00E - R0032 - Practical Activities - 1hb - (12.6 SQM)     | Student Space (5)                         |                               |
| B00F - R0001 - Home Base - (56.8 SQM) - Teaching Space: 1  | Student Space (26)                        |                               |
| B00F - R0004 - Movement - (5.2 SQM)                        | Not Applicable                            | Circulation or storage space. |
| B00F - R0009 - Home Base - (56.4 SQM) - Teaching Space: 1  | Student Space (26)                        |                               |
| B00F - R0014 - Entry Vestibule - (12.73 SQM)               | Not Applicable                            | Circulation or storage space. |
| B00F - R0021 - Practical Activities - 1hb - (14.65 SQM)    | Student Space (6)                         |                               |
| B00F - R0022 - Practical Activities - 1hb - (14.76 SQM)    | Student Space (6)                         |                               |
| B00F - R0028 - Home Base - (61.05 SQM) - Teaching Space: 1 | Student Space (28)                        |                               |
| B00F - R0029 - Practical Activities - 1hb - (10.34 SQM)    | Student Space (4)                         |                               |
| B00G - R0001 - Home Base - (56.86 SQM) - Teaching Space: 1 | Student Space (26)                        |                               |
| B00G - R0004 - Movement - (5.63 SQM)                       | Not Applicable                            | Circulation or storage space. |
| B00G - R0009 - Home Base - (58.98 SQM) - Teaching Space: 1 | Student Space (27)                        |                               |
| B00G - R0010 - Home Base - (56.94 SQM) - Teaching Space: 1 | Student Space (26)                        |                               |
| B00G - R0013 - Movement - (5.13 SQM)                       | Not Applicable                            | Circulation or storage space. |
| B00G - R0018 - Home Base - (57.09 SQM) - Teaching Space: 1 | Student Space (26)                        |                               |
| B00H - R0002 - Movement - (13.19 SQM)                      | Not Applicable                            | Circulation or storage space. |
| B00I - R0001 - Interview - (8.29 SQM)                      | Office (2)                                |                               |
| B00I - R0003 - Staff Room Annexe - (10.29 SQM)             | Office (2)                                |                               |
| B00J - R0001 - Home Base - (57.46 SQM) - Teaching Space: 1 | Student Space (26)                        |                               |
| B00J - R0009 - Home Base - (57.38 SQM) - Teaching Space: 1 | Student Space (26)                        |                               |
| B00J - R0010 - Home Base - (57.29 SQM) - Teaching Space: 1 | Student Space (26)                        |                               |
| B00J - R0018 - Home Base - (57.3 SQM) - Teaching Space: 1  | Student Space (26)                        |                               |
| B00J - R0021 - Practical Activities - 1hb - (15.37 SQM)    | Student Space (7)                         |                               |
| B00J - R0022 - Practical Activities - 1hb - (14.94 SQM)    | Student Space (6)                         |                               |
| B00J - R0023 - Practical Activities - 1hb - (15.03 SQM)    | Student Space (6)                         |                               |
| B00J - R0024 - Practical Activities - 1hb - (15.13 SQM)    | Student Space (7)                         |                               |
| B00J - R0025 - Movement - (8.05 SQM)                       | Not Applicable                            | Circulation or storage space. |
| B00J - R0026 - Movement - (8.07 SQM)                       | Not Applicable                            | Circulation or storage space. |
| B00K - R0001 - Special Programs Room - (17.93 SQM)         | Student Space (8)                         |                               |
| B00K - R0003 - Movement - (8.96 SQM)                       | Not Applicable                            | Circulation or storage space. |
| B00K - R0009 - Home Base - (78.37 SQM) - Teaching Space: 1 | Student Space (36)                        |                               |
| B00K - R0010 - Home Base - (56.67 SQM) - Teaching Space: 1 | Student Space (26)                        |                               |
| B00K - R0014 - Movement - (6.31 SQM)                       | Not Applicable                            | Circulation or storage space. |
| B00K - R0017 - Home Base - (56.44 SQM) - Teaching Space: 1 | Student Space (26)                        |                               |
| B00K - R0021 - Movement - (7.71 SQM)                       | Not Applicable                            | Circulation or storage space. |
| B00K - R0023 - Special Programs Room - (21.14 SQM)         | Student Space (9)                         |                               |
| B00K - R0026 - Practical Activities - 1hb - (13.31 SQM)    | Student Space (6)                         |                               |
| B00K - R0027 - Practical Activities - 1hb - (13.31 SQM)    | Student Space (6)                         |                               |
| B00K - R0030 - Practical Activities - 1hb - (13.41 SQM)    | Student Space (6)                         |                               |
| B00K - R0031 - Practical Activities - 1hb - (13.35 SQM)    | Student Space (6)                         |                               |
| B00K - R0032 - Home Base - (56.69 SQM) - Teaching Space: 1 | Student Space (26)                        |                               |
| B00M - R0001 - Home Base - (57.6 SQM) - Teaching Space: 1  | Student Space (26)                        |                               |
| B00M - R0006 - Home Base - (56.88 SQM) - Teaching Space: 1 | Student Space (26)                        |                               |
| B00M - R0007 - Movement - (6.16 SQM)                       | Not Applicable                            | Circulation or storage space. |
| B00M - R0009 - Practical Activities - 1hb - (15 SQM)       | Student Space (6)                         |                               |
| B00M - R0012 - Practical Activities - 1hb - (14.56 SQM)    | Student Space (6)                         |                               |
| B00N - R0004 - Home Base - (57.91 SQM) - Teaching Space: 1 | Student Space (26)                        |                               |

| Entity Location  | Audit Condition Classification (Capacity)  | Comment                       |
|--|--|-------------------------------|
| B00N - R0005 - Home Base - (57.31 SQM) - Teaching Space: 1 |  Student Space (26) |                               |
| B00N - R0008 - Movement - (5.52 SQM)                       | Not Applicable   | Circulation or storage space. |
| B00N - R0014 - Home Base - (56.69 SQM) - Teaching Space: 1 |  Student Space (26) |                               |
| B00N - R0015 - Home Base - (85.66 SQM) - Teaching Space: 1 |  Student Space (39) |                               |
| B00N - R0021 - Movement - (10.22 SQM)                      | Not Applicable   | Circulation or storage space. |
| B00N - R0023 - Practical Activities - 1hb - (13.84 SQM)    |  Student Space (6)  |                               |
| B00N - R0024 - Practical Activities - 1hb - (14.22 SQM)    |  Student Space (6)  |                               |
| B00N - R0027 - Practical Activities - 1hb - (14.1 SQM)     |  Student Space (6)  |                               |
| B00N - R0028 - Practical Activities - 1hb - (21.44 SQM)    |  Student Space (9)  |                               |
| B00R - R0002 - Staff Kitchen - (18.34 SQM)                 |  Office (4)         |                               |
| B00R - R0006 - Special Programs Room - (17.73 SQM)         |  Student Space (8)  |                               |
| B00R - R0011 - Special Programs Room - (76.64 SQM)         |  Student Space (35) |                               |
| B00R - R0013 - Special Programs Room - (77.5 SQM)          |  Student Space (35) |                               |
| B00R - R0021 - Staff Room - (15.04 SQM)                    |  Office (3)         |                               |
| B00R - R0022 - Staff Kitchen - (19.87 SQM)                 |  Office (4)         |                               |