

VENTILATION AUDIT REPORT

SCHOOL:	Homebush West Public School (5251)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Strathfield
LOCAL GOVERNMENT AREA:	Strathfield

5251 - Homebush West Public School
Site Plan (10692)














Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Home Base - (47.37 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R0008 - Reading Area - (47.38 SQM)	● Student Space (21)	
B00A - R0017 - Interview - (8.75 SQM)	● Office (2)	
B00A - R0034 - Special Programs Room - Type 1 - (34.65 SQM)	● Student Space (16)	
B00A - R0036 - Movement - (21.03 SQM)	Not Applicable	Circulation or storage space.
B00A - R0038 - Seminar/Study - (19.47 SQM)	● Office (4)	
B00A - R0039 - Home Base - (47.08 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R0040 - Practical Activities - 1hb - (22.71 SQM)	● Student Space (10)	
B00A - R0042 - Practical Activities - 1hb - (16.75 SQM)	● Student Space (7)	
B00A - R0045 - Movement - (34.66 SQM)	Not Applicable	Circulation or storage space.
B00A - R0046 - Withdrawal Space - 2hb - (22.67 SQM)	● Student Space (10)	
B00A - R0048 - Practical Activities - 1hb - (17.34 SQM)	● Student Space (8)	
B00A - R0051 - Special Programs Room - (52.21 SQM)	● Student Space (24)	
B00A - R0052 - Reading Area - (115.57 SQM)	● Student Space (53)	
B00L - R0001 - Communal Space - (142.7 SQM)	● Student Space (66)	
B00L - R0002 - Raised Platform - (59.18 SQM)	Not Applicable	Circulation or storage space.
B00L - R0016 - Movement - (7 SQM)	Not Applicable	Circulation or storage space.
B00L - R0021 - Movement - (13.92 SQM)	Not Applicable	Circulation or storage space.
B00N - R0004 - Practical Activities - 1hb - (18.85 SQM)	● Student Space (8)	
B00N - R0006 - Home Base - (61.49 SQM) - Teaching Space: 1	● Student Space (28)	
B00N - R0007 - Withdrawal Space - 2hb - (11.92 SQM)	● Student Space (5)	
B00N - R0008 - Home Base - (61.06 SQM) - Teaching Space: 1	● Student Space (28)	
B00N - R0009 - Practical Activities - 1hb - (19.14 SQM)	● Student Space (8)	
B00N - R1003 - Practical Activities - 1hb - (18.95 SQM)	● Student Space (8)	
B00N - R1005 - Home Base - (61.29 SQM) - Teaching Space: 1	● Student Space (28)	
B00N - R1006 - Withdrawal Space - 2hb - (12.13 SQM)	● Student Space (5)	
B00N - R1007 - Home Base - (61.34 SQM) - Teaching Space: 1	● Student Space (28)	
B00N - R1008 - Practical Activities - 1hb - (19.02 SQM)	● Student Space (8)	
B00P - R0002 - Entry Vestibule - (34.29 SQM)	Not Applicable	Circulation or storage space.
B00P - R0003 - Clerical Office - (36.96 SQM)	● Office (9)	
B00P - R0004 - Sick Bay - (8.98 SQM)	● Student Space (4)	
B00P - R0006 - Interview/Office - Type 3 - (16.1 SQM)	● Office (4)	
B00P - R0007 - Movement - (56.14 SQM)	Not Applicable	Circulation or storage space.
B00P - R0010 - Staff Room Annexe - (22.61 SQM)	● Office (5)	
B00P - R0011 - Staff Room - (27.61 SQM)	● Office (6)	
B00P - R0012 - Staff Kitchen - (17.73 SQM)	● Office (4)	
B00P - R0013 - Deputy Principal - Type 2 - (13 SQM)	● Office (3)	
B00P - R0014 - Principal - (17.04 SQM)	● Office (4)	
B00P - R0015 - Interview - (13.53 SQM)	● Office (3)	
B00P - R0020 - Duplicating Workroom - (22.82 SQM)	● Office (5)	
B00P - R1001 - Movement - (12.64 SQM)	Not Applicable	Circulation or storage space.
B00P - R1002 - Special Programs Room - Type 2 - (15.88 SQM)	● Student Space (7)	
B00P - R1003 - Special Programs Room - Type 2 - (15.83 SQM)	● Student Space (7)	
B00P - R1005 - Home Base - (61.67 SQM) - Teaching Space: 1	● Student Space (28)	
B00P - R1006 - Practical Activities - 1hb - (19.27 SQM)	● Student Space (8)	
B00P - R1007 - Withdrawal Space - 2hb - (11.8 SQM)	● Student Space (5)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00P - R1008 - Home Base - (61.04 SQM) - Teaching Space: 1	 Student Space (28)	
B00P - R1010 - Practical Activities - 1hb - (18.94 SQM)	 Student Space (8)	
B00Q - R0002 - Movement - (37.62 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0006 - Home Base - (68.82 SQM) - Teaching Space: 1	 Student Space (31)	
B00Q - R0008 - Raised Platform - (32.66 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0009 - Movement - (10.15 SQM)	Not Applicable	Circulation or storage space.
B00R - R0001 - Movement - (6.41 SQM)	Not Applicable	Circulation or storage space.
B00R - R0002 - Home Base - (98.02 SQM) - Teaching Space: 1	 Student Space (45)	
B00R - R0003 - Practical Activities - (10.51 SQM)	 Student Space (4)	
B00R - R0004 - Raised Platform - (22.85 SQM)	Not Applicable	Circulation or storage space.
B00S - R0001 - Canteen - (49.81 SQM)	Not Applicable	Circulation or storage space.
B00S - R0007 - Home Base - (103.33 SQM) - Teaching Space: 1	 Student Space (47)	
B00S - R0009 - Withdrawal Space - 2hb - (10.33 SQM)	 Student Space (4)	
B00S - R0010 - Practical Activities - (50.96 SQM)	 Student Space (23)	
B00S - R0012 - Presentation Area - (46.31 SQM)	Not Applicable	Circulation or storage space.
B00S - R0013 - Home Base X2 - (145.4 SQM) - Teaching Space: 2	 Student Space (67)	
B00S - R0015 - Interview - (13.59 SQM)	 Office (3)	
B00S - R0016 - Home Base X3 - (119.23 SQM)	 Student Space (55)	
B00S - R0017 - Withdrawal Space - 1hb - (13.6 SQM)	 Student Space (6)	
B00S - R0018 - Practical Activities - (53.76 SQM)	 Student Space (24)	
B00S - R0019 - Presentation Home Base - (53.21 SQM) - Teaching Space: 1	Not Applicable	Circulation or storage space.
B00S - R0020 - Home Base X2 - (127.85 SQM) - Teaching Space: 2	 Student Space (59)	
B00S - R0021 - Interview - (12.54 SQM)	 Office (3)	
B00S - R0022 - Special Programs Room - (26.25 SQM)	 Student Space (12)	
B00S - R0023 - Staff Kitchen - (8.81 SQM)	 Office (2)	
B00S - R0024 - Special Programs Room - (27.32 SQM)	 Student Space (12)	
B00S - R0025 - Staff Kitchen - (7.75 SQM)	 Office (1)	
B00S - R1005 - Presentation Area - (30.88 SQM)	Not Applicable	Circulation or storage space.
B00S - R1006 - Home Base X3 - (112.43 SQM) - Teaching Space: 2	 Student Space (52)	
B00S - R1007 - Craft Room - (10.4 SQM)	 Office (2)	
B00S - R1009 - Practical Activities - 2hb - (51.52 SQM)	 Student Space (23)	
B00S - R1010 - Presentation Area - (56.59 SQM)	Not Applicable	Circulation or storage space.
B00S - R1011 - Home Base X2 - (144.48 SQM) - Teaching Space: 2	 Student Space (67)	
B00S - R1012 - Withdrawal Space - 1hb - (13.9 SQM)	 Student Space (6)	
B00S - R1013 - Home Base X2 - (120.99 SQM) - Teaching Space: 2	 Student Space (56)	
B00S - R1014 - Withdrawal Space - 1hb - (14.23 SQM)	 Student Space (6)	
B00S - R1015 - Presentation Area - (51.33 SQM)	Not Applicable	Circulation or storage space.
B00S - R1016 - Practical Activities - (51.33 SQM)	 Student Space (23)	
B00S - R1017 - Home Base X3 - (181.81 SQM) - Teaching Space: 3	 Student Space (84)	
B00S - R1019 - Withdrawal Space - 1hb - (11.79 SQM)	 Student Space (5)	
B00S - R1020 - Movement - (18.86 SQM)	Not Applicable	Circulation or storage space.
B00S - R1021 - Home Base X2 - (122.93 SQM) - Teaching Space: 2	 Student Space (57)	
B00S - R1022 - Practical Activities - (36.9 SQM)	 Student Space (17)	
B00S - R1023 - Withdrawal Space - 1hb - (18.68 SQM)	 Student Space (8)	
B00S - R1024 - Staff Room - (16.42 SQM)	 Office (4)	
B00S - R1025 - Staff Kitchen - (5.33 SQM)	 Office (1)	
B00S - R2005 - Home Base X4 - (302.2 SQM) - Teaching Space: 4	 Student Space (140)	
B00S - R2007 - Withdrawal Space - 2hb - (11.67 SQM)	 Student Space (5)	
B00S - R2008 - Presentation Area - (53.01 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00S - R2010 - Withdrawal Space - 2hb - (12.57 SQM)	 Student Space (5)	
B00S - R2011 - Practical Activities - (52.16 SQM)	 Student Space (24)	
B00S - R2012 - Movement - (9.81 SQM)	Not Applicable	Circulation or storage space.
B00S - R2013 - Practical Activities - (60.34 SQM)	 Student Space (27)	
B00S - R2014 - Presentation Area - (59.86 SQM)	Not Applicable	Circulation or storage space.
B00S - R2015 - Home Base X4 - (281.07 SQM) - Teaching Space: 4	 Student Space (130)	
B00S - R2016 - Withdrawal Space - 2hb - (13.53 SQM)	 Student Space (6)	
B00S - R2017 - Withdrawal Space - 2hb - (14.09 SQM)	 Student Space (6)	
B00S - R2021 - Home Base - (122.93 SQM) - Teaching Space: 1	 Student Space (57)	
B00S - R2022 - Movement - (18.86 SQM)	Not Applicable	Circulation or storage space.
B00S - R2023 - Practical Activities - (36.9 SQM)	 Student Space (17)	
B00S - R2024 - Withdrawal Space - 2hb - (18.68 SQM)	 Student Space (8)	
B00S - R2025 - Staff Room - (16.42 SQM)	 Office (4)	
B00S - R2026 - Staff Kitchen - (5.33 SQM)	 Office (1)	