

VENTILATION AUDIT REPORT

SCHOOL:	Hornsby North Public School (4365)
AMU REGION:	Northern Sydney
STATE ELECTORATE:	Hornsby
LOCAL GOVERNMENT AREA:	Hornsby

4365 - Hornsby North Public School
Site Plan (10432)



1:930

Printed: 24-Dec-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Practical Activities - 1hb - (52.33 SQM)	● Student Space (24)	
B00A - R0003 - Home Base - (52.55 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0001 - Withdrawal Space - 1hb - (8.76 SQM)	● Student Space (4)	
B00B - R0002 - Practical Activities - 1hb - (13.48 SQM)	● Student Space (6)	
B00B - R0004 - Home Base - (40.26 SQM) - Teaching Space: 1	● Student Space (18)	
B00B - R0007 - Home Base - (40.26 SQM) - Teaching Space: 1	● Student Space (18)	
B00B - R0009 - Practical Activities - 1hb - (13.48 SQM)	● Student Space (6)	
B00B - R0010 - Withdrawal Space - 1hb - (8.76 SQM)	● Student Space (4)	
B00C - R0005 - Home Base - (47.54 SQM) - Teaching Space: 1	● Student Space (22)	
B00C - R0007 - Practical Activities - 1hb - (27.4 SQM)	● Student Space (12)	
B00C - R0008 - Practical Activities - 1hb - (8.48 SQM)	● Student Space (3)	
B00C - R0009 - Practical Activities - 1hb - (8.48 SQM)	● Student Space (3)	
B00C - R0011 - Home Base - (46.55 SQM) - Teaching Space: 1	● Student Space (21)	
B00C - R0014 - Staff Room Annexe - (13.11 SQM)	● Office (3)	
B00D - R0003 - Movement - (13.71 SQM)	Not Applicable	Circulation or storage space.
B00D - R0009 - Reading Area - (250.84 SQM)	● Student Space (116)	
B00D - R0010 - Seminar/Study - (14.13 SQM)	● Office (3)	
B00D - R0011 - Seminar/Study - (13.4 SQM)	● Office (3)	
B00D - R1002 - Home Base - (62.14 SQM) - Teaching Space: 1	● Student Space (28)	
B00D - R1004 - Practical Activities - 1hb - (27.07 SQM)	● Student Space (12)	
B00D - R1006 - Home Base - (62.14 SQM) - Teaching Space: 1	● Student Space (28)	
B00D - R9002 - Withdrawal Space - 1hb - (42.15 SQM)	● Student Space (19)	
B00D - R9007 - Withdrawal Space - 1hb - (47.15 SQM)	● Student Space (21)	
B00E - R0003 - Communal Space - (241.65 SQM)	● Student Space (112)	
B00E - R0005 - Movement - (11.74 SQM)	Not Applicable	Circulation or storage space.
B00E - R0006 - Raised Platform - (49.5 SQM)	Not Applicable	Circulation or storage space.
B00E - R0008 - Movement - (8.68 SQM)	Not Applicable	Circulation or storage space.
B00E - R0010 - Canteen - (46.81 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Staff Room - (66.42 SQM)	● Office (16)	
B00F - R0006 - Movement - (11.48 SQM)	Not Applicable	Circulation or storage space.
B00F - R0008 - Home Base - (56.65 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R0011 - Movement - (7.2 SQM)	Not Applicable	Circulation or storage space.
B00F - R0013 - Home Base - (56.65 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R0014 - Home Base - (57.36 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R0018 - Movement - (6.98 SQM)	Not Applicable	Circulation or storage space.
B00F - R0020 - Home Base - (57.28 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0004 - Home Base - (56.74 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0005 - Home Base - (56.82 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0008 - Movement - (6.13 SQM)	Not Applicable	Circulation or storage space.
B00G - R0014 - Home Base - (56.9 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0015 - Home Base - (56.83 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0021 - Principal - (20.78 SQM)	● Office (5)	
B00G - R0022 - Entry Vestibule - (36.28 SQM)	Not Applicable	Circulation or storage space.
B00G - R0027 - Sick Bay - (8.52 SQM)	● Student Space (3)	
B00G - R0029 - Movement - (26.55 SQM)	Not Applicable	Circulation or storage space.
B00G - R0030 - Duplicating Workroom - (14.15 SQM)	● Office (3)	
B00G - R0032 - Deputy Principal - (13.95 SQM)	● Office (3)	
B00H - R0003 - Practical Activities - 1hb - (19.52 SQM)	● Student Space (9)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00H - R0005 - Home Base - (87.01 SQM) - Teaching Space: 1	Student Space (40)	
B00H - R0006 - Home Base - (86.99 SQM) - Teaching Space: 1	Student Space (40)	
B00H - R0008 - Practical Activities - 1hb - (19.52 SQM)	Student Space (9)	
B00I - R0002 - Movement - (16.07 SQM)	Not Applicable	Circulation or storage space.
B00I - R0003 - Interview - (12.75 SQM)	Office (3)	
B00I - R0005 - Clerical Office - (10.64 SQM)	Office (2)	
B00J - R0001 - Movement - (38.47 SQM)	Not Applicable	Circulation or storage space.
B00J - R0002 - Practical Activities - 1hb - (19.4 SQM)	Student Space (9)	
B00J - R0004 - Home Base - (59.2 SQM) - Teaching Space: 1	Student Space (27)	
B00J - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	Student Space (5)	
B00J - R0006 - Home Base - (59.19 SQM) - Teaching Space: 1	Student Space (27)	
B00J - R0008 - Practical Activities - 1hb - (19.41 SQM)	Student Space (9)	
B00K - R0001 - Practical Activities - 1hb - (20.48 SQM)	Student Space (9)	
B00K - R0002 - Home Base - (58.48 SQM) - Teaching Space: 1	Student Space (27)	
B00K - R0003 - Withdrawal Space - 1hb - (9.2 SQM)	Student Space (4)	
B00K - R0005 - Practical Activities - 1hb - (18.81 SQM)	Student Space (8)	
B00K - R0007 - Home Base - (60.28 SQM) - Teaching Space: 1	Student Space (27)	
B00K - R0008 - Withdrawal Space - 2hb - (11.67 SQM)	Student Space (5)	
B00K - R0009 - Practical Activities - 1hb - (18.82 SQM)	Student Space (8)	
B00K - R0010 - Home Base - (60.28 SQM) - Teaching Space: 1	Student Space (27)	
B00K - R1001 - Practical Activities - 1hb - (20.48 SQM)	Student Space (9)	
B00K - R1002 - Home Base - (58.48 SQM) - Teaching Space: 1	Student Space (27)	
B00K - R1003 - Withdrawal Space - 1hb - (9.2 SQM)	Student Space (4)	
B00K - R1005 - Practical Activities - 1hb - (18.81 SQM)	Student Space (8)	
B00K - R1007 - Home Base - (60.28 SQM) - Teaching Space: 1	Student Space (27)	
B00K - R1008 - Withdrawal Space - 2hb - (11.67 SQM)	Student Space (5)	
B00K - R1009 - Practical Activities - 1hb - (18.82 SQM)	Student Space (8)	
B00K - R1010 - Home Base - (60.28 SQM) - Teaching Space: 1	Student Space (27)	
OS 602 10310 - OS 602 10310 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 11925 - OS 602 11925 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 15157 - OS 602 15157 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 15221 - OS 602 15221 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 603 12325 - OS 603 12325 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	Student Space (35)	
OS 603 13282 - OS 603 13282 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	Student Space (35)	
OS 603 13291 - OS 603 13291 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	Student Space (35)	
OS 603 13359 - OS 603 13359 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	Student Space (35)	
OS 606 19010 - OS 606 19010 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	Student Space (35)	
OS 606 19122 - OS 606 19122 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	Student Space (35)	
OS 606 19258 - OS 606 19258 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	Student Space (35)	
OS 606 19262 - OS 606 19262 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	Student Space (35)	
OS 606 19594 - OS 606 19594 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	Student Space (35)	
OS 606 19666 - OS 606 19666 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	Student Space (35)	