

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Hoxton Park High School (8485)</b>
<b>AMU REGION:</b>	<b>South Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Liverpool</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Liverpool</b>

8485 - Hoxton Park High School  
Site Plan (10434)



1:1,671







Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Administration - Clerical - (20.14 SQM)	Office (5)	
B00A - R0002 - Deputy Principal Office - (16.11 SQM)	Office (4)	
B00A - R0008 - Audio Visual Workroom - (79.8 SQM)	Student Space (37)	
B00A - R0014 - Interview/Office - Type 2 - (9.68 SQM)	Office (2)	
B00A - R0017 - Principal Office - (23.05 SQM)	Office (5)	
B00A - R0019 - Deputy Principal Office - (19.62 SQM)	Office (4)	
B00A - R0020 - Administration - Clerical - (33.15 SQM)	Office (8)	
B00A - R0022 - Public Reception - (31.22 SQM)	Not Applicable	Circulation or storage space.
B00A - R0023 - Movement - (40.67 SQM)	Not Applicable	Circulation or storage space.
B00A - R0025 - Clinic - (6.43 SQM)	Office (1)	
B00A - R0026 - Tea Room - (16.87 SQM)	Not Applicable	Circulation or storage space.
B00A - R0027 - Commonroom - (58.82 SQM)	Office (14)	
B00A - R0031 - Movement - (30.48 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - General Learning Space - (40.49 SQM) - Teaching Space: 1	Student Space (18)	
B00A - R1002 - General Learning Space - (40.94 SQM) - Teaching Space: 1	Student Space (18)	
B00A - R1004 - Interview/Office - Type 1 - (18.19 SQM)	Office (4)	
B00A - R1005 - Staff Study - (40.88 SQM)	Office (10)	
B00A - R1006 - General Learning Space - (53.89 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R1007 - General Learning Space - (53.82 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1008 - Staff Study - (22.46 SQM)	Office (5)	
B00A - R1011 - General Learning Space - (60.03 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1012 - General Learning Space - (60.1 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1013 - General Learning Space - (53.89 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R1014 - Movement - (57.3 SQM)	Not Applicable	Circulation or storage space.
B00B - M1002 - Seminar - (22.05 SQM)	Office (5)	
B00B - M1003 - Seminar - (23.95 SQM)	Office (5)	
B00B - M1004 - Movement - (37.63 SQM)	Not Applicable	Circulation or storage space.
B00B - M1005 - Senior Study - (36.99 SQM)	Office (9)	
B00B - M1006 - General Learning Space - (71.46 SQM) - Teaching Space: 1	Student Space (33)	
B00B - R0001 - Laboratory L.S. - (91.04 SQM) - Teaching Space: 1	Student Space (42)	
B00B - R0002 - Staff Study - (49.19 SQM)	Office (12)	
B00B - R0003 - Laboratory L.S. - (91.04 SQM) - Teaching Space: 1	Student Space (42)	
B00B - R0005 - Laboratory L.S. - (90.94 SQM) - Teaching Space: 1	Student Space (42)	
B00B - R0006 - Preparation - Science - (49.28 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Laboratory L.S. - (90.76 SQM) - Teaching Space: 1	Student Space (42)	
B00B - R0009 - Movement - (59 SQM)	Not Applicable	Circulation or storage space.
B00B - R1001 - Main Area - (374.73 SQM)	Not Applicable	Circulation or storage space.
B00B - R1008 - Staff Study - (14.92 SQM)	Office (3)	
B00B - R1009 - Staff Study - (12.71 SQM)	Office (3)	
B00B - R1010 - Audio Visual Workroom - (35.31 SQM)	Student Space (16)	
B00B - R1012 - Workroom - (13.93 SQM)	Office (3)	
B00C - R0001 - Food Technology L.S. - (82.29 SQM) - Teaching Space: 1	Student Space (38)	
B00C - R0006 - Food/Research Space - (37.98 SQM)	Not Applicable	Circulation or storage space.
B00C - R0007 - General Learning Space - (65.74 SQM) - Teaching Space: 1	Student Space (30)	
B00C - R0010 - Staff Study - (32.1 SQM)	Office (8)	
B00C - R0015 - Movement - (73.86 SQM)	Not Applicable	Circulation or storage space.
B00C - R0016 - Food Technology L.S. - (76.49 SQM) - Teaching Space: 1	Student Space (35)	
B00C - R1001 - General Learning Space - (65.15 SQM) - Teaching Space: 1	Student Space (30)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R1003 - General Learning Space - (65.76 SQM) - Teaching Space: 1	● Student Space (30)	
B00C - R1005 - Music Learning Space - (64.97 SQM) - Teaching Space: 1	● Student Space (30)	
B00C - R1006 - Staff Study - (32.07 SQM)	○ Office (8)	
B00C - R1007 - Music Learning Space - (65.85 SQM) - Teaching Space: 1	● Student Space (30)	
B00C - R1009 - Art Learning Space - (65.83 SQM) - Teaching Space: 1	● Student Space (30)	
B00C - R1010 - Art Learning Space - (69.54 SQM) - Teaching Space: 1	● Student Space (32)	
B00C - R1012 - Movement - (61.79 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Student Canteen - (48.09 SQM)	Not Applicable	Circulation or storage space.
B00D - R0010 - Multi-Purpose Space - (309.49 SQM)	● Student Space (143)	
B00D - R0018 - Movement - (14.31 SQM)	Not Applicable	Circulation or storage space.
B00D - R0019 - Movement - (48.92 SQM)	Not Applicable	Circulation or storage space.
B00D - R0020 - Movement - (53.22 SQM)	Not Applicable	Circulation or storage space.
B00D - R0023 - Movement - (15.19 SQM)	Not Applicable	Circulation or storage space.
B00D - R1009 - Movement - (66.51 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Metal Technology L.S. - (82.93 SQM) - Teaching Space: 1	● Student Space (38)	
B00E - R0006 - Welding Area - (9.87 SQM)	Not Applicable	Circulation or storage space.
B00E - R0007 - Metal Technology L.S. - (82.84 SQM) - Teaching Space: 1	● Student Space (38)	
B00E - R0011 - Movement - (37 SQM)	Not Applicable	Circulation or storage space.
B00E - R0017 - Art Learning Space - (62.08 SQM) - Teaching Space: 1	● Student Space (28)	
B00E - R1001 - Staff Study - (25.89 SQM)	○ Office (6)	
B00E - R1002 - Design L.S. - (52.8 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1005 - Wood Technology L.S. - (82.93 SQM) - Teaching Space: 1	● Student Space (38)	
B00E - R1007 - Wood Technology Bay - (20.95 SQM)	Not Applicable	Circulation or storage space.
B00E - R1008 - Wood Technology L.S. - (82.93 SQM) - Teaching Space: 1	● Student Space (38)	
B00E - R1011 - Computer Learning Space - (52.03 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1012 - Movement - (52.19 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Laboratory L.S. - (90.82 SQM) - Teaching Space: 1	● Student Space (42)	
B00F - R0002 - Preparation - Science - (48.9 SQM)	Not Applicable	Circulation or storage space.
B00F - R0003 - Laboratory L.S. - (90.82 SQM) - Teaching Space: 1	● Student Space (42)	
B00F - R1001 - General Learning Space - (90.72 SQM) - Teaching Space: 1	● Student Space (42)	
B00F - R1002 - Staff Study - (48.81 SQM)	○ Office (12)	
B00F - R1003 - Movement Studio - (90.91 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - General Learning Space - (53.24 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R0002 - General Learning Space - (53.53 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R0003 - General Learning Space - (37.86 SQM) - Teaching Space: 1	● Student Space (17)	
B00G - R0004 - General Learning Space - (52.14 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R0005 - Computer Learning Space - (51.71 SQM) - Teaching Space: 1	● Student Space (23)	
B00G - R0006 - General Learning Space - (52.14 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R0008 - Staff Study - (7.61 SQM)	○ Office (1)	
B00G - R0009 - Staff Kitchen - (5.5 SQM)	○ Office (1)	
B00G - R0010 - Staff Study - (36.74 SQM)	○ Office (9)	
B00G - R0012 - Staff Study - (10.81 SQM)	○ Office (2)	
B00G - R0018 - Movement - (85.7 SQM)	Not Applicable	Circulation or storage space.
B00G - R1001 - General Learning Space - (53.16 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R1003 - General Learning Space - (53.67 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R1004 - General Learning Space - (53.67 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R1005 - Staff Study - (18.41 SQM)	○ Office (4)	
B00G - R1006 - Computer Learning Space - (53.09 SQM) - Teaching Space: 1	● Student Space (24)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R1007 - Computer Learning Space - (54.04 SQM) - Teaching Space: 1	 Student Space (25)	
B00G - R1008 - Movement - (18.42 SQM)	Not Applicable	Circulation or storage space.
B00G - R1009 - General Learning Space - (54.7 SQM) - Teaching Space: 1	 Student Space (25)	
B00G - R1010 - General Learning Space - (54.63 SQM) - Teaching Space: 1	 Student Space (25)	
B00G - R1013 - Staff Study - (11.05 SQM)	 Office (2)	
B00G - R1014 - Staff Study - (40.83 SQM)	 Office (10)	
B00G - R1015 - Movement - (26.48 SQM)	Not Applicable	Circulation or storage space.
B00H - R0004 - General Assistants - (6.55 SQM)	 Office (1)	