


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Hoxton Park Public School (2187)</b>
<b>AMU REGION:</b>	<b>South Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Liverpool</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Liverpool</b>

2187 - Hoxton Park Public School  
Site Plan (03082)





1:1,226

Printed: 23-Jun-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00H - R0002 - Practical Activities - 1hb - (19.23 SQM)	 Student Space (8)	
B00H - R0004 - Home Base - (60.58 SQM) - Teaching Space: 1	 Student Space (28)	
B00H - R0005 - Withdrawal Space - 2hb - (11.74 SQM)	 Student Space (5)	
B00H - R0006 - Home Base - (60.63 SQM) - Teaching Space: 1	 Student Space (28)	
B00H - R0008 - Practical Activities - 1hb - (18.65 SQM)	 Student Space (8)	
B0AA - R0002 - Duplicating Workroom - (32.73 SQM)	 Office (8)	
B0AA - R0003 - Principal - (16.89 SQM)	 Office (4)	
B0AA - R0008 - Staff Room Annexe - (26.5 SQM)	 Office (6)	
B0AA - R0009 - Staff Room - (57.7 SQM)	 Office (14)	
B0AA - R0012 - Deputy Principal - (13.15 SQM)	 Office (3)	
B0AA - R0013 - Deputy Principal - (13.11 SQM)	 Office (3)	
B0AA - R0014 - Interview - (13.11 SQM)	 Office (3)	
B0AA - R0016 - Sick Bay - (8.22 SQM)	 Student Space (3)	
B0AA - R0017 - Clerical Office/Workroom - (17.69 SQM)	 Office (4)	
B0AA - R0019 - Entry Vestibule - (17.14 SQM)	Not Applicable	Circulation or storage space.
B0AA - R0020 - Movement - (38.26 SQM)	Not Applicable	Circulation or storage space.
BOBB - R0002 - Practical Activities - 1hb - (19.8 SQM)	 Student Space (9)	
BOBB - R0003 - Home Base - (60.26 SQM) - Teaching Space: 1	 Student Space (27)	
BOBB - R0004 - Withdrawal Space - 2hb - (11.54 SQM)	 Student Space (5)	
BOBB - R0005 - Home Base - (59.41 SQM) - Teaching Space: 1	 Student Space (27)	
BOBB - R0006 - Practical Activities - 1hb - (19.95 SQM)	 Student Space (9)	
BOBB - R0013 - Practical Activities - 1hb - (19.92 SQM)	 Student Space (9)	
BOBB - R0014 - Home Base - (60.19 SQM) - Teaching Space: 1	 Student Space (27)	
BOBB - R0015 - Withdrawal Space - 2hb - (11.64 SQM)	 Student Space (5)	
BOBB - R0016 - Home Base - (60.17 SQM) - Teaching Space: 1	 Student Space (27)	
BOBB - R0017 - Practical Activities - 1hb - (20.01 SQM)	 Student Space (9)	
BOBB - R0021 - Practical Activities - 1hb - (19.92 SQM)	 Student Space (9)	
BOBB - R0022 - Home Base - (59.55 SQM) - Teaching Space: 1	 Student Space (27)	
BOBB - R0023 - Withdrawal Space - 2hb - (11.61 SQM)	 Student Space (5)	
BOBB - R0024 - Home Base - (60.25 SQM) - Teaching Space: 1	 Student Space (27)	
BOBB - R0025 - Practical Activities - 1hb - (20.09 SQM)	 Student Space (9)	
BOBB - R0026 - Movement - (5.78 SQM)	Not Applicable	Circulation or storage space.
BOCC - R0004 - Special Programs Room - (45.95 SQM)	 Student Space (21)	
BOCC - R0008 - Reading Area - (222.73 SQM)	 Student Space (103)	
BOCC - R0012 - Practical Activities - 1hb - (19.93 SQM)	 Student Space (9)	
BOCC - R0013 - Home Base - (59.45 SQM) - Teaching Space: 1	 Student Space (27)	
BOCC - R0014 - Withdrawal Space - 2hb - (11.57 SQM)	 Student Space (5)	
BOCC - R0015 - Home Base - (60.33 SQM) - Teaching Space: 1	 Student Space (27)	
BOCC - R0016 - Practical Activities - 1hb - (20.11 SQM)	 Student Space (9)	
BODD - R0006 - Practical Activities - 1hb - (20.05 SQM)	 Student Space (9)	
BODD - R0007 - Home Base - (59.5 SQM) - Teaching Space: 1	 Student Space (27)	
BODD - R0008 - Withdrawal Space - 2hb - (11.64 SQM)	 Student Space (5)	
BODD - R0009 - Home Base - (60.39 SQM) - Teaching Space: 1	 Student Space (28)	
BODD - R0010 - Practical Activities - 1hb - (20.06 SQM)	 Student Space (9)	
BODD - R0013 - Practical Activities - 1hb - (20.12 SQM)	Student Space (9)	
BODD - R0014 - Home Base - (60.51 SQM) - Teaching Space: 1	Student Space (28)	

Entity Location	Audit Condition Classification (Capacity)	Comment
BODD - R0015 - Withdrawal Space - 2hb - (11.61 SQM)	● Student Space (5)	
BODD - R0016 - Home Base - (60.33 SQM) - Teaching Space: 1	● Student Space (27)	
BODD - R0017 - Practical Activities - 1hb - (20.02 SQM)	● Student Space (9)	
BODD - R0021 - Practical Activities - 1hb - (20.04 SQM)	● Student Space (9)	
BODD - R0022 - Home Base - (59.69 SQM) - Teaching Space: 1	● Student Space (27)	
BODD - R0023 - Withdrawal Space - 2hb - (11.61 SQM)	● Student Space (5)	
BODD - R0024 - Home Base - (60.4 SQM) - Teaching Space: 1	● Student Space (28)	
BODD - R0025 - Practical Activities - 1hb - (19.9 SQM)	● Student Space (9)	
BODD - R0026 - Movement - (5.76 SQM)	Not Applicable	Circulation or storage space.
BOEE - R0002 - Canteen - (42.35 SQM)	Not Applicable	Circulation or storage space.
BOEE - R0011 - Movement - (27.76 SQM)	Not Applicable	Circulation or storage space.
BOEE - R0012 - Raised Platform - (52.22 SQM)	Not Applicable	Circulation or storage space.
BOEE - R0013 - Movement - (11.37 SQM)	Not Applicable	Circulation or storage space.
BOEE - R0014 - Communal Space - (200.81 SQM)	● Student Space (93)	
BOFF - R0002 - Practical Activities - 1hb - (19.4 SQM)	● Student Space (9)	
BOFF - R0004 - Home Base - (59.2 SQM) - Teaching Space: 1	● Student Space (27)	
BOFF - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	● Student Space (5)	
BOFF - R0006 - Home Base - (59.19 SQM) - Teaching Space: 1	● Student Space (27)	
BOFF - R0008 - Practical Activities - 1hb - (19.41 SQM)	● Student Space (9)	
BOGG - R0002 - Practical Activities - 1hb - (19.18 SQM)	● Student Space (8)	
BOGG - R0004 - Home Base - (60.54 SQM) - Teaching Space: 1	● Student Space (28)	
BOGG - R0005 - Withdrawal Space - 2hb - (11.78 SQM)	● Student Space (5)	
BOGG - R0006 - Home Base - (60.57 SQM) - Teaching Space: 1	● Student Space (28)	
BOGG - R0008 - Practical Activities - 1hb - (18.6 SQM)	● Student Space (8)	
BOGG - R0009 - Practical Activities - 1hb - (19.21 SQM)	● Student Space (8)	
BOGG - R0011 - Home Base - (60.76 SQM) - Teaching Space: 1	● Student Space (28)	
BOGG - R0012 - Withdrawal Space - 2hb - (11.74 SQM)	● Student Space (5)	
BOGG - R0013 - Home Base - (60.55 SQM) - Teaching Space: 1	● Student Space (28)	
BOGG - R0015 - Practical Activities - 1hb - (19.18 SQM)	● Student Space (8)	
OS 602 13786 - OS 602 13786 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 14286 - OS 602 14286 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 19466 - OS 602 19466 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 603 10346 - OS 603 10346 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	
OS 603 14807 - OS 603 14807 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	
OS 751 11293 - OS 751 11293 - Learning Unit - ESL - (76 SQM)	● Student Space (35)	