


VENTILATION AUDIT REPORT

SCHOOL:	Hunter River High School (8219)
AMU REGION:	Hunter/Central Coast
STATE ELECTORATE:	Port Stephens
LOCAL GOVERNMENT AREA:	Port Stephens

8219 - Hunter River High School
Site Plan (11236)



1:2,179

Printed: 14-Sep-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Leading Teacher - (17.84 SQM)	Office (4)	
B00A - R0002 - Administration - Clerical - (9.82 SQM)	Office (2)	
B00A - R0006 - Administration - Clerical - (33.34 SQM)	Office (8)	
B00A - R0007 - Interview/Office - Type 1 - (10.74 SQM)	Office (2)	
B00A - R0008 - Leading Teacher - (10.46 SQM)	Office (2)	
B00A - R0009 - Deputy Principal Office - (13.04 SQM)	Office (3)	
B00A - R0012 - Clinic - Boys - (12.73 SQM)	Office (3)	
B00A - R0017 - Duplicating Workroom - (25.38 SQM)	Office (6)	
B00A - R0021 - Principal Office - (23.32 SQM)	Office (5)	
B00A - R0022 - Movement - (61.79 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Interview/Office - Type 1 - (22.55 SQM)	Office (5)	
B00B - R0005 - General Learning Space - (53.78 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0006 - General Learning Space - (53.77 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0014 - Interview/Office - Type 1 - (25.57 SQM)	Office (6)	
B00B - R0015 - General Learning Space - (54.21 SQM) - Teaching Space: 1	Student Space (25)	
B00B - R0017 - Staff Study - (27 SQM)	Office (6)	
B00C - R0007 - Food/Research Space - (12.8 SQM)	Not Applicable	Circulation or storage space.
B00C - R0008 - Food Technology L.S. - (84.47 SQM) - Teaching Space: 1	Student Space (39)	
B00C - R0012 - Staff Study - (58.02 SQM)	Office (14)	
B00C - R0013 - General Learning Space - Type 1 - (68.83 SQM) - Teaching Space: 1	Student Space (31)	
B00D - R0001 - Design L.S. - (74.43 SQM) - Teaching Space: 1	Student Space (34)	
B00D - R0002 - Materials Technology L.S. - (79.12 SQM) - Teaching Space: 1	Student Space (36)	
B00D - R0009 - Movement - (37.15 SQM)	Not Applicable	Circulation or storage space.
B00D - R0010 - Computer Room - (24.54 SQM)	Student Space (11)	
B00D - R0012 - Design L.S. - (57.96 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0013 - Wood Technology Bay - (109.27 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Commonroom - (152.24 SQM)	Office (38)	
B00E - R0004 - Movement - (26.46 SQM)	Not Applicable	Circulation or storage space.
B00E - R0007 - Staff Study - (24.91 SQM)	Office (6)	
B00E - R0008 - Materials Technology L.S. - (67.5 SQM) - Teaching Space: 1	Student Space (31)	
B00E - R0011 - Staff Study - (26.45 SQM)	Office (6)	
B00E - R0012 - Movement - (33.5 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - General Learning Space - (67.03 SQM) - Teaching Space: 1	Student Space (31)	
B00F - R0002 - General Learning Space - (66.6 SQM) - Teaching Space: 1	Student Space (30)	
B00F - R0003 - Movement - (15.44 SQM)	Not Applicable	Circulation or storage space.
B00F - R0005 - General Learning Space - (66.24 SQM) - Teaching Space: 1	Student Space (30)	
B00F - R0009 - Administration - Clerical - (18.03 SQM)	Office (4)	
B00F - R0012 - Deputy Principal Office - (16.2 SQM)	Office (4)	
B00F - R0013 - Interview/Office - Type 1 - (12.8 SQM)	Office (3)	
B00F - R0014 - Interview/Office - Type 1 - (11.72 SQM)	Office (2)	
B00F - R0015 - Interview/Office - Type 1 - (12.8 SQM)	Office (3)	
B00F - R0016 - Pupil Entry - (21.45 SQM)	Not Applicable	Circulation or storage space.
B00F - R0017 - Movement - (15.61 SQM)	Not Applicable	Circulation or storage space.
B00G - R0004 - Art Learning Space - (60.24 SQM)	Student Space (27)	
B00G - R0005 - Art Learning Space - (59.43 SQM)	Student Space (27)	
B00G - R0008 - Laboratory L.S. - (93.08 SQM) - Teaching Space: 1	Student Space (43)	
B00G - R0010 - Preparation - (17.87 SQM)	Not Applicable	Circulation or storage space.
B00G - R1002 - Staff Study - (26.15 SQM)	Office (6)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R1003 - General Learning Space - (53.19 SQM) - Teaching Space: 1	Student Space (24)	
B00G - R1007 - General Learning Space - (52.82 SQM) - Teaching Space: 1	Student Space (24)	
B00G - R1008 - General Learning Space - (66.63 SQM) - Teaching Space: 1	Student Space (30)	
B00G - R1011 - General Learning Space - (66.31 SQM) - Teaching Space: 1	Student Space (30)	
B00G - R1013 - Movement - (96.55 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Laboratory L.S. - (93.89 SQM) - Teaching Space: 1	Student Space (43)	
B00H - R0008 - Staff Study - (36 SQM)	Office (9)	
B00H - R0014 - Food/Research Space - (42.02 SQM)	Not Applicable	Circulation or storage space.
B00H - R0015 - Food Technology L.S. - (89.2 SQM) - Teaching Space: 1	Student Space (41)	
B00H - R0016 - Preparation - Materials - (21.24 SQM)	Not Applicable	Circulation or storage space.
B00H - R1007 - Computer Learning Space - (52.6 SQM) - Teaching Space: 1	Student Space (24)	
B00H - R1008 - Computer Learning Space - (39.74 SQM) - Teaching Space: 1	Student Space (18)	
B00H - R1011 - General Learning Space - (52.83 SQM) - Teaching Space: 1	Student Space (24)	
B00H - R1015 - General Learning Space - (53.62 SQM) - Teaching Space: 1	Student Space (24)	
B00H - R1018 - Staff Study - (43.33 SQM)	Office (10)	
B00I - R0003 - General Learning Space - (53.34 SQM) - Teaching Space: 1	Student Space (24)	
B00I - R0004 - General Learning Space - (52.82 SQM) - Teaching Space: 1	Student Space (24)	
B00I - R0008 - General Learning Space - (52.97 SQM) - Teaching Space: 1	Student Space (24)	
B00I - R0009 - Art Learning Space - (66.13 SQM) - Teaching Space: 1	Student Space (30)	
B00I - R0010 - General Learning Space - (53.56 SQM) - Teaching Space: 1	Student Space (24)	
B00I - R1002 - Music Learning Space - (52.82 SQM) - Teaching Space: 1	Student Space (24)	
B00I - R1003 - General Learning Space - (52.01 SQM) - Teaching Space: 1	Student Space (24)	
B00I - R1006 - General Learning Space - (52.82 SQM) - Teaching Space: 1	Student Space (24)	
B00I - R1007 - General Learning Space - (52.89 SQM) - Teaching Space: 1	Student Space (24)	
B00I - R1008 - Staff Study - (53.78 SQM)	Office (13)	
B00J - R0001 - General Learning Space - (53.19 SQM) - Teaching Space: 1	Student Space (24)	
B00J - R0005 - General Learning Space - (53.19 SQM) - Teaching Space: 1	Student Space (24)	
B00J - R0006 - Staff Study - (65.74 SQM)	Office (16)	
B00J - R1001 - Seminar - (25.85 SQM)	Office (6)	
B00J - R1005 - Performance Workshop - (25.52 SQM)	Student Space (11)	
B00J - R1008 - Staff Study - (25.89 SQM)	Office (6)	
B00J - R1009 - Movement - (55.39 SQM)	Not Applicable	Circulation or storage space.
B00J - R1013 - Performance Workspace - (105.8 SQM) - Teaching Space: 1	Student Space (49)	
B00K - M1008 - Computer Learning Space - (118.64 SQM) - Teaching Space: 1	Student Space (55)	
B00K - R0001 - Laboratory L.S. - (91.72 SQM) - Teaching Space: 1	Student Space (42)	
B00K - R0003 - Movement - (42.16 SQM)	Not Applicable	Circulation or storage space.
B00K - R0004 - Laboratory L.S. - (92.51 SQM) - Teaching Space: 1	Student Space (42)	
B00K - R0005 - Preparation - (48.11 SQM)	Not Applicable	Circulation or storage space.
B00K - R0006 - Laboratory L.S. - (92.52 SQM) - Teaching Space: 1	Student Space (42)	
B00K - R0009 - Laboratory L.S. - (92.21 SQM) - Teaching Space: 1	Student Space (42)	
B00K - R0010 - Preparation - (47.77 SQM)	Not Applicable	Circulation or storage space.
B00K - R1004 - Main Area - (366.58 SQM)	Not Applicable	Circulation or storage space.
B00K - R1005 - Seminar - (12.67 SQM)	Office (3)	
B00K - R1006 - Seminar - (12.33 SQM)	Office (3)	
B00K - R1009 - Seminar - (12.33 SQM)	Office (3)	
B00K - R1010 - Seminar - (12.66 SQM)	Office (3)	
B00K - R1011 - Audio Visual Workroom - (36.77 SQM)	Student Space (17)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00K - R1013 - Workroom - (47.74 SQM)	Office (11)	
B00M - R0001 - General Learning Space - (46.42 SQM) - Teaching Space: 1	Student Space (21)	
B00M - R0002 - General Learning Space - (54.51 SQM) - Teaching Space: 1	Student Space (25)	
B00M - R0003 - Darkroom Space - (22.55 SQM)	Office (5)	
B00M - R0006 - Performance Workspace - (89.92 SQM) - Teaching Space: 1	Student Space (41)	
B00O - R0006 - Student Canteen - (58.53 SQM)	Not Applicable	Circulation or storage space.
B00O - R0010 - Movement - (343.16 SQM)	Not Applicable	Circulation or storage space.
B00O - R1001 - Movement - (10.54 SQM)	Not Applicable	Circulation or storage space.
B00O - R1006 - Movement - (10.51 SQM)	Not Applicable	Circulation or storage space.
B00P - R0010 - Materials Technology L.S. - (80.66 SQM) - Teaching Space: 1	Student Space (37)	
B00P - R0011 - T.A.S. Outdoor Area - (26.92 SQM)	Not Applicable	Circulation or storage space.
B00P - R0020 - Workshop Area - (33.28 SQM)	Student Space (15)	
B00P - R0021 - Workshop - (143.38 SQM)	Student Space (66)	
B00Q - R0014 - General Learning Space - (55.29 SQM) - Teaching Space: 1	Student Space (25)	
B00Q - R0015 - Staff Kitchen - (10.57 SQM)	Office (2)	
B00Q - R0016 - Staff Kitchen - (13.23 SQM)	Office (3)	
B00Q - R0017 - Staff Study - (12.61 SQM)	Office (3)	
B00R - R0004 - Stage - (87.7 SQM)	Not Applicable	Circulation or storage space.
B00R - R0008 - Multi-Purpose Space - (440.28 SQM)	Student Space (204)	
B00R - R0013 - Entry - (22.83 SQM)	Not Applicable	Circulation or storage space.
B00R - R0015 - Staff Kitchen - (16.02 SQM)	Office (4)	
B00U - R0001 - Entry - (13.8 SQM)	Not Applicable	Circulation or storage space.
B00U - R0005 - Materials Technology L.S. - (43.39 SQM) - Teaching Space: 1	Student Space (20)	
B00U - R0007 - Teachers Aides - (11.09 SQM)	Office (2)	
B00U - R0008 - Workshop Area - (219.49 SQM)	Student Space (101)	
B00U - R0010 - Outdoor Workshop - (106.11 SQM)	Not Applicable	Circulation or storage space.
OS 601 11733 - OS 601 11733 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 13560 - OS 601 13560 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 13990 - OS 601 13990 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 621 19863 - OS 621 19863 - Learning Unit Single - PWD - (SQM)	Student Space ()	
OS 711 10619 - OS 711 10619 - Home Science/Art/Science Dem/Computer - (95 SQM)	Student Space (44)	