

VENTILATION AUDIT REPORT

SCHOOL:	Hunters Hill Public School (2189)
AMU REGION:	Northern Sydney
STATE ELECTORATE:	Lane Cove
LOCAL GOVERNMENT AREA:	Hunters Hill

2189 - Hunters Hill Public School
Site Plan (12659)



1:664

Printed: 20-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Practical Activities - 1hb - (17.04 SQM)	● Student Space (7)	
B00A - R0002 - Home Base - (48.52 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R0003 - Home Base - (58.88 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R0006 - Home Base - (52.95 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0010 - Staff Room Annexe - (13.4 SQM)	● Office (3)	
B00D - R0001 - Entry Vestibule - (17.05 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Reading Area - (76.56 SQM)	● Student Space (35)	
B00D - R0004 - Reading Area - (42.85 SQM)	● Student Space (19)	
B00D - R0005 - Reading Area - (39.59 SQM)	● Student Space (18)	
B00D - R0006 - Reading Area - (39.51 SQM)	● Student Space (18)	
B00D - R1001 - Home Base - (77.05 SQM) - Teaching Space: 1	● Student Space (35)	
B00D - R1002 - Home Base - (76.98 SQM) - Teaching Space: 1	● Student Space (35)	
B00D - R1003 - Practical Activities - 1hb - (26.67 SQM)	● Student Space (12)	
B00D - R1004 - Practical Activities - 1hb - (26.52 SQM)	● Student Space (12)	
B00D - R1005 - Withdrawal Space - 2hb - (12.87 SQM)	● Student Space (5)	
B00E - R0003 - Duplicating Workroom - (20.34 SQM)	● Office (5)	
B00E - R0004 - Principal - (19.79 SQM)	● Office (4)	
B00E - R0006 - Entry Vestibule - (8.54 SQM)	Not Applicable	Circulation or storage space.
B00E - R0007 - Clerical Office - (12.81 SQM)	● Office (3)	
B00E - R0008 - Deputy Principal - (15.49 SQM)	● Office (3)	
B00E - R0025 - Staff Kitchen - (15.21 SQM)	● Office (3)	
B00E - R0026 - Staff Room - (42.23 SQM)	● Office (10)	
B00E - R0027 - Movement - (78.02 SQM)	Not Applicable	Circulation or storage space.
B00E - R0028 - Sick Bay - (8.66 SQM)	● Student Space (4)	
B00E - R0029 - Movement - (24.92 SQM)	Not Applicable	Circulation or storage space.
B00E - R0030 - Clerical Office - (6.21 SQM)	● Office (1)	
B00E - R1001 - Home Base - (60.18 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R1004 - Home Base - (60.35 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R1006 - Home Base - (62.53 SQM) - Teaching Space: 1	● Student Space (29)	
B00E - R1009 - Home Base - (62.45 SQM) - Teaching Space: 1	● Student Space (28)	
B00E - R1014 - Movement - (86.82 SQM)	Not Applicable	Circulation or storage space.
B00F - R0005 - Movement - (10.5 SQM)	Not Applicable	Circulation or storage space.
B00F - R0009 - Withdrawal Space - 1hb - (13.52 SQM)	● Student Space (6)	
B00F - R0010 - Home Base - (51.89 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R0001 - Home Base - (61.91 SQM) - Teaching Space: 1	● Student Space (28)	
B00G - R0002 - Practical Activities - 1hb - (25.38 SQM)	● Student Space (11)	
B00G - R0005 - Movement - (13.47 SQM)	Not Applicable	Circulation or storage space.
B00G - R0012 - Canteen - (27 SQM)	Not Applicable	Circulation or storage space.
B00G - R0013 - Movement - (53.11 SQM)	Not Applicable	Circulation or storage space.
B00G - R0014 - Movement - (78.36 SQM)	Not Applicable	Circulation or storage space.
B00G - R1001 - Practical Activities - 1hb - (24.17 SQM)	● Student Space (11)	
B00G - R1002 - Movement - (19.82 SQM)	Not Applicable	Circulation or storage space.
B00G - R1003 - Home Base - (46.07 SQM) - Teaching Space: 1	● Student Space (21)	
B00G - R1004 - Withdrawal Space - 1hb - (8.85 SQM)	● Student Space (4)	
B00G - R1005 - Movement - (68.39 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Communal Space - (144.24 SQM)	● Student Space (66)	
B00H - R0006 - Raised Platform - (49.32 SQM)	Not Applicable	Circulation or storage space.
B00H - R0007 - Movement - (6.38 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00H - R0008 - Movement - (39.96 SQM)	Not Applicable	Circulation or storage space.
B00H - R0009 - Movement - (8.58 SQM)	Not Applicable	Circulation or storage space.
B00I - R0001 - Home Base - (61.11 SQM) - Teaching Space: 1	● Student Space (28)	
B00I - R0002 - Home Base - (60.96 SQM) - Teaching Space: 1	● Student Space (28)	
B00I - R0003 - Practical Activities - 1hb - (19.07 SQM)	● Student Space (8)	
B00I - R0004 - Practical Activities - 1hb - (19.07 SQM)	● Student Space (8)	
B00I - R0005 - Withdrawal Space - 2hb - (11.65 SQM)	● Student Space (5)	
B00I - R1001 - Home Base - (60.76 SQM) - Teaching Space: 1	● Student Space (28)	
B00I - R1002 - Home Base - (60.85 SQM) - Teaching Space: 1	● Student Space (28)	
B00I - R1003 - Practical Activities - 1hb - (18.99 SQM)	● Student Space (8)	
B00I - R1004 - Practical Activities - 1hb - (19.1 SQM)	● Student Space (8)	
B00I - R1005 - Withdrawal Space - 2hb - (11.58 SQM)	● Student Space (5)	