


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Ingleburn High School (8262)</b>
<b>AMU REGION:</b>	<b>South Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Macquarie Fields</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Campbelltown</b>

8262 - Ingleburn High School  
Site Plan (10758)



1:1,910

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - General Learning Space - (54.69 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R0003 - General Learning Space - (54.69 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R0004 - General Learning Space - (55.59 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R0005 - Interview/Office - Type 1 - (13.32 SQM)	Office (3)	
B00A - R0007 - General Learning Space - (54.76 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R0008 - General Learning Space - (54.62 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R0009 - General Learning Space - (54.76 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R0014 - General Learning Space - (54.76 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R0016 - Staff Study - (54.76 SQM)	Office (13)	
B00A - R0019 - General Learning Space - (54.76 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R0020 - General Learning Space - (53.86 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0021 - General Learning Space - (54.21 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R0022 - General Learning Space - (54.69 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R0027 - Leading Teacher - (13.54 SQM)	Office (3)	
B00A - R0029 - Performance Workshop - (27.08 SQM)	Student Space (12)	
B00A - R0030 - General Learning Space - (54.69 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R0036 - Computer Learning Space - (54.92 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R0041 - Student Waiting - (13.33 SQM)	Not Applicable	Circulation or storage space.
B00A - R0042 - Movement - (287.3 SQM)	Not Applicable	Circulation or storage space.
B00A - R0043 - General Learning Space - (54.76 SQM) - Teaching Space: 1	Student Space (25)	
B00B - R0021 - Staff Study - (27.61 SQM)	Office (6)	
B00B - R0024 - General Learning Space - (54.84 SQM) - Teaching Space: 1	Student Space (25)	
B00B - R0031 - Computer Learning Space - (55.14 SQM) - Teaching Space: 1	Student Space (25)	
B00B - R0034 - Art Learning Space - (62.07 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R0035 - Workshop - (51.03 SQM)	Student Space (23)	
B00B - R0037 - Art Learning Space - (61.31 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R0038 - General Learning Space - (57.18 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0046 - General Learning Space - (54.31 SQM) - Teaching Space: 1	Student Space (25)	
B00B - R0047 - General Learning Space - (54.09 SQM) - Teaching Space: 1	Student Space (25)	
B00B - R0049 - Music Learning Space - (59.62 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0051 - Music Learning Space - (78.32 SQM) - Teaching Space: 1	Student Space (36)	
B00B - R0059 - General Learning Space - (54.61 SQM) - Teaching Space: 1	Student Space (25)	
B00B - R0063 - Dark Room - (24.14 SQM)	Office (6)	
B00B - R0064 - Staff Study - (43.05 SQM)	Office (10)	
B00B - R0066 - Commonroom - (82.38 SQM)	Office (20)	
B00B - R0067 - Staff Kitchen - (6.29 SQM)	Office (1)	
B00B - R0068 - Movement - (286.47 SQM)	Not Applicable	Circulation or storage space.
B00B - R0070 - Staff Study - (50.06 SQM)	Office (12)	
B00C - R0001 - Staff Study - (27.16 SQM)	Office (6)	
B00C - R0002 - Food Technology L.S. - (68.62 SQM) - Teaching Space: 1	Student Space (31)	
B00C - R0003 - Food/Research Space - (54.54 SQM)	Not Applicable	Circulation or storage space.
B00C - R0005 - Preparation - Materials - (20.54 SQM)	Not Applicable	Circulation or storage space.
B00C - R0006 - Food Technology L.S. - (68.41 SQM) - Teaching Space: 1	Student Space (31)	
B00C - R0026 - Laboratory L.S. - (96.66 SQM) - Teaching Space: 1	Student Space (44)	
B00C - R0027 - Preparation - Science - (26.97 SQM)	Not Applicable	Circulation or storage space.
B00C - R0029 - Laboratory L.S. - (96.29 SQM) - Teaching Space: 1	Student Space (44)	
B00C - R0032 - Preparation - Science - (25.58 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R0033 - Laboratory L.S. - (82.67 SQM) - Teaching Space: 1	● Student Space (38)	
B00C - R0036 - Design L.S. - (72.95 SQM) - Teaching Space: 1	● Student Space (33)	
B00C - R0041 - Laboratory L.S. - (95.02 SQM) - Teaching Space: 1	● Student Space (44)	
B00C - R0043 - Laboratory L.S. - (94.79 SQM) - Teaching Space: 1	● Student Space (43)	
B00C - R0044 - Staff Study - (40.04 SQM)	● Office (10)	
B00C - R0053 - Movement - (278.96 SQM)	Not Applicable	Circulation or storage space.
B00C - R1001 - General Learning Space - (54.1 SQM) - Teaching Space: 1	● Student Space (25)	
B00C - R1002 - General Learning Space - (53.8 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1003 - Computer Learning Space - (54.17 SQM) - Teaching Space: 1	● Student Space (25)	
B00C - R1008 - General Learning Space - (54.1 SQM) - Teaching Space: 1	● Student Space (25)	
B00C - R1009 - Movement - (61.1 SQM)	Not Applicable	Circulation or storage space.
B00C - R1012 - Staff Study - (36.52 SQM)	● Office (9)	
B00D - R0007 - Tea Room - (18.96 SQM)	Not Applicable	Circulation or storage space.
B00D - R0009 - Movement - (128.1 SQM)	Not Applicable	Circulation or storage space.
B00D - R0011 - General Learning Space - (62.72 SQM) - Teaching Space: 1	● Student Space (29)	
B00D - R0016 - Design L.S. - (55.51 SQM) - Teaching Space: 1	● Student Space (25)	
B00D - R0017 - Computer Learning Space - (62.33 SQM) - Teaching Space: 1	● Student Space (28)	
B00D - R0018 - Staff Study - (27.4 SQM)	● Office (6)	
B00D - R0020 - Wood Technology L.S. - (77.54 SQM) - Teaching Space: 1	● Student Space (35)	
B00D - R0021 - Wood Technology Bay - (41.12 SQM)	Not Applicable	Circulation or storage space.
B00D - R0022 - Materials Technology L.S. - (77.54 SQM) - Teaching Space: 1	● Student Space (35)	
B00D - R0024 - Student Canteen - (49.47 SQM)	Not Applicable	Circulation or storage space.
B00D - R0029 - General Assistants - (20.6 SQM)	● Office (5)	
B00D - R0033 - Metal Technology Bay - (29.46 SQM)	Not Applicable	Circulation or storage space.
B00E - R0005 - Administration - Clerical - (13.24 SQM)	● Office (3)	
B00E - R0010 - Staff Room Annexe - (12.82 SQM)	● Office (3)	
B00E - R0011 - Principal - (17.83 SQM)	● Office (4)	
B00E - R0017 - Clinic - (6.22 SQM)	● Office (1)	
B00E - R0018 - Ancillary Staff - (17.48 SQM)	● Office (4)	
B00E - R0019 - Administration - Clerical - (33.59 SQM)	● Office (8)	
B00E - R0024 - Movement - (6.4 SQM)	Not Applicable	Circulation or storage space.
B00E - R0027 - Student Waiting - (13.14 SQM)	Not Applicable	Circulation or storage space.
B00E - R0031 - Deputy Principal Office - (10.44 SQM)	● Office (2)	
B00E - R0032 - Deputy Principal Office - (12.77 SQM)	● Office (3)	
B00E - R0034 - Public Reception - (10.46 SQM)	Not Applicable	Circulation or storage space.
B00E - R0035 - Student Reception - (16.4 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Audio Visual Workroom - (14.7 SQM)	● Student Space (6)	
B00G - R0004 - Main Entry - (11.86 SQM)	Not Applicable	Circulation or storage space.
B00G - R0006 - Tea Room - (14.69 SQM)	Not Applicable	Circulation or storage space.
B00G - R0009 - Tiered Learning Area - (11.71 SQM)	● Student Space (5)	
B00G - R0010 - Movement - (28.2 SQM)	Not Applicable	Circulation or storage space.
B00G - R0011 - Multi Media Workshop - (60.8 SQM)	Not Applicable	Circulation or storage space.
B00G - R0020 - Seminar - (15.4 SQM)	● Office (3)	
B00G - R0021 - Seminar - (15.17 SQM)	● Office (3)	
B00G - R0022 - Main Area - (143.22 SQM)	Not Applicable	Circulation or storage space.
B00G - R1005 - Senior Study - (31.57 SQM)	● Office (7)	
B00G - R1006 - Staff Study - (15.22 SQM)	● Office (3)	
B00G - R1008 - Movement - (22.32 SQM)	Not Applicable	Circulation or storage space.
B00G - R1011 - Computer Learning Space - (106.5 SQM) - Teaching Space: 1	● Student Space (49)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R1012 - Main Area - (68.62 SQM)	Not Applicable	Circulation or storage space.
B00H - R0007 - Stage - (68.32 SQM)	Not Applicable	Circulation or storage space.
B00H - R0012 - Staff Kitchen - (14.8 SQM)	Office (3)	
B00H - R0023 - Tea Room - (9.7 SQM)	Not Applicable	Circulation or storage space.
B00H - R0024 - Staff Study - (24.43 SQM)	Office (6)	
B00H - R0025 - Multi-Purpose Space - (484.75 SQM)	Student Space (224)	
B00H - R0026 - Movement - (15.91 SQM)	Not Applicable	Circulation or storage space.
B00H - R0027 - Movement - (15.81 SQM)	Not Applicable	Circulation or storage space.
B00H - R0028 - Movement - (5.62 SQM)	Not Applicable	Circulation or storage space.
B00I - R0001 - Gymnasium - (132.32 SQM)	Student Space (61)	
B00J - R0004 - General Learning Space - (58.47 SQM) - Teaching Space: 1	Student Space (27)	
B00J - R0005 - General Learning Space - (58.47 SQM) - Teaching Space: 1	Student Space (27)	
B00J - R0006 - Seminar - Type 1 - (25.57 SQM)	Office (6)	
B00J - R0007 - General Learning Space - (58.47 SQM) - Teaching Space: 1	Student Space (27)	
B00J - R0008 - General Learning Space - (58.47 SQM) - Teaching Space: 1	Student Space (27)	
B00J - R0009 - Seminar - Type 1 - (9.8 SQM)	Office (2)	
B00J - R0010 - Movement - (6.69 SQM)	Not Applicable	Circulation or storage space.
B00J - R0011 - Practical Activities Area - 2 G.L.S. - (9.65 SQM)	Student Space (4)	
B00J - R0015 - Practical Activities Area - 2 G.L.S. - (6.6 SQM)	Student Space (3)	
B00J - R0016 - Movement - (52.73 SQM)	Not Applicable	Circulation or storage space.
B00J - R0017 - Seminar - Type 1 - (11.56 SQM)	Office (2)	
B00J - R0018 - General Learning Space - (59.38 SQM) - Teaching Space: 1	Student Space (27)	
B00J - R0019 - General Learning Space - (59.37 SQM) - Teaching Space: 1	Student Space (27)	
B00J - R0020 - General Learning Space - (59.38 SQM) - Teaching Space: 1	Student Space (27)	
B00J - R0021 - Seminar - Type 1 - (24.15 SQM)	Office (6)	
B00J - R0022 - General Learning Space - (58.54 SQM) - Teaching Space: 1	Student Space (27)	
B00J - R0023 - Performance Workshop - (94.92 SQM)	Student Space (44)	
B00J - R0024 - General Learning Space - (58.47 SQM) - Teaching Space: 1	Student Space (27)	
B00J - R0028 - Outdoor Learning Area - (234.41 SQM)	Not Applicable	Circulation or storage space.
B00J - R0031 - Movement - (59.5 SQM)	Not Applicable	Circulation or storage space.
B00J - R0032 - Practical Activities Area - 2 G.L.S. - (6.36 SQM)	Student Space (2)	
OS 601 11723 - OS 601 11723 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 14200 - OS 601 14200 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 621 13002 - OS 621 13002 - Learning Unit Single - PWD - (95 SQM)	Student Space (44)	
OS 700 12166 - OS 700 12166 - Art Learning Space/Workshop/Store - (114 SQM)	Not Applicable	Circulation or storage space.