

VENTILATION AUDIT REPORT

SCHOOL:	Ingleburn Public School (2206)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Macquarie Fields
LOCAL GOVERNMENT AREA:	Campbelltown

2206 - Ingleburn Public School
Site Plan (11017)



1:1,114

Printed: 15-Dec-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Staff Room - (45.13 SQM)	Office (11)	
B00A - R0003 - Staff Room Annexe - (45.51 SQM)	Office (11)	
B00A - R0005 - Movement - (35.12 SQM)	Not Applicable	Circulation or storage space.
B00A - R0008 - Special Programs Room - (47.46 SQM)	Student Space (22)	
B00A - R0009 - Movement - (16.21 SQM)	Not Applicable	Circulation or storage space.
B00B - M0003 - Movement - (7.12 SQM)	Not Applicable	Circulation or storage space.
B00B - M0004 - Movement - (7.06 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Movement - (103.62 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Movement - (9.33 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Home Base - (57.02 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0008 - Home Base - (57.1 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0013 - Home Base - (57.02 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0014 - Staff Room Annexe - (28.04 SQM)	Office (7)	
B00B - R0015 - Movement - (6.84 SQM)	Not Applicable	Circulation or storage space.
B00B - R0017 - Home Base - (57.03 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0023 - Home Base - (57.03 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0024 - Practical Activities - (9.7 SQM)	Student Space (4)	
B00B - R0026 - Practical Activities/Movement - 2hb - (13.13 SQM)	Student Space (6)	
B00B - R1001 - Movement - (119.23 SQM)	Not Applicable	Circulation or storage space.
B00B - R1005 - Home Base - (57.1 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R1006 - Home Base - (57.03 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R1011 - Home Base - (56.95 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R1012 - Deputy Principal - (28.04 SQM)	Office (7)	
B00B - R1014 - Home Base - (56.94 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R1018 - Home Base - (57.33 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R1019 - Practical Activities - (9.4 SQM)	Student Space (4)	
B00C - R0001 - Movement - (69.66 SQM)	Not Applicable	Circulation or storage space.
B00C - R0005 - Home Base - (57.05 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0008 - Home Base - (56.55 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0011 - Home Base - (57.04 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0014 - Home Base - (56.91 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0015 - Practical Activities - (9.5 SQM)	Student Space (4)	
B00D - R0004 - Home Base - E - (89.05 SQM) - Teaching Space: 1	Student Space (41)	
B00D - R0005 - Home Base - E - (88.97 SQM) - Teaching Space: 1	Student Space (41)	
B00D - R0012 - Home Base - E - (89.27 SQM) - Teaching Space: 1	Student Space (41)	
B00D - R0019 - Movement - (196.16 SQM)	Not Applicable	Circulation or storage space.
B00D - R0020 - Movement - (93.07 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Principal - (16.99 SQM)	Office (4)	
B00F - R0002 - Interview - (14.93 SQM)	Office (3)	
B00F - R0003 - Entry Vestibule - (13.02 SQM)	Not Applicable	Circulation or storage space.
B00F - R0004 - Movement - (25.63 SQM)	Not Applicable	Circulation or storage space.
B00F - R0006 - Sick Bay - (10.52 SQM)	Student Space (4)	
B00F - R0008 - Duplicating Workroom - (32.7 SQM)	Office (8)	
B00F - R0011 - Movement - (8.37 SQM)	Not Applicable	Circulation or storage space.
B00F - R0012 - Movement - (18.69 SQM)	Not Applicable	Circulation or storage space.
B00F - R0014 - Clerical Office - (11.63 SQM)	Office (2)	
B00F - R0015 - Clerical Office/Workroom - (14.09 SQM)	Office (3)	
B00F - R0016 - Deputy Principal - (14.53 SQM)	Office (3)	
B00F - R0017 - Movement - (13.1 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R0019 - Movement - (5.13 SQM)	Not Applicable	Circulation or storage space.
B00F - R0020 - Movement - (16.61 SQM)	Not Applicable	Circulation or storage space.
B00I - R0003 - Movement - (22.45 SQM)	Not Applicable	Circulation or storage space.
B00J - R0001 - Reading Area - (8.44 SQM)	● Student Space (3)	
B00J - R0002 - Reading Area - (8.41 SQM)	● Student Space (3)	
B00K - R0004 - Communal Space - (36.03 SQM)	● Student Space (16)	
B00K - R0008 - Canteen - (42.82 SQM)	Not Applicable	Circulation or storage space.
B00K - R0010 - Communal Space - (220.65 SQM)	● Student Space (102)	
B00K - R0015 - Movement - (24.3 SQM)	Not Applicable	Circulation or storage space.
B00K - R0016 - Movement - (42.82 SQM)	Not Applicable	Circulation or storage space.
B00L - R0006 - Special Programs Room - (42.12 SQM)	● Student Space (19)	
B00L - R0007 - Movement - (29.25 SQM)	Not Applicable	Circulation or storage space.
B00L - R0010 - Reading Area - (224.66 SQM)	● Student Space (104)	
B00L - R0011 - Movement - (91.56 SQM)	Not Applicable	Circulation or storage space.
B00M - R0002 - Home Base - (51.55 SQM) - Teaching Space: 1	● Student Space (23)	
B00M - R0003 - Practical Activities - 1hb - (24.67 SQM)	● Student Space (11)	
B00M - R0005 - Withdrawal Space - 1hb - (11.8 SQM)	● Student Space (5)	
B00M - R0006 - Home Base - (51.74 SQM) - Teaching Space: 1	● Student Space (24)	
B00M - R0007 - Practical Activities - 1hb - (25.96 SQM)	● Student Space (12)	
B00M - R0009 - Movement - (52.65 SQM)	Not Applicable	Circulation or storage space.
B00M - R0010 - Movement - (11.04 SQM)	Not Applicable	Circulation or storage space.
B00M - R0011 - Movement - (10.8 SQM)	Not Applicable	Circulation or storage space.
B00M - R1001 - Movement - (65.56 SQM)	Not Applicable	Circulation or storage space.
B00M - R1002 - Home Base - (49.9 SQM) - Teaching Space: 1	● Student Space (23)	
B00M - R1003 - Practical Activities - 1hb - (28.57 SQM)	● Student Space (13)	
B00M - R1005 - Withdrawal Space - 1hb - (11.42 SQM)	● Student Space (5)	
B00M - R1006 - Home Base - (49.85 SQM) - Teaching Space: 1	● Student Space (23)	
B00M - R1007 - Practical Activities - 1hb - (28.64 SQM)	● Student Space (13)	
B0E2 - R0002 - Home Base - (53.72 SQM) - Teaching Space: 1	● Student Space (24)	
B0E2 - R0003 - Home Base - (53.81 SQM) - Teaching Space: 1	● Student Space (24)	
B0E2 - R0004 - Home Base - (53.73 SQM) - Teaching Space: 1	● Student Space (24)	
B0E2 - R0006 - Movement - (13.19 SQM)	Not Applicable	Circulation or storage space.
B0E2 - R0009 - Special Programs Room - (16.16 SQM)	● Student Space (7)	
B0E2 - R0010 - Withdrawal Space - 1hb - (17.54 SQM)	● Student Space (8)	
B0E2 - R0011 - Movement - (50.42 SQM)	Not Applicable	Circulation or storage space.
B0E2 - R0012 - Withdrawal - M - (20.09 SQM)	● Student Space (9)	
OS 602 13753 - OS 602 13753 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 16638 - OS 602 16638 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	