

VENTILATION AUDIT REPORT

SCHOOL:	Inner Sydney High School (8913)
AMU REGION:	Sydney
STATE ELECTORATE:	Newtown
LOCAL GOVERNMENT AREA:	Sydney

8913 - Inner Sydney High School
Site Plan (10935)



1:427

Printed: 30-Jan-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B1 - 1.1 - Movement - (140.23 SQM)	Not Applicable	Circulation or storage space.
B1 - 1.10 - Seminar - (32.08 SQM)	Office (8)	
B1 - 1.11 - Administration - Clerical - (20.26 SQM)	Office (5)	
B1 - 1.14 - Independent Learning Space - (16.96 SQM) - Teaching Space: 1	Student Space (7)	
B1 - 1.15 - General Learning Space - (41.52 SQM) - Teaching Space: 1	Student Space (19)	
B1 - 1.3 - Science Laboratory - (113.06 SQM)	Student Space (52)	
B1 - 1.5 - General Learning Space - (47.86 SQM) - Teaching Space: 1	Student Space (22)	
B1 - 1.7 - General Learning Space - (51.2 SQM) - Teaching Space: 1	Student Space (23)	
B1 - 1.8 - General Learning Space - (54.26 SQM) - Teaching Space: 1	Student Space (25)	
B1 - 1.9 - Preparation - (17.47 SQM)	Not Applicable	Circulation or storage space.
B1 - G.1 - Movement - (143.1 SQM)	Not Applicable	Circulation or storage space.
B1 - G.13 - Independent Learning Space - (15.42 SQM) - Teaching Space: 1	Student Space (7)	
B1 - G.2 - Science Laboratory - (136.47 SQM)	Student Space (63)	
B1 - G.3 - General Learning Space - (41.59 SQM) - Teaching Space: 1	Student Space (19)	
B1 - G.4 - General Learning Space - (48.24 SQM) - Teaching Space: 1	Student Space (22)	
B1 - G.5 - Interview/Meeting - (11.23 SQM)	Office (2)	
B1 - G.6 - General Learning Space - (50.72 SQM) - Teaching Space: 1	Student Space (23)	
B1 - G.7 - General Learning Space - (55.05 SQM) - Teaching Space: 1	Student Space (25)	
B1 - G.9 - Seminar - (31.44 SQM)	Office (7)	
B1 - LG1.14 - Movement - (17.29 SQM)	Not Applicable	Circulation or storage space.
B1 - LG1.15 - Movement - (30.29 SQM)	Not Applicable	Circulation or storage space.
B1 - LG1.3 - Movement - (9.55 SQM)	Not Applicable	Circulation or storage space.
B1 - LG1.4 - Movement - (16.87 SQM)	Not Applicable	Circulation or storage space.
B2 - 1.1 - Staff Study - (75.77 SQM)	Office (18)	
B2 - 1.10 - Interview/Meeting - (15.01 SQM)	Office (3)	
B2 - 1.2 - Interview/Meeting - (10.49 SQM)	Office (2)	
B2 - 1.4 - Interview/Meeting - (7.92 SQM)	Office (1)	
B2 - 1.5 - Staff Kitchen - (19.15 SQM)	Office (4)	
B2 - 1.6 - Administration - Executive - (26.28 SQM)	Office (6)	
B2 - 1.7 - Interview/Meeting - (9.27 SQM)	Office (2)	
B2 - 1.8 - Principal Office - (12.1 SQM)	Office (3)	
B2 - 1.9 - Movement - (81.02 SQM)	Not Applicable	Circulation or storage space.
B2 - G.1 - Staff Study - (71.81 SQM)	Office (17)	
B2 - G.10 - Interview/Meeting - (11.72 SQM)	Office (2)	
B2 - G.11 - Clinic - (14.3 SQM)	Office (3)	
B2 - G.12 - Clinic - (14.14 SQM)	Office (3)	
B2 - G.13 - Public Reception - (31.23 SQM)	Not Applicable	Circulation or storage space.
B2 - G.14 - Student Waiting - (13.37 SQM)	Not Applicable	Circulation or storage space.
B2 - G.19 - Movement - (77.15 SQM)	Not Applicable	Circulation or storage space.
B2 - G.2 - Movement - (10.81 SQM)	Not Applicable	Circulation or storage space.
B2 - G.24 - Staff Kitchen - (11.44 SQM)	Office (2)	
B2 - G.27 - Movement - (6.51 SQM)	Not Applicable	Circulation or storage space.
B2 - G.5 - Multi-Purpose Space - (123.22 SQM)	Student Space (57)	
B2 - G.8 - Administration - Clerical - (19.6 SQM)	Office (4)	
B2 - LG1.11 - Fitness Laboratory - (160.15 SQM)	Student Space (74)	
B2 - LG1.14 - Movement - (15.42 SQM)	Not Applicable	Circulation or storage space.
B2 - LG1.15 - Movement - (10.18 SQM)	Not Applicable	Circulation or storage space.
B2 - LG1.17 - Movement - (13.16 SQM)	Not Applicable	Circulation or storage space.
B2 - LG1.6 - Movement - (27.85 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B3 - 1.2 - Movement - (51.28 SQM)	Not Applicable	Circulation or storage space.
B3 - 1.3 - General Learning Space - (47.42 SQM) - Teaching Space: 1	● Student Space (22)	
B3 - 1.4 - Practical Activities - (46.84 SQM)	● Student Space (21)	
B3 - G.2 - Movement - (42.54 SQM)	Not Applicable	Circulation or storage space.
B3 - G.3 - General Learning Space - (80.2 SQM) - Teaching Space: 1	● Student Space (37)	
B3 - G.4 - Practice/Seminar - (15.21 SQM)	Not Applicable	Circulation or storage space.
B3 - G.5 - Practice/Seminar - (14.27 SQM)	Not Applicable	Circulation or storage space.
B3 - LG1.1 - Music Learning Space - (49.4 SQM) - Teaching Space: 1	● Student Space (22)	
B3 - LG1.2 - Movement - (74.91 SQM)	Not Applicable	Circulation or storage space.
B3 - LG1.4 - Performance Workspace - (76.14 SQM) - Teaching Space: 1	● Student Space (35)	
B3 - LG1.8 - Practical Activities - (89.12 SQM)	● Student Space (41)	
B3 - LG1.9 - Movement - (8.62 SQM)	Not Applicable	Circulation or storage space.
B4 - 1.3 - Student Canteen - (44.09 SQM)	Not Applicable	Circulation or storage space.
B4 - 10.1 - Interview/Meeting - (11.03 SQM)	○ Office (2)	
B4 - 10.10 - General Learning Space - (111.83 SQM) - Teaching Space: 1	● Student Space (51)	
B4 - 10.11 - Staff Study - (31.02 SQM)	○ Office (7)	
B4 - 10.12 - Staff Study - (20.31 SQM)	○ Office (5)	
B4 - 10.19 - Movement - (142.69 SQM)	Not Applicable	Circulation or storage space.
B4 - 10.22 - Movement - (10.94 SQM)	Not Applicable	Circulation or storage space.
B4 - 10.23 - Movement - (10.86 SQM)	Not Applicable	Circulation or storage space.
B4 - 10.24 - Practical Activities - (11.04 SQM)	● Student Space (5)	
B4 - 10.3 - Seminar - (21.96 SQM)	○ Office (5)	
B4 - 10.5 - Preparation - Science - (48.5 SQM)	Not Applicable	Circulation or storage space.
B4 - 10.6 - Science Laboratory - (95.09 SQM)	● Student Space (44)	
B4 - 10.7 - General Learning Space - Type 10 - (55.84 SQM) - Teaching Space: 0.5	● Student Space (25)	
B4 - 10.8 - General Learning Space - Type 10 - (45.67 SQM) - Teaching Space: 0.5	● Student Space (21)	
B4 - 10.9 - Practical Activities Area - 2 G.L.S. - (58.53 SQM)	● Student Space (27)	
B4 - 11.1 - Interview/Meeting - (11.5 SQM)	○ Office (2)	
B4 - 11.10 - Shared Learning Space - (95.02 SQM)	● Student Space (44)	
B4 - 11.11 - Staff Study - (31.02 SQM)	○ Office (7)	
B4 - 11.18 - Movement - (142.69 SQM)	Not Applicable	Circulation or storage space.
B4 - 11.20 - Movement - (10.94 SQM)	Not Applicable	Circulation or storage space.
B4 - 11.23 - Movement - (10.86 SQM)	Not Applicable	Circulation or storage space.
B4 - 11.26 - Movement - (9.19 SQM)	Not Applicable	Circulation or storage space.
B4 - 11.3 - Seminar - (21.96 SQM)	○ Office (5)	
B4 - 11.5 - Outdoor Learning Area - (76.68 SQM)	Not Applicable	Circulation or storage space.
B4 - 11.6 - Science Laboratory - (95.09 SQM)	● Student Space (44)	
B4 - 11.7 - General Learning Space - (55.84 SQM) - Teaching Space: 1	● Student Space (25)	
B4 - 11.8 - General Learning Space - (56.93 SQM) - Teaching Space: 1	● Student Space (26)	
B4 - 11.9 - Practical Activities - (58.53 SQM)	● Student Space (27)	
B4 - 12.4 - Movement - (91.64 SQM)	Not Applicable	Circulation or storage space.
B4 - 2.1 - Interview/Meeting - (21.68 SQM)	○ Office (5)	
B4 - 2.10 - Metal Technology Bay - (97.06 SQM)	Not Applicable	Circulation or storage space.
B4 - 2.11 - Multi Media Studio - (57.79 SQM)	Not Applicable	Circulation or storage space.
B4 - 2.12 - General Learning Space - (58.25 SQM) - Teaching Space: 1	● Student Space (27)	
B4 - 2.13 - General Learning Space - (56.24 SQM) - Teaching Space: 1	● Student Space (26)	
B4 - 2.14 - General Learning Space - (55.19 SQM) - Teaching Space: 1	● Student Space (25)	
B4 - 2.15 - General Learning Space - Type 14 - (34.91 SQM) - Teaching Space: 1	● Student Space (16)	
B4 - 2.16 - General Learning Space - Type 14 - (83.7 SQM) - Teaching Space: 1	● Student Space (38)	
B4 - 2.17 - Staff Study - (11.69 SQM)	○ Office (2)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B4 - 2.18 - Interview/Meeting - (9.22 SQM)	Office (2)	
B4 - 2.19 - Interview/Meeting - (11.26 SQM)	Office (2)	
B4 - 2.20 - Staff Study - (16.52 SQM)	Office (4)	
B4 - 2.21 - Materials Learning Space - Type 1 - (18.19 SQM) - Teaching Space: 1	Student Space (8)	
B4 - 2.22 - Movement - (11.92 SQM)	Not Applicable	Circulation or storage space.
B4 - 2.3 - Materials Workshop - Type 2 - (6.96 SQM)	Student Space (3)	
B4 - 2.30 - Movement - (232.6 SQM)	Not Applicable	Circulation or storage space.
B4 - 2.41 - Practical Activities - (5.58 SQM)	Student Space (2)	
B4 - 2.42 - Tiered Learning Area - (15.54 SQM)	Student Space (7)	
B4 - 2.6 - Wood Technology Bay - (121.8 SQM)	Not Applicable	Circulation or storage space.
B4 - 3.1 - Interview/Meeting - (29.61 SQM)	Office (7)	
B4 - 3.10 - Senior Learning Centre - (83.4 SQM)	Student Space (38)	
B4 - 3.11 - Multi Media Studio - (63.85 SQM)	Not Applicable	Circulation or storage space.
B4 - 3.12 - Practical Activities - (62.2 SQM)	Student Space (28)	
B4 - 3.13 - General Learning Space - (55.88 SQM) - Teaching Space: 1	Student Space (25)	
B4 - 3.14 - General Learning Space - (55.61 SQM) - Teaching Space: 1	Student Space (25)	
B4 - 3.15 - Tiered Learning Area - (34.6 SQM)	Student Space (16)	
B4 - 3.16 - Shared Learning Space - (70.27 SQM)	Student Space (32)	
B4 - 3.17 - Interview/Meeting - (8.61 SQM)	Office (2)	
B4 - 3.18 - Interview/Meeting - (11.45 SQM)	Office (2)	
B4 - 3.19 - Staff Study - (16.88 SQM)	Office (4)	
B4 - 3.21 - Shared Learning Space - (53.24 SQM)	Student Space (24)	
B4 - 3.22 - Movement - (251.46 SQM)	Not Applicable	Circulation or storage space.
B4 - 3.3 - Seminar - Type 1 - (31.56 SQM)	Office (7)	
B4 - 3.31 - Tiered Learning Area - (15.54 SQM)	Student Space (7)	
B4 - 3.35 - Movement - (10.94 SQM)	Not Applicable	Circulation or storage space.
B4 - 3.4 - Photographic Studio - (24.64 SQM)	Office (6)	
B4 - 3.7 - Visual Arts Workshop - (118.78 SQM)	Student Space (55)	
B4 - 3.8 - Seminar - Type 1 - (20.61 SQM)	Office (5)	
B4 - 3.9 - Outdoor Learning Area - (135.81 SQM)	Not Applicable	Circulation or storage space.
B4 - 4.10 - Movement - (10.86 SQM)	Not Applicable	Circulation or storage space.
B4 - 4.2 - Movement - (76.51 SQM)	Not Applicable	Circulation or storage space.
B4 - 4.3 - Gymnasium - (762.27 SQM)	Student Space (353)	
B4 - 4.9 - Movement - (10.94 SQM)	Not Applicable	Circulation or storage space.
B4 - 5.1 - Staff Study - (16.34 SQM)	Office (4)	
B4 - 5.16 - Movement - (106.43 SQM)	Not Applicable	Circulation or storage space.
B4 - 5.17 - Movement - (10.94 SQM)	Not Applicable	Circulation or storage space.
B4 - 5.20 - Movement - (10.86 SQM)	Not Applicable	Circulation or storage space.
B4 - 5.3 - Seminar - (21.96 SQM)	Office (5)	
B4 - 5.4 - Kitchen - Type 1 - (69.51 SQM)	Student Space (32)	
B4 - 5.6 - Kitchen - Type 2 - (24.01 SQM)	Student Space (11)	
B4 - 5.7 - Kitchen - Type 1 - (110.99 SQM)	Student Space (51)	
B4 - 5.8 - Shared Learning Space - (83.27 SQM)	Student Space (38)	
B4 - 5.9 - Hospitality Space - (73.86 SQM)	Student Space (34)	
B4 - 6.1 - Interview/Meeting - (11.03 SQM)	Office (2)	
B4 - 6.10 - Shared Learning Space - (108.27 SQM)	Student Space (50)	
B4 - 6.11 - Staff Study - (31.06 SQM)	Office (7)	
B4 - 6.19 - Movement - (142.69 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B4 - 6.21 - Practical Activities - (11.04 SQM)	● Student Space (5)	
B4 - 6.23 - Movement - (10.86 SQM)	Not Applicable	Circulation or storage space.
B4 - 6.26 - Movement - (10.94 SQM)	Not Applicable	Circulation or storage space.
B4 - 6.3 - Seminar - Type 1 - (21.96 SQM)	● Office (5)	
B4 - 6.5 - Preparation - Science - (48.19 SQM)	Not Applicable	Circulation or storage space.
B4 - 6.6 - Science Laboratory - (95.77 SQM)	● Student Space (44)	
B4 - 6.7 - General Learning Space - (55.84 SQM) - Teaching Space: 1	● Student Space (25)	
B4 - 6.8 - General Learning Space - (45.67 SQM) - Teaching Space: 1	● Student Space (21)	
B4 - 6.9 - Practical Activities - (57.43 SQM)	● Student Space (26)	
B4 - 7.1 - Interview/Meeting - (11.03 SQM)	● Office (2)	
B4 - 7.10 - General Learning Space - (95.02 SQM) - Teaching Space: 1	● Student Space (44)	
B4 - 7.11 - Staff Study - (31.38 SQM)	● Office (7)	
B4 - 7.12 - Staff Study - (21.16 SQM)	● Office (5)	
B4 - 7.19 - Movement - (142.69 SQM)	Not Applicable	Circulation or storage space.
B4 - 7.20 - Practical Activities - (11.04 SQM)	● Student Space (5)	
B4 - 7.24 - Movement - (9.09 SQM)	Not Applicable	Circulation or storage space.
B4 - 7.3 - Seminar - (21.96 SQM)	● Office (5)	
B4 - 7.6 - Science Laboratory - (95.72 SQM)	● Student Space (44)	
B4 - 7.7 - General Learning Space - Type 10 - (55.84 SQM) - Teaching Space: 0.5	● Student Space (25)	
B4 - 7.8 - General Learning Space - Type 10 - (45.67 SQM) - Teaching Space: 0.5	● Student Space (21)	
B4 - 7.9 - Practical Activities - (57.43 SQM)	● Student Space (26)	
B4 - 8.2 - Movement - (111.5 SQM)	Not Applicable	Circulation or storage space.
B4 - 9.1 - Interview/Meeting - (11.03 SQM)	● Office (2)	
B4 - 9.10 - Shared Learning Space - (123.16 SQM)	● Student Space (57)	
B4 - 9.11 - Staff Study - (31.06 SQM)	● Office (7)	
B4 - 9.18 - Movement - (142.69 SQM)	Not Applicable	Circulation or storage space.
B4 - 9.20 - Practical Activities - (11.04 SQM)	● Student Space (5)	
B4 - 9.21 - Movement - (9.1 SQM)	Not Applicable	Circulation or storage space.
B4 - 9.22 - Movement - (10.94 SQM)	Not Applicable	Circulation or storage space.
B4 - 9.25 - Movement - (10.86 SQM)	Not Applicable	Circulation or storage space.
B4 - 9.3 - Seminar - (21.96 SQM)	● Office (5)	
B4 - 9.5 - Outdoor Learning Area - (55.52 SQM)	Not Applicable	Circulation or storage space.
B4 - 9.6 - Science Laboratory - (94.72 SQM)	● Student Space (43)	
B4 - 9.7 - General Learning Space - (55.84 SQM) - Teaching Space: 1	● Student Space (25)	
B4 - 9.8 - General Learning Space - (45.67 SQM) - Teaching Space: 1	● Student Space (21)	
B4 - 9.9 - Practical Activities - (57.43 SQM)	● Student Space (26)	
B4 - G.10 - Senior Study - (47.19 SQM)	● Office (11)	
B4 - G.11 - Interview/Meeting - (8.09 SQM)	● Office (2)	
B4 - G.12 - Interview/Meeting - (10.62 SQM)	● Office (2)	
B4 - G.13 - Outdoor Learning Area - (179.37 SQM)	Not Applicable	Circulation or storage space.
B4 - G.14 - Main Area - (146.19 SQM)	Not Applicable	Circulation or storage space.
B4 - G.15 - Shared Study Space - (25.04 SQM)	● Office (6)	
B4 - G.16 - Interview/Office - Type 1 - (12.6 SQM)	● Office (3)	
B4 - G.17 - Deputy Principal Office - (12.63 SQM)	● Office (3)	
B4 - G.18 - Deputy Principal Office - (12.84 SQM)	● Office (3)	
B4 - G.20 - Computer Learning Space - (20.76 SQM) - Teaching Space: 1	● Student Space (9)	
B4 - G.22 - Outdoor Learning Area - (79.68 SQM)	Not Applicable	Circulation or storage space.
B4 - G.23 - Interview/Office - Type 1 - (12.43 SQM)	● Office (3)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B4 - G.24 - Movement - (28.35 SQM)	Not Applicable	Circulation or storage space.
B4 - G.26 - Outdoor Learning Area - (30.81 SQM)	Not Applicable	Circulation or storage space.
B4 - G.27 - Outdoor Learning Area - (18.91 SQM)	Not Applicable	Circulation or storage space.
B4 - G.30 - Staff Kitchen - (8.15 SQM)	Office (2)	
B4 - G.8 - Seminar - (27.21 SQM)	Office (6)	
B4 - G.9 - Seminar - (18.76 SQM)	Office (4)	
B4 - LG1.23 - Movement - (34.36 SQM)	Not Applicable	Circulation or storage space.
B4 - LG1.26 - Movement - (24.76 SQM)	Not Applicable	Circulation or storage space.
B4 - LG1.34 - Movement - (5.23 SQM)	Not Applicable	Circulation or storage space.
B4 - LG1.38 - Movement - (38.99 SQM)	Not Applicable	Circulation or storage space.
B4 - LG1.4 - Multi Media Studio - (58.46 SQM)	Not Applicable	Circulation or storage space.
B4 - LG1.5 - Performance Workshop - (88.94 SQM)	Student Space (41)	
B4 - LG1.6 - Movement - (157.83 SQM)	Not Applicable	Circulation or storage space.
B4 - LG1.7 - Movement - (67.31 SQM)	Not Applicable	Circulation or storage space.
B4 - LG2.14 - Movement - (20.09 SQM)	Not Applicable	Circulation or storage space.
B4 - LG2.32 - Movement Studio - (172.11 SQM)	Not Applicable	Circulation or storage space.
B4 - LG2.33 - Staff Study - (9.79 SQM)	Office (2)	
B4 - LG2.36 - Movement - (129.79 SQM)	Not Applicable	Circulation or storage space.
B4 - LG2.44 - Movement - (12.07 SQM)	Not Applicable	Circulation or storage space.
B4 - LG2.6 - Movement - (54.94 SQM)	Not Applicable	Circulation or storage space.
B4 - LG2.7 - Gymnasium - (639.01 SQM)	Student Space (296)	