


VENTILATION AUDIT REPORT

SCHOOL:	Inverell Public School (2209)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Northern Tablelands
LOCAL GOVERNMENT AREA:	Inverell

2209 - Inverell Public School
Site Plan (10890)






















1:1,619

Printed: 20-Aug-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Staff Room Annexe - (22.52 SQM)	Office (5)	
B00A - R0003 - Staff Room - (59.95 SQM)	Office (14)	
B00A - R0005 - Movement - (7.63 SQM)	Not Applicable	Circulation or storage space.
B00A - R0008 - Clerical Office - (17.67 SQM)	Office (4)	
B00A - R0009 - Duplicating Workroom - (28.79 SQM)	Office (7)	
B00A - R0011 - Principal - (16.52 SQM)	Office (4)	
B00A - R0012 - Movement - (29.56 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Deputy Principal - (14.6 SQM)	Office (3)	
B00A - R0014 - Interview - (13.97 SQM)	Office (3)	
B00A - R0015 - Sick Bay - (8.44 SQM)	Student Space (3)	
B00A - R0018 - Movement - (17.34 SQM)	Not Applicable	Circulation or storage space.
B00A - R0019 - Entry Vestibule - (16.36 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Home Base - (94.06 SQM) - Teaching Space: 1	Student Space (43)	
B00B - R0002 - Practical Activities - 1hb - (40.13 SQM)	Student Space (18)	
B00B - R0007 - Movement - (81.94 SQM)	Not Applicable	Circulation or storage space.
B00B - R0008 - Staff Room Annexe - (11.59 SQM)	Office (2)	
B00B - R0009 - Practical Activities - 1hb - (39.85 SQM)	Student Space (18)	
B00B - R0010 - Home Base - (93.59 SQM) - Teaching Space: 1	Student Space (43)	
B00B - R0011 - Movement - (13.03 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Movement - (73.35 SQM)	Not Applicable	Circulation or storage space.
B00B - R0013 - Home Base - (79.14 SQM) - Teaching Space: 1	Student Space (36)	
B00B - R0015 - Home Base - M - (54.56 SQM) - Teaching Space: 1	Student Space (25)	
B00B - R0017 - Movement - (43.92 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Movement - (159.55 SQM)	Not Applicable	Circulation or storage space.
B00C - R0005 - Canteen - (27.84 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Reading Area - (223.29 SQM)	Student Space (103)	
B00D - R0004 - Movement - (89.13 SQM)	Not Applicable	Circulation or storage space.
B00D - R0005 - Home Base - (57 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0008 - Home Base - (56.84 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0011 - Movement - (5.65 SQM)	Not Applicable	Circulation or storage space.
B00D - R0013 - Home Base - P - (56.99 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0016 - Practical Activities - 1hb - (7.91 SQM)	Student Space (3)	
B00D - R0017 - Home Base - (60.57 SQM) - Teaching Space: 1	Student Space (28)	
B00D - R0018 - Special Programs Room - (53.35 SQM)	Student Space (24)	
B00E - R0009 - Movement - (10.02 SQM)	Not Applicable	Circulation or storage space.
B00E - R0010 - Movement - (82.77 SQM)	Not Applicable	Circulation or storage space.
B00E - R0011 - Movement - (10 SQM)	Not Applicable	Circulation or storage space.
B00E - R0012 - Communal Space - (201.06 SQM)	Student Space (93)	
B00E - R0018 - Movement - (14.48 SQM)	Not Applicable	Circulation or storage space.
B00E - R0019 - Raised Platform - (49.83 SQM)	Not Applicable	Circulation or storage space.
B00E - R0020 - Movement - (13.33 SQM)	Not Applicable	Circulation or storage space.
B00F - R0003 - Home Base - (53.57 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R0005 - Home Base - (85.28 SQM) - Teaching Space: 1	Student Space (39)	
B00F - R0011 - Movement - (7.73 SQM)	Not Applicable	Circulation or storage space.
B00F - R0014 - Home Base - (83.61 SQM) - Teaching Space: 1	Student Space (38)	
B00F - R0021 - Movement - (93.25 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Movement - (35.76 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Home Base - (52.55 SQM) - Teaching Space: 1	Student Space (24)	
B00H - R0003 - Staff Room Annexe - (10.44 SQM)	Office (2)	
B00H - R0004 - Movement - (11.52 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00H - R0005 - Home Base - (52.81 SQM) - Teaching Space: 1	 Student Space (24)	
B00H - R0006 - Movement - (21.83 SQM)	Not Applicable	Circulation or storage space.
B00H - R0007 - Practical Activities - 1hb - (9.58 SQM)	 Student Space (4)	
B00H - R0008 - Home Base - (53.08 SQM) - Teaching Space: 1	 Student Space (24)	
B00J - R0002 - Practical Activities - 1hb - (19.07 SQM)	 Student Space (8)	
B00J - R0004 - Home Base - (60.28 SQM) - Teaching Space: 1	 Student Space (27)	
B00J - R0005 - Special Programs Room - (11.6 SQM)	 Student Space (5)	
B00J - R0006 - Practical Activities - 1hb - (19.19 SQM)	 Student Space (8)	
B00J - R0007 - Home Base - (60.08 SQM) - Teaching Space: 1	 Student Space (27)	
B00J - R0010 - Practical Activities - 1hb - (15.12 SQM)	 Student Space (7)	
B00J - R0012 - Home Base - (60.08 SQM) - Teaching Space: 1	 Student Space (27)	
B00J - R0013 - Special Programs Room - (11.59 SQM)	 Student Space (5)	
B00J - R0014 - Practical Activities - 1hb - (14.99 SQM)	 Student Space (6)	
B00J - R0015 - Home Base - (60.08 SQM) - Teaching Space: 1	 Student Space (27)	
OS 601 11645 - OS 601 11645 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 602 10051 - OS 602 10051 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 13429 - OS 602 13429 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 19498 - OS 602 19498 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 606 19217 - OS 606 19217 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	
OS 606 19893 - OS 606 19893 - Learning Unit - Standard With P.A.A A/C - (SQM)	 Student Space ()	