


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Ivanhoe Central School (2213)</b>
<b>AMU REGION:</b>	<b>North Western NSW</b>
<b>STATE ELECTORATE:</b>	<b>Barwon</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Central Darling</b>

2213 - Ivanhoe Central School  
Site Plan (13576)



1:1,063

Printed: 20-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - General Learning Space - (45.34 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R0002 - General Learning Space - (44.11 SQM) - Teaching Space: 1	● Student Space (20)	
B00A - R0003 - Computer Learning Space - (43.32 SQM) - Teaching Space: 1	● Student Space (20)	
B00A - R0004 - Movement - (34.39 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Movement - (30.21 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Food Technology L.S. - (53.85 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0007 - Materials Technology L.S. - (51.96 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0008 - Welding Area - (8.68 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Preparation - (11.76 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Laboratory L.S. - (76.27 SQM) - Teaching Space: 1	● Student Space (35)	
B00C - R0004 - Movement - (11.17 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Movement - (34.76 SQM)	Not Applicable	Circulation or storage space.
B00D - R0004 - Reading Area - (121.26 SQM)	● Student Space (56)	
B00D - R0005 - Movement - (7.97 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Movement - (34.1 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Staff Room - (33.17 SQM)	● Office (8)	
B00E - R0004 - Principal - (15.49 SQM)	● Office (3)	
B00E - R0005 - Clerical Office/Workroom - (11.6 SQM)	● Office (2)	
B00E - R0006 - Sick Bay - (8.55 SQM)	● Student Space (3)	
B00E - R0007 - Duplicating Workroom - (22.66 SQM)	● Office (5)	
B00E - R0008 - Staff Room Annexe - (12.59 SQM)	● Office (3)	
B00E - R0015 - Staff Room Annexe - (11.6 SQM)	● Office (2)	
B00E - R0016 - Movement - (24.21 SQM)	Not Applicable	Circulation or storage space.
B00E - R0017 - Entry Vestibule - (13.59 SQM)	Not Applicable	Circulation or storage space.
B00E - R0018 - Clerical Office - (12.36 SQM)	● Office (3)	
B00E - R0019 - Movement - (78.71 SQM)	Not Applicable	Circulation or storage space.
B00E - R0020 - Clinic-Waiting - (5.45 SQM)	● Office (1)	
B00F - R0001 - Movement - (97.15 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Movement - (87.91 SQM)	Not Applicable	Circulation or storage space.
B00F - R0003 - Art Learning Space - (57.67 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R0007 - Practical Activities - 1hb - (74.46 SQM)	● Student Space (34)	
B00F - R0009 - Withdrawal Space - 1hb - (12.05 SQM)	● Student Space (5)	
B00F - R0010 - Home Base - (59 SQM) - Teaching Space: 1	● Student Space (27)	
B00F - R0012 - Home Base - (55.2 SQM) - Teaching Space: 1	● Student Space (25)	
B00F - R0014 - Withdrawal Space - 1hb - (6.17 SQM)	● Student Space (2)	
B00F - R0021 - Withdrawal Space - 1hb - (12.02 SQM)	● Student Space (5)	
B00F - R0022 - Home Base - (57.59 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R0024 - Practical Activities - 1hb - (38.1 SQM)	● Student Space (17)	
B00F - R0026 - General Learning Space - (59.07 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0003 - Raised Platform - (41.94 SQM)	Not Applicable	Circulation or storage space.
B00G - R0005 - Communal Space - (159.85 SQM)	● Student Space (74)	
B00G - R0014 - Canteen - (23.15 SQM)	Not Applicable	Circulation or storage space.
B00G - R0023 - Movement - (100.62 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Home Base - (59.91 SQM) - Teaching Space: 1	● Student Space (27)	
B00P - R0001 - Growing/Breeding - (5.77 SQM)	Not Applicable	Circulation or storage space.