

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>J J Cahill Memorial High School (8263)</b>
<b>AMU REGION:</b>	<b>Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Heffron</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Bayside</b>

8263 - J J Cahill Memorial High School  
Site Plan (10446)



1:1,141

Printed: 09-Sep-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Gymnasium - (64.66 SQM)	Student Space (29)	
B00A - R0004 - Art Learning Space - (64.98 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R0006 - Art Learning Space - (65.24 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R0034 - Staff Study - (31.76 SQM)	Office (7)	
B00A - R0036 - Computer Learning Space - (64.43 SQM) - Teaching Space: 1	Student Space (29)	
B00A - R0037 - Computer Learning Space - (64.3 SQM) - Teaching Space: 1	Student Space (29)	
B00A - R0052 - Deputy Principal Office - (13.42 SQM)	Office (3)	
B00A - R0053 - Deputy Principal Office - (13.39 SQM)	Office (3)	
B00A - R0055 - Clinic - (13.28 SQM)	Office (3)	
B00A - R0056 - Interview/Office - Type 1 - (12.31 SQM)	Office (3)	
B00A - R0058 - Interview/Office - Type 1 - (12.94 SQM)	Office (3)	
B00A - R0059 - Movement - (361.31 SQM)	Not Applicable	Circulation or storage space.
B00A - R0061 - Administration - Clerical - (59.59 SQM)	Office (14)	
B00A - R0062 - Duplicating Workroom - (13.21 SQM)	Office (3)	
B00A - R0064 - Administration - Clerical - (11.16 SQM)	Office (2)	
B00A - R0065 - Staff Kitchen - (10.08 SQM)	Office (2)	
B00A - R0067 - Movement - (5.28 SQM)	Not Applicable	Circulation or storage space.
B00A - R0070 - Principal Office - (19.57 SQM)	Office (4)	
B00A - R0071 - Interview/Office - Type 1 - (13.76 SQM)	Office (3)	
B00A - R0072 - Movement - (11.79 SQM)	Not Applicable	Circulation or storage space.
B00A - R0073 - Computer Learning Space - (129.77 SQM) - Teaching Space: 1	Student Space (60)	
B00A - R0079 - Darkroom Space - (20.47 SQM)	Office (5)	
B00A - R0082 - Art Learning Space - (65.23 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R0083 - General Learning Space - (48.18 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1001 - Senior Seminar - (32.06 SQM)	Office (8)	
B00A - R1002 - Interview/Office - Type 1 - (16.62 SQM)	Office (4)	
B00A - R1004 - General Learning Space - (31.48 SQM) - Teaching Space: 1	Student Space (14)	
B00A - R1005 - General Learning Space - (64.97 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R1006 - Computer Learning Space - (31.58 SQM) - Teaching Space: 1	Student Space (14)	
B00A - R1007 - General Learning Space - (65.15 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R1008 - General Learning Space - (65.06 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R1009 - General Learning Space - (52.36 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1012 - General Learning Space - (51.78 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1013 - Stage - (25.39 SQM)	Not Applicable	Circulation or storage space.
B00A - R1017 - General Learning Space - (65.31 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R1019 - Staff Study - (51.93 SQM)	Office (12)	
B00A - R1024 - General Learning Space - (52.15 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1025 - General Learning Space - (52.28 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1029 - Interview/Office - Type 1 - (12.61 SQM)	Office (3)	
B00A - R1030 - Interview/Office - Type 1 - (12.61 SQM)	Office (3)	
B00A - R1031 - General Learning Space - (65.1 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R1032 - Commonroom - (98.53 SQM)	Office (24)	
B00A - R1033 - Staff Kitchen - (7.55 SQM)	Office (1)	
B00A - R1036 - Movement - (230.06 SQM)	Not Applicable	Circulation or storage space.
B00A - R1042 - Movement - (8.79 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - General Learning Space - (52.58 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0003 - General Learning Space - (56.21 SQM) - Teaching Space: 1	Student Space (26)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R0006 - General Learning Space - (52.5 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0011 - General Learning Space - (52.65 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0012 - Movement - (129.06 SQM)	Not Applicable	Circulation or storage space.
B00B - R0015 - Laboratory L.S. - (93.05 SQM) - Teaching Space: 1	● Student Space (43)	
B00B - R0017 - Preparation - (30.14 SQM)	Not Applicable	Circulation or storage space.
B00B - R0018 - Laboratory L.S. - (92.87 SQM) - Teaching Space: 1	● Student Space (43)	
B00B - R1001 - General Learning Space - (52.72 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1002 - Staff Study - (26.03 SQM)	● Office (6)	
B00B - R1003 - Staff Study - (15.9 SQM)	● Office (3)	
B00B - R1004 - Staff Study - (15.94 SQM)	● Office (3)	
B00B - R1005 - Staff Study - (26.5 SQM)	● Office (6)	
B00B - R1010 - General Learning Space - (52.64 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1012 - Movement - (73.72 SQM)	Not Applicable	Circulation or storage space.
B00B - R1013 - General Learning Space - (51.48 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R1014 - General Learning Space - (66.01 SQM) - Teaching Space: 1	● Student Space (30)	
B00B - R1017 - General Learning Space - (52.57 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1018 - General Learning Space - (52.13 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1021 - Movement - (11.6 SQM)	Not Applicable	Circulation or storage space.
B00B - R1026 - Movement - (117.16 SQM)	Not Applicable	Circulation or storage space.
B00B - R1028 - Movement - (32.15 SQM)	Not Applicable	Circulation or storage space.
B00B - R2001 - Computer Learning Space - (56.6 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R2002 - General Learning Space - (56.6 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R2005 - General Learning Space - (52.42 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R2010 - Computer Learning Space - (52.64 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R2013 - Movement - (90.97 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Staff Study - (15.96 SQM)	● Office (3)	
B00C - R0002 - Design L.S. - (72.4 SQM) - Teaching Space: 1	● Student Space (33)	
B00C - R0006 - Materials Technology L.S. - (93.71 SQM) - Teaching Space: 1	● Student Space (43)	
B00C - R0007 - Materials Technology L.S. - (76.57 SQM) - Teaching Space: 1	● Student Space (35)	
B00C - R0010 - Materials Technology L.S. - (87.38 SQM) - Teaching Space: 1	● Student Space (40)	
B00C - R0014 - Movement - (39.02 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Food Technology L.S. - (82.86 SQM) - Teaching Space: 1	● Student Space (38)	
B00D - R0002 - Movement - (17.18 SQM)	Not Applicable	Circulation or storage space.
B00D - R0005 - Movement - (111.17 SQM)	Not Applicable	Circulation or storage space.
B00D - R0008 - Staff Study - (18.05 SQM)	● Office (4)	
B00D - R0009 - Design L.S. - (64.27 SQM) - Teaching Space: 1	● Student Space (29)	
B00D - R0012 - Design L.S. - (64.54 SQM) - Teaching Space: 1	● Student Space (29)	
B00D - R0015 - Food Technology L.S. - (79.14 SQM) - Teaching Space: 1	● Student Space (36)	
B00D - R0016 - Food/Research Space - (18.57 SQM)	Not Applicable	Circulation or storage space.
B00D - R1001 - Food Technology L.S. - (52 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1002 - Movement - (12.95 SQM)	Not Applicable	Circulation or storage space.
B00D - R1004 - Movement - (109.8 SQM)	Not Applicable	Circulation or storage space.
B00D - R1005 - General Learning Space - (52.29 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1007 - Staff Study - (34.62 SQM)	● Office (8)	
B00D - R1011 - General Learning Space - (52.51 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1012 - General Learning Space - (52.07 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1013 - General Learning Space - (52.43 SQM) - Teaching Space: 1	● Student Space (24)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R1014 - General Learning Space - (52.5 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1017 - Movement - (34.38 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Laboratory L.S. - (80.49 SQM) - Teaching Space: 1	● Student Space (37)	
B00E - R0004 - Preparation - (27.36 SQM)	Not Applicable	Circulation or storage space.
B00E - R0007 - Laboratory L.S. - (80.76 SQM) - Teaching Space: 1	● Student Space (37)	
B00E - R1002 - Laboratory L.S. - (80.75 SQM) - Teaching Space: 1	● Student Space (37)	
B00E - R1003 - Preparation - (27.95 SQM)	Not Applicable	Circulation or storage space.
B00E - R1006 - Laboratory L.S. - (80.58 SQM) - Teaching Space: 1	● Student Space (37)	
B00E - R1008 - Staff Study - (38.03 SQM)	● Office (9)	
B00F - R0001 - Main Area - (438.88 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Seminar - (12.48 SQM)	● Office (3)	
B00F - R0003 - Seminar - (13.29 SQM)	● Office (3)	
B00F - R0004 - Seminar - (13.12 SQM)	● Office (3)	
B00F - R0006 - Workroom - (46.17 SQM)	● Office (11)	
B00F - R0008 - Audio Visual Workroom - (30.29 SQM)	● Student Space (14)	
B00F - R0009 - Seminar - (15.63 SQM)	● Office (3)	
B00G - R0003 - Staff Study - (20.37 SQM)	● Office (5)	
B00G - R0007 - Movement - (5.69 SQM)	Not Applicable	Circulation or storage space.
B00G - R0009 - Staff Kitchen - (10.24 SQM)	● Office (2)	
B00G - R0010 - Multi-Purpose Space - (387.13 SQM)	● Student Space (179)	
B00G - R0016 - Movement - (10.9 SQM)	Not Applicable	Circulation or storage space.
B00G - R0018 - Movement - (18.09 SQM)	Not Applicable	Circulation or storage space.
B00G - R0019 - Stage - (71.99 SQM)	Not Applicable	Circulation or storage space.
B00G - R0020 - Movement - (17.94 SQM)	Not Applicable	Circulation or storage space.
B00G - R0021 - Movement - (19.08 SQM)	Not Applicable	Circulation or storage space.
B00G - R0028 - Music Learning Space - (60.51 SQM) - Teaching Space: 1	● Student Space (28)	
B00G - R0029 - Music Learning Space - (110.98 SQM) - Teaching Space: 1	● Student Space (51)	
B00G - R0030 - Music Learning Space - (60.81 SQM) - Teaching Space: 1	● Student Space (28)	
B00G - R0032 - Practice/Seminar - (18.69 SQM)	Not Applicable	Circulation or storage space.
B00G - R0033 - Practice/Seminar - (19.43 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - General Learning Space - S/P - (58.16 SQM) - Teaching Space: 1	● Student Space (26)	
B00H - R0003 - General Learning Space - S/P - (60.28 SQM) - Teaching Space: 1	● Student Space (27)	
B00H - R0004 - Staff Study - (40.07 SQM)	● Office (10)	
B00H - R0007 - Seminar - Type 3 - (13.13 SQM)	● Office (3)	
B00H - R0008 - Practical Activity Area - (58.24 SQM)	● Student Space (27)	
B00H - R0015 - General Learning Space - S/P - (73.66 SQM) - Teaching Space: 1	● Student Space (34)	
B00I - R0001 - Student Canteen - (54.56 SQM)	Not Applicable	Circulation or storage space.
B00J - R0001 - Gymnasium - (633.7 SQM)	● Student Space (294)	
B00J - R0017 - Movement - (5.46 SQM)	Not Applicable	Circulation or storage space.
B00J - R1002 - Multi-Purpose Space - (53.77 SQM)	● Student Space (24)	