


VENTILATION AUDIT REPORT

SCHOOL:	James Erskine Public School (4579)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Mulgoa
LOCAL GOVERNMENT AREA:	Penrith

4579 - James Erskine Public School
Site Plan (10440)



1:1,857

Printed: 15-Jun-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Staff Room - (68.83 SQM)	Office (17)	
B00A - R0008 - Deputy Principal - (12.96 SQM)	Office (3)	
B00A - R0009 - Movement - (23.78 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Duplicating Workroom - (33.06 SQM)	Office (8)	
B00A - R0011 - Clerical Office - (13.09 SQM)	Office (3)	
B00A - R0012 - Entry Vestibule - (17.13 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Clerical Office/Workroom - (13.45 SQM)	Office (3)	
B00A - R0014 - Principal - (14.84 SQM)	Office (3)	
B00A - R0015 - Sick Bay - (8.31 SQM)	Student Space (3)	
B00A - R0020 - Interview - (12.81 SQM)	Office (3)	
B00A - R0021 - Staff Room Annexe - (23.42 SQM)	Office (5)	
B00A - R0022 - Movement - (51.91 SQM)	Not Applicable	Circulation or storage space.
B00A - R0023 - Movement - (49.94 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Movement - (44.29 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Movement - (173.52 SQM)	Not Applicable	Circulation or storage space.
B00B - R0009 - Home Base - (59.78 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0011 - Practical Activities - 1hb - (40.24 SQM)	Student Space (18)	
B00B - R0013 - Withdrawal Space - 1hb - (11.85 SQM)	Student Space (5)	
B00B - R0014 - Movement - (18.15 SQM)	Not Applicable	Circulation or storage space.
B00B - R0015 - Home Base - (59.79 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0019 - Home Base - (59.79 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0020 - Withdrawal Space - 1hb - (11.85 SQM)	Student Space (5)	
B00B - R0021 - Practical Activities - 1hb - (40.2 SQM)	Student Space (18)	
B00B - R0023 - Home Base - (59.78 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0025 - Movement - (18.12 SQM)	Not Applicable	Circulation or storage space.
B00B - R0028 - Home Base - (59.78 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0029 - Withdrawal Space - 1hb - (11.85 SQM)	Student Space (5)	
B00B - R0030 - Practical Activities - 1hb - (40.25 SQM)	Student Space (18)	
B00B - R0032 - Home Base - (59.79 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0035 - Movement - (9.45 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Movement - (9.42 SQM)	Not Applicable	Circulation or storage space.
B00C - R0006 - Canteen - (45.25 SQM)	Not Applicable	Circulation or storage space.
B00C - R0012 - Communal Space - (207.87 SQM)	Student Space (96)	
B00C - R0013 - Raised Platform - (42.33 SQM)	Not Applicable	Circulation or storage space.
B00C - R0018 - Movement - (37.78 SQM)	Not Applicable	Circulation or storage space.
B00C - R0019 - Movement - (191.28 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Movement - (22.63 SQM)	Not Applicable	Circulation or storage space.
B00D - R0007 - Home Base - (59.33 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0009 - Practical Activities - 1hb - (40.32 SQM)	Student Space (18)	
B00D - R0011 - Withdrawal Space - 1hb - (12.06 SQM)	Student Space (5)	
B00D - R0012 - Home Base - (59.34 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0015 - Home Base - (59.33 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0017 - Practical Activities - 1hb - (40.32 SQM)	Student Space (18)	
B00D - R0019 - Withdrawal Space - 1hb - (12.07 SQM)	Student Space (5)	
B00D - R0020 - Home Base - (59.34 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0023 - Home Base - (59.34 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0025 - Practical Activities - 1hb - (40.32 SQM)	Student Space (18)	
B00D - R0027 - Withdrawal Space - 1hb - (12.06 SQM)	Student Space (5)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R0028 - Home Base - (59.34 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R0031 - Home Base - (59.34 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R0033 - Practical Activities - 1hb - (40.32 SQM)	● Student Space (18)	
B00D - R0035 - Withdrawal Space - 1hb - (12.07 SQM)	● Student Space (5)	
B00D - R0036 - Home Base - (59.34 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R0001 - Reading Area - (230.79 SQM)	● Student Space (107)	
B00E - R0002 - Special Programs Room - (41.05 SQM)	● Student Space (19)	
B00E - R0007 - Movement - (47.74 SQM)	Not Applicable	Circulation or storage space.
B00E - R0009 - Movement - (12.76 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Movement - (38.48 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Practical Activities - 1hb - (19.4 SQM)	● Student Space (9)	
B00F - R0004 - Home Base - (59.2 SQM) - Teaching Space: 1	● Student Space (27)	
B00F - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	● Student Space (5)	
B00F - R0006 - Home Base - (59.19 SQM) - Teaching Space: 1	● Student Space (27)	
B00F - R0008 - Practical Activities - 1hb - (19.4 SQM)	● Student Space (9)	
B00G - R0002 - Practical Activities - 1hb - (18.51 SQM)	● Student Space (8)	
B00G - R0004 - Home Base - (59.49 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0005 - Withdrawal Space - 2hb - (11.26 SQM)	● Student Space (5)	
B00G - R0006 - Home Base - (59.75 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0008 - Practical Activities - 1hb - (18.5 SQM)	● Student Space (8)	
B00G - R0009 - Practical Activities - 1hb - (18.45 SQM)	● Student Space (8)	
B00G - R0011 - Home Base - (59.21 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0012 - Withdrawal Space - 2hb - (11.26 SQM)	● Student Space (5)	
B00G - R0013 - Home Base - (59.4 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0015 - Practical Activities - 1hb - (18.47 SQM)	● Student Space (8)	
B00G - R0016 - Special Programs Room - (33.21 SQM)	● Student Space (15)	
OS 602 10088 - OS 602 10088 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 15298 - OS 602 15298 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 15350 - OS 602 15350 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 750 16301 - OS 750 16301 - Learning Unit - ESL - (38 SQM)	● Student Space (17)	