


VENTILATION AUDIT REPORT

SCHOOL:	James Fallon High School (8266)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Albury
LOCAL GOVERNMENT AREA:	Albury

8266 - James Fallon High School
Site Plan (10856)



Printed: 12-Dec-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Administration - Clerical - (31.9 SQM)	Office (7)	
B00A - R0002 - Public Entry - (38.51 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Principal Office - (16.93 SQM)	Office (4)	
B00A - R0006 - Ancillary Staff - (18.04 SQM)	Office (4)	
B00A - R0010 - Staff Study - (12.66 SQM)	Office (3)	
B00A - R0011 - Clinic - Girls - (10.78 SQM)	Office (2)	
B00A - R0014 - Clinic - Boys - (13.98 SQM)	Office (3)	
B00A - R0025 - Food Technology L.S. - (65.05 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R0039 - Staff Study - (25.62 SQM)	Office (6)	
B00A - R0040 - General Learning Space - (52.01 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0041 - Deputy Principal Office - (25.58 SQM)	Office (6)	
B00A - R0042 - Deputy Principal Office - (12.84 SQM)	Office (3)	
B00A - R0043 - Commonroom - (91.45 SQM)	Office (22)	
B00A - R0046 - Leading Teacher - (11.21 SQM)	Office (2)	
B00A - R0048 - Duplicating Workroom - (17.77 SQM)	Office (4)	
B00A - R0049 - Interview/Office - Type 1 - (13.83 SQM)	Office (3)	
B00A - R0051 - Administration - Clerical - (20.94 SQM)	Office (5)	
B00A - R0055 - Movement - (112 SQM)	Not Applicable	Circulation or storage space.
B00A - R0059 - General Learning Space - S/P - (64.96 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R0060 - Movement - (17.87 SQM)	Not Applicable	Circulation or storage space.
B00A - R0062 - General Learning Space - S/P - (60.98 SQM) - Teaching Space: 1	Student Space (28)	
B00A - R0063 - Staff Kitchen - (6.76 SQM)	Office (1)	
B00A - R0064 - Practical Activity Area - (6.08 SQM)	Student Space (2)	
B00A - R0066 - General Learning Space - S/P - (68.09 SQM) - Teaching Space: 1	Student Space (31)	
B00A - R0067 - Practical Activity Area - (6.03 SQM)	Student Space (2)	
B00A - R0068 - Movement - (49.79 SQM)	Not Applicable	Circulation or storage space.
B00A - R0069 - Movement - (10.69 SQM)	Not Applicable	Circulation or storage space.
B00A - R0070 - Movement - (237.57 SQM)	Not Applicable	Circulation or storage space.
B00A - R0079 - Preparation - Materials - (15.77 SQM)	Not Applicable	Circulation or storage space.
B00A - R0081 - Food Technology L.S. - (82.23 SQM) - Teaching Space: 1	Student Space (38)	
B00A - R0082 - Food/Research Space - (18.78 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - General Learning Space - (52.24 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1003 - Movement - (5.09 SQM)	Not Applicable	Circulation or storage space.
B00A - R1004 - General Learning Space - (52.16 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1006 - General Learning Space - (65.05 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R1007 - Senior Study - (133.65 SQM)	Office (33)	
B00A - R1009 - Staff Study - (52.03 SQM)	Office (13)	
B00A - R1012 - General Learning Space - (55.55 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R1013 - Computer Learning Space - (52.24 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1017 - Music Learning Space - (52.02 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1019 - General Learning Space - (52.02 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1020 - General Learning Space - (52.03 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1021 - General Learning Space - (51.95 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1024 - Performance Workspace - (74.33 SQM) - Teaching Space: 1	Student Space (34)	
B00A - R1025 - General Learning Space - (52.39 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1026 - General Learning Space - (52.09 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1027 - General Learning Space - (52.17 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1028 - General Learning Space - (52.18 SQM) - Teaching Space: 1	Student Space (24)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R1029 - Movement - (253.87 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Laboratory L.S. - (86.62 SQM) - Teaching Space: 1	● Student Space (40)	
B00B - R0007 - General Learning Space - (52.53 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0008 - Staff Study - (52.46 SQM)	● Office (13)	
B00B - R0009 - General Learning Space - (52.53 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0013 - Movement - (149.79 SQM)	Not Applicable	Circulation or storage space.
B00B - R0014 - Staff Study - (25.68 SQM)	● Office (6)	
B00B - R0017 - Preparation - (28.44 SQM)	Not Applicable	Circulation or storage space.
B00B - R0020 - Practical Activities - (18.06 SQM)	● Student Space (8)	
B00B - R0021 - General Learning Space - (65.04 SQM) - Teaching Space: 1	● Student Space (30)	
B00B - R1001 - Audio Visual Workroom - (13.1 SQM)	● Student Space (6)	
B00B - R1006 - Art Learning Space - (65.65 SQM) - Teaching Space: 1	● Student Space (30)	
B00B - R1007 - Art Learning Space - (65.57 SQM) - Teaching Space: 1	● Student Space (30)	
B00B - R1010 - Art Learning Space - (53.18 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1011 - Movement - (122.85 SQM)	Not Applicable	Circulation or storage space.
B00B - R1012 - Staff Study - (25.98 SQM)	● Office (6)	
B00B - R1013 - Art Learning Space - (52.53 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1015 - Art Learning Space - (52.6 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1017 - Darkroom Space - (12.8 SQM)	● Office (3)	
B00B - R1019 - Darkroom Space - (10.29 SQM)	● Office (2)	
B00B - R1021 - Darkroom Space - (11.85 SQM)	● Office (2)	
B00B - R1023 - Seminar - Type 1 - (25.75 SQM)	● Office (6)	
B00C - R0001 - General Learning Space - (52.89 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0002 - General Learning Space - (54.47 SQM) - Teaching Space: 1	● Student Space (25)	
B00C - R0006 - Staff Study - (16.18 SQM)	● Office (4)	
B00C - R0010 - Staff Study - (32.95 SQM)	● Office (8)	
B00C - R0014 - Music Learning Space - (54.04 SQM) - Teaching Space: 1	● Student Space (25)	
B00C - R0017 - General Assistants - (12.88 SQM)	● Office (3)	
B00C - R0018 - Staff Study - (9.76 SQM)	● Office (2)	
B00C - R0021 - Staff Study - (9.19 SQM)	● Office (2)	
B00C - R0022 - Movement - (163.39 SQM)	Not Applicable	Circulation or storage space.
B00C - R0023 - General Learning Space - (52.08 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0024 - General Learning Space - (52.97 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0025 - General Learning Space - (52.67 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0026 - General Learning Space - (52.31 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0027 - Practice/Seminar - (51.67 SQM)	Not Applicable	Circulation or storage space.
B00C - R1001 - General Learning Space - (52.82 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1002 - General Learning Space - (54.48 SQM) - Teaching Space: 1	● Student Space (25)	
B00C - R1005 - Interview/Office - Type 1 - (16.31 SQM)	● Office (4)	
B00C - R1008 - Staff Study - (16.37 SQM)	● Office (4)	
B00C - R1009 - Staff Study - (33 SQM)	● Office (8)	
B00C - R1014 - Computer Learning Space - (54.47 SQM) - Teaching Space: 1	● Student Space (25)	
B00C - R1015 - General Learning Space - (52.75 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1016 - Staff Study - (19.23 SQM)	● Office (4)	
B00C - R1017 - General Learning Space - (52.3 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1018 - General Learning Space - (52.82 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1021 - General Learning Space - (52.82 SQM) - Teaching Space: 1	● Student Space (24)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R1022 - Staff Study - (25.63 SQM)	Office (6)	
B00C - R1023 - Movement - (146.28 SQM)	Not Applicable	Circulation or storage space.
B00D - M1002 - Interview/Office - Type 1 - (38.35 SQM)	Office (9)	
B00D - M1003 - Main Area - (67.69 SQM)	Not Applicable	Circulation or storage space.
B00D - M1005 - Seminar - (15.33 SQM)	Office (3)	
B00D - R0001 - Laboratory L.S. - (91.24 SQM) - Teaching Space: 1	Student Space (42)	
B00D - R0006 - Laboratory L.S. - (91.24 SQM) - Teaching Space: 1	Student Space (42)	
B00D - R0007 - Preparation - (44.57 SQM)	Not Applicable	Circulation or storage space.
B00D - R0009 - Laboratory L.S. - (91.35 SQM) - Teaching Space: 1	Student Space (42)	
B00D - R0011 - Movement - (25.74 SQM)	Not Applicable	Circulation or storage space.
B00D - R0012 - Laboratory L.S. - (91.15 SQM) - Teaching Space: 1	Student Space (42)	
B00D - R0013 - Movement - (40.81 SQM)	Not Applicable	Circulation or storage space.
B00D - R0017 - Preparation - Science - (48.61 SQM)	Not Applicable	Circulation or storage space.
B00D - R1001 - Seminar - (13.14 SQM)	Office (3)	
B00D - R1002 - Seminar - (11.22 SQM)	Office (2)	
B00D - R1009 - Seminar - (11.48 SQM)	Office (2)	
B00D - R1010 - Seminar - (13.14 SQM)	Office (3)	
B00D - R1011 - Main Area - (327.34 SQM)	Not Applicable	Circulation or storage space.
B00D - R1012 - Audio Visual Workroom - (28.84 SQM)	Student Space (13)	
B00D - R1014 - Audio Visual Workroom - (12.88 SQM)	Student Space (5)	
B00D - R1015 - Workroom - (17.54 SQM)	Office (4)	
B00D - R1017 - Movement - (24.62 SQM)	Not Applicable	Circulation or storage space.
B00D - R1019 - Computer Learning Space - (71.74 SQM) - Teaching Space: 1	Student Space (33)	
B00E - R0001 - Main Entry - (148.73 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Gymnasium - (761.3 SQM)	Student Space (353)	
B00E - R0003 - Kitchen - Type 1 - (47.72 SQM)	Student Space (22)	
B00G - R0001 - Movement - (44.24 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Movement - (7.05 SQM)	Not Applicable	Circulation or storage space.
B00H - R0004 - Stage - (106.19 SQM)	Not Applicable	Circulation or storage space.
B00H - R0005 - Multi-Purpose Space - (276.14 SQM)	Student Space (128)	
B00H - R0007 - Movement - (31.25 SQM)	Not Applicable	Circulation or storage space.
B00H - R0008 - Staff Kitchen - (11.78 SQM)	Office (2)	
B00H - R0010 - Movement - (7.14 SQM)	Not Applicable	Circulation or storage space.
B00H - R0019 - Performance Workspace - (125.54 SQM) - Teaching Space: 1	Student Space (58)	
B00M - R0004 - Metal Technology Bay - (161.29 SQM)	Not Applicable	Circulation or storage space.
B00M - R0005 - Welding Area - (11.64 SQM)	Not Applicable	Circulation or storage space.
B00N - R0004 - Wood Technology Bay - (95.6 SQM)	Not Applicable	Circulation or storage space.
B00N - R0006 - Movement - (24.47 SQM)	Not Applicable	Circulation or storage space.
B00N - R0007 - Design L.S. - (51.44 SQM) - Teaching Space: 1	Student Space (23)	
B00N - R0011 - Staff Study - (25.33 SQM)	Office (6)	
B00N - R0012 - Welding Area - (10.33 SQM)	Not Applicable	Circulation or storage space.
B00N - R0014 - Metal Technology Bay - (75.33 SQM)	Not Applicable	Circulation or storage space.
B00P - R0001 - Design L.S. - (51.88 SQM) - Teaching Space: 1	Student Space (24)	
B00P - R0003 - Movement - (12.17 SQM)	Not Applicable	Circulation or storage space.
B00P - R0006 - Wood Technology Bay - (99.95 SQM)	Not Applicable	Circulation or storage space.
B00S - R0020 - Student Canteen - (48.13 SQM)	Not Applicable	Circulation or storage space.
B00S - R0024 - Student Canteen - (67.36 SQM)	Not Applicable	Circulation or storage space.
B00T - R0001 - Movement Studio - (142.71 SQM)	Not Applicable	Circulation or storage space.