

VENTILATION AUDIT REPORT

SCHOOL:	James Meehan High School (8497)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Macquarie Fields
LOCAL GOVERNMENT AREA:	Campbelltown

8497 - James Meehan High School
Site Plan (11020)



1:1,147

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B001 - R0015 - Art Learning Space - (64.21 SQM) - Teaching Space: 1	Student Space (29)	
B001 - R0021 - Movement - (25.65 SQM)	Not Applicable	Circulation or storage space.
B001 - R0023 - Metal Technology L.S. - (149.57 SQM) - Teaching Space: 1	Student Space (69)	
B001 - R1002 - Staff Study - (52.8 SQM)	Office (13)	
B001 - R1004 - Wood Technology L.S. - (82.84 SQM) - Teaching Space: 1	Student Space (38)	
B001 - R1011 - General Learning Space - (52.56 SQM) - Teaching Space: 1	Student Space (24)	
B001 - R1012 - Movement - (64.2 SQM)	Not Applicable	Circulation or storage space.
B001 - R1013 - Wood Technology L.S. - (94.04 SQM) - Teaching Space: 1	Student Space (43)	
B002 - R0001 - Gymnasium - (308.87 SQM)	Student Space (143)	
B002 - R0007 - Movement - (79.55 SQM)	Not Applicable	Circulation or storage space.
B002 - R0011 - Student Canteen - (55.62 SQM)	Not Applicable	Circulation or storage space.
B002 - R1009 - Movement - (66.26 SQM)	Not Applicable	Circulation or storage space.
B003 - R0002 - Food Technology L.S. - (82.77 SQM) - Teaching Space: 1	Student Space (38)	
B003 - R0008 - Design/Technology L.S. - (65.67 SQM) - Teaching Space: 1	Student Space (30)	
B003 - R0011 - Staff Study - (32.05 SQM)	Office (8)	
B003 - R0013 - General Assistants - (18.16 SQM)	Office (4)	
B003 - R0015 - Movement - (73.87 SQM)	Not Applicable	Circulation or storage space.
B003 - R0018 - Food Technology L.S. - (81.65 SQM) - Teaching Space: 1	Student Space (37)	
B003 - R0020 - Food Technology L.S. - (43.43 SQM) - Teaching Space: 1	Student Space (20)	
B003 - R0021 - Preparation - Materials - (27.58 SQM)	Not Applicable	Circulation or storage space.
B003 - R1001 - Music Learning Space - (65.33 SQM) - Teaching Space: 1	Student Space (30)	
B003 - R1002 - Music Learning Space - (65.07 SQM) - Teaching Space: 1	Student Space (30)	
B003 - R1003 - Staff Study - (31.22 SQM)	Office (7)	
B003 - R1004 - Art Learning Space - (64.35 SQM) - Teaching Space: 1	Student Space (29)	
B003 - R1006 - Art Learning Space - (65.71 SQM) - Teaching Space: 1	Student Space (30)	
B003 - R1007 - Art Learning Space - (69.19 SQM) - Teaching Space: 1	Student Space (32)	
B003 - R1009 - Movement - (77.36 SQM)	Not Applicable	Circulation or storage space.
B003 - R1010 - Music Learning Space - (65.65 SQM) - Teaching Space: 1	Student Space (30)	
B004 - M1001 - Study Space - (149.34 SQM)	Not Applicable	Circulation or storage space.
B004 - M1002 - Study Space - (22.36 SQM)	Not Applicable	Circulation or storage space.
B004 - R0001 - Laboratory L.S. - (90.94 SQM) - Teaching Space: 1	Student Space (42)	
B004 - R0002 - Preparation - Science - (49.04 SQM)	Not Applicable	Circulation or storage space.
B004 - R0003 - Laboratory L.S. - (90.54 SQM) - Teaching Space: 1	Student Space (42)	
B004 - R0005 - Laboratory L.S. - (90.95 SQM) - Teaching Space: 1	Student Space (42)	
B004 - R0006 - Staff Study - (49.1 SQM)	Office (12)	
B004 - R0007 - Laboratory L.S. - (90.75 SQM) - Teaching Space: 1	Student Space (42)	
B004 - R0008 - Movement - (58.66 SQM)	Not Applicable	Circulation or storage space.
B004 - R1003 - Seminar/Study - (13.33 SQM)	Office (3)	
B004 - R1004 - Seminar/Study - (13.05 SQM)	Office (3)	
B004 - R1008 - Study Space - (13.34 SQM)	Not Applicable	Circulation or storage space.
B004 - R1011 - Workroom - (35.34 SQM)	Office (8)	
B004 - R1017 - Main Entry - (25.8 SQM)	Not Applicable	Circulation or storage space.
B004 - R1018 - Main Area - (344.06 SQM)	Not Applicable	Circulation or storage space.
B005 - R0001 - Deputy Principal Office - (19.88 SQM)	Office (4)	
B005 - R0002 - Deputy Principal Office - (15.97 SQM)	Office (3)	
B005 - R0007 - Staff Study - (11.9 SQM)	Office (2)	
B005 - R0011 - Ancillary Staff - (13.71 SQM)	Office (3)	
B005 - R0013 - Interview/Office - Type 1 - (9.43 SQM)	Office (2)	
B005 - R0016 - Administration - Clerical - (15.36 SQM)	Office (3)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B005 - R0017 - Principal Office - (22.01 SQM)	Office (5)	
B005 - R0022 - Public Entry - (12.19 SQM)	Not Applicable	Circulation or storage space.
B005 - R0023 - Student Reception - (31.96 SQM)	Not Applicable	Circulation or storage space.
B005 - R0024 - Administration - Clerical - (58.1 SQM)	Office (14)	
B005 - R0025 - Movement - (28.54 SQM)	Not Applicable	Circulation or storage space.
B005 - R0026 - Movement - (35.92 SQM)	Not Applicable	Circulation or storage space.
B005 - R0027 - General Learning Space - (165.83 SQM) - Teaching Space: 1	Student Space (76)	
B005 - R0028 - Practical Activities - (9.46 SQM)	Student Space (4)	
B005 - R0032 - Movement - (39.29 SQM)	Not Applicable	Circulation or storage space.
B005 - R0034 - Movement - (16.01 SQM)	Not Applicable	Circulation or storage space.
B005 - R1001 - Computer Learning Space - (53.6 SQM) - Teaching Space: 1	Student Space (24)	
B005 - R1002 - General Learning Space - (53.67 SQM) - Teaching Space: 1	Student Space (24)	
B005 - R1008 - Performance Workshop - (53.74 SQM)	Student Space (24)	
B005 - R1009 - General Learning Space - (40.47 SQM) - Teaching Space: 1	Student Space (18)	
B005 - R1010 - General Learning Space - (40.55 SQM) - Teaching Space: 1	Student Space (18)	
B005 - R1013 - Staff Study - (40.69 SQM)	Office (10)	
B005 - R1014 - Movement - (56.78 SQM)	Not Applicable	Circulation or storage space.
B005 - R1015 - Movement Studio - (80.21 SQM)	Not Applicable	Circulation or storage space.
B005 - R1016 - Performance Workshop - (39.86 SQM)	Student Space (18)	
B006 - R0001 - General Learning Space - (53.09 SQM) - Teaching Space: 1	Student Space (24)	
B006 - R0002 - General Learning Space - (53.75 SQM) - Teaching Space: 1	Student Space (24)	
B006 - R0003 - Staff Study - (37.88 SQM)	Office (9)	
B006 - R0004 - General Learning Space - (52.06 SQM) - Teaching Space: 1	Student Space (24)	
B006 - R0005 - General Learning Space - (53.38 SQM) - Teaching Space: 1	Student Space (24)	
B006 - R0006 - General Learning Space - (52.36 SQM) - Teaching Space: 1	Student Space (24)	
B006 - R0008 - Staff Study - (13.44 SQM)	Office (3)	
B006 - R0017 - Movement - (85.92 SQM)	Not Applicable	Circulation or storage space.
B006 - R1001 - General Learning Space - (53.23 SQM) - Teaching Space: 1	Student Space (24)	
B006 - R1003 - General Learning Space - (52.72 SQM) - Teaching Space: 1	Student Space (24)	
B006 - R1004 - General Learning Space - (52.72 SQM) - Teaching Space: 1	Student Space (24)	
B006 - R1005 - Shared Study Space - (18.28 SQM)	Office (4)	
B006 - R1006 - General Learning Space - (52.87 SQM) - Teaching Space: 1	Student Space (24)	
B006 - R1007 - General Learning Space - (53.81 SQM) - Teaching Space: 1	Student Space (24)	
B006 - R1008 - Shared Study Space - (40.5 SQM)	Office (10)	
B006 - R1009 - General Learning Space - (40.52 SQM) - Teaching Space: 1	Student Space (18)	
B006 - R1013 - Staff Study - (40.82 SQM)	Office (10)	
B006 - R1014 - Movement - (72.19 SQM)	Not Applicable	Circulation or storage space.
B007 - R0004 - Fitness Laboratory - (31.67 SQM)	Student Space (14)	
B007 - R0010 - Staff Study - (50.14 SQM)	Office (12)	
B007 - R0011 - General Learning Space - (53.23 SQM) - Teaching Space: 1	Student Space (24)	
B007 - R0013 - General Learning Space - (53.67 SQM) - Teaching Space: 1	Student Space (24)	
B007 - R0015 - General Learning Space - (53.67 SQM) - Teaching Space: 1	Student Space (24)	
B007 - R0016 - General Learning Space - (53.31 SQM) - Teaching Space: 1	Student Space (24)	
B007 - R0024 - General Learning Space - (82.16 SQM) - Teaching Space: 1	Student Space (38)	
B007 - R0025 - Movement - (50.63 SQM)	Not Applicable	Circulation or storage space.
B007 - R0028 - Movement - (6.37 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B007 - R1001 - Staff Study - (39.96 SQM)	Office (9)	
B007 - R1005 - General Learning Space - (39.63 SQM) - Teaching Space: 1	Student Space (18)	
B007 - R1006 - Computer Learning Space - (39.63 SQM) - Teaching Space: 1	Student Space (18)	
B007 - R1007 - Seminar - (54.03 SQM)	Office (13)	
B007 - R1008 - General Learning Space - (52.8 SQM) - Teaching Space: 1	Student Space (24)	
B007 - R1010 - General Learning Space - (52.8 SQM) - Teaching Space: 1	Student Space (24)	
B007 - R1011 - General Learning Space - (52.8 SQM) - Teaching Space: 1	Student Space (24)	
B007 - R1013 - General Learning Space - (53.09 SQM) - Teaching Space: 1	Student Space (24)	
B007 - R1014 - Movement - (73.17 SQM)	Not Applicable	Circulation or storage space.
B008 - R0001 - General Learning Space - (91.24 SQM) - Teaching Space: 1	Student Space (42)	
B008 - R0002 - Staff Study - (48.47 SQM)	Office (12)	
B008 - R0003 - Special Learning Space - (90.42 SQM) - Teaching Space: 1	Student Space (41)	
B008 - R1001 - Special Learning Space - (90.23 SQM) - Teaching Space: 1	Student Space (41)	
B008 - R1014 - Staff Study - (40.69 SQM)	Office (10)	
B008 - R1015 - Special Learning Space - (48.45 SQM) - Teaching Space: 1	Student Space (22)	
B008 - R1016 - Seminar - Type 1 - (17.91 SQM)	Office (4)	
B008 - R1017 - Practice/Seminar - (27.41 SQM)	Not Applicable	Circulation or storage space.
B009 - R0007 - Multi-Purpose Space - (63.43 SQM)	Student Space (29)	
B009 - R0017 - Staff Kitchen - (29.34 SQM)	Office (7)	
B009 - R0018 - Stage - (127.81 SQM)	Not Applicable	Circulation or storage space.
B009 - R0019 - Multi-Purpose Space - (365.73 SQM)	Student Space (169)	
B009 - R0030 - Movement - (31.02 SQM)	Not Applicable	Circulation or storage space.
B009 - R0032 - Multi-Purpose Space - (99.14 SQM)	Student Space (45)	
B009 - R0034 - Movement - (142.64 SQM)	Not Applicable	Circulation or storage space.
B009 - R1001 - Movement - (32.69 SQM)	Not Applicable	Circulation or storage space.
B009 - R1004 - Multi-Purpose Space - (181.12 SQM)	Student Space (84)	
B009 - R1011 - Movement - (18.45 SQM)	Not Applicable	Circulation or storage space.
B011 - R0001 - General Learning Space - (91.92 SQM) - Teaching Space: 1	Student Space (42)	
B011 - R0002 - Seminar - (18.78 SQM)	Office (4)	