


VENTILATION AUDIT REPORT

SCHOOL:	Jindabyne Central School (2237)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Monaro
LOCAL GOVERNMENT AREA:	Snowy Monaro

2237 - Jindabyne Central School
Site Plan (10444)



1:1,065















Printed: 20-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Duplicating Workroom - (11.68 SQM)	Office (2)	
B00A - R0004 - Sick Bay - (6.98 SQM)	Student Space (3)	
B00A - R0005 - Staff Room Annexe - (10.6 SQM)	Office (2)	
B00A - R0008 - Entry Vestibule - (20.44 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Movement - (14.07 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Withdrawal Space - 1hb - (19.7 SQM)	Student Space (9)	
B00A - R0012 - Principal - (15.34 SQM)	Office (3)	
B00A - R0013 - Clerical Office/Workroom - (19.68 SQM)	Office (4)	
B00A - R0018 - Staff Room Annexe - (8.07 SQM)	Office (2)	
B00A - R0021 - Home Base - (57.39 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0022 - Home Base - (57.47 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0026 - Movement - (53.29 SQM)	Not Applicable	Circulation or storage space.
B00A - R0040 - Home Base - (56.54 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0041 - Home Base - (85.61 SQM) - Teaching Space: 1	Student Space (39)	
B00A - R0045 - Movement - (90.63 SQM)	Not Applicable	Circulation or storage space.
B00A - R0047 - Clerical Office - (29.48 SQM)	Office (7)	
B00A - R0048 - Duplicating Workroom - (20.34 SQM)	Office (5)	
B00A - R0049 - Interview/Office - Type 3 - (20.75 SQM)	Office (5)	
B00A - R0050 - Movement - (36.95 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Communal Space - (90.82 SQM)	Student Space (42)	
B00B - R0009 - Movement - (23.91 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Canteen - (34.71 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Practical Activities - 1hb - (18.71 SQM)	Student Space (8)	
B00F - R0004 - Home Base - (59.56 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0005 - Withdrawal Space - 2hb - (11.59 SQM)	Student Space (5)	
B00F - R0006 - Home Base - (59.62 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0008 - Practical Activities - 1hb - (18.93 SQM)	Student Space (8)	
B00F - R0010 - Practical Activities - 1hb - (17.83 SQM)	Student Space (8)	
B00F - R0012 - Home Base - (60.15 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0013 - Withdrawal Space - 2hb - (11.73 SQM)	Student Space (5)	
B00F - R0014 - Home Base - (60.61 SQM) - Teaching Space: 1	Student Space (28)	
B00F - R0016 - Practical Activities - 1hb - (18.99 SQM)	Student Space (8)	
B00G - R0006 - Seminar/Study - (13.14 SQM)	Office (3)	
B00G - R0007 - Seminar/Study - (13.14 SQM)	Office (3)	
B00G - R0012 - Special Programs Room - (63.6 SQM)	Student Space (29)	
B00G - R0013 - Movement - (19.96 SQM)	Not Applicable	Circulation or storage space.
B00G - R0021 - Reading Area - (216.6 SQM)	Student Space (100)	
B00G - R0022 - Seminar/Study - (63.49 SQM)	Office (15)	
B00G - R0023 - Special Programs Room - (32.51 SQM)	Student Space (15)	
B00H - R0001 - General Learning Space - Type 1 - (58.54 SQM) - Teaching Space: 1	Student Space (27)	
B00H - R0002 - General Learning Space - Type 11 - (28.81 SQM) - Teaching Space: 1	Student Space (13)	
B00H - R0003 - General Learning Space - Type 11 - (29.03 SQM) - Teaching Space: 1	Student Space (13)	
B00H - R0004 - General Learning Space - Type 1 - (58.47 SQM) - Teaching Space: 1	Student Space (27)	
B00H - R0005 - General Learning Space - Type 2 - (68.16 SQM) - Teaching Space: 1	Student Space (31)	
B00H - R0006 - General Learning Space - Type 1 - (59.28 SQM) - Teaching Space: 1	Student Space (27)	
B00H - R0007 - Interview/Meeting - (13.11 SQM)	Office (3)	
B00H - R0009 - Movement - (142.55 SQM)	Not Applicable	Circulation or storage space.
B00H - R0010 - Staff Lounge - (66.67 SQM)	Office (16)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00H - R0011 - Staff Study - (28.96 SQM)	Office (7)	
B00H - R0012 - General Learning Space - Type 11 - (28.96 SQM) - Teaching Space: 1	Student Space (13)	
B00H - R0013 - Staff Study - (87.25 SQM)	Office (21)	
B00H - R0018 - Shared Learning Space - (47.58 SQM)	Student Space (22)	
B00H - R0019 - Staff Study - (13.94 SQM)	Office (3)	
B00H - R0020 - Staff Study - (14.05 SQM)	Office (3)	
B00H - R0024 - Staff Room Annexe - (18.9 SQM)	Office (4)	
B00I - R0001 - General Learning Space - Type 7 - (58.91 SQM) - Teaching Space: 1	Student Space (27)	
B00I - R0002 - General Learning Space - Type 12 - (59.06 SQM) - Teaching Space: 1	Student Space (27)	
B00I - R0003 - General Learning Space - Type 13 - (76.86 SQM) - Teaching Space: 1	Student Space (35)	
B00I - R0004 - General Learning Space - Type 3 - (59.13 SQM) - Teaching Space: 1	Student Space (27)	
B00I - R0005 - General Learning Space - Type 10 - (31.34 SQM) - Teaching Space: 0.5	Student Space (14)	
B00I - R0007 - Movement - (112.03 SQM)	Not Applicable	Circulation or storage space.
B00I - R0008 - Seminar - Type 1 - (20.73 SQM)	Office (5)	
B00I - R0009 - Materials Workshop - Type 2 - (69.06 SQM)	Student Space (32)	
B00I - R0013 - Welding/Hot Metals Area - (5.62 SQM)	Not Applicable	Circulation or storage space.
B00I - R0014 - Workshop Area - (50.95 SQM)	Student Space (23)	
B00I - R0015 - Kitchen - Type 3 - (69.87 SQM)	Student Space (32)	
B00I - R0018 - Practice/Seminar - (10.4 SQM)	Not Applicable	Circulation or storage space.
B00I - R0020 - Preparation - Materials - (16.35 SQM)	Not Applicable	Circulation or storage space.
B00I - R0021 - Science Laboratory - (66.76 SQM)	Student Space (30)	
B00I - R0023 - Preparation - Science - (37.16 SQM)	Not Applicable	Circulation or storage space.
B00J - R0013 - Gymnasium - (604.06 SQM)	Student Space (280)	
B00L - R0002 - Entry Vestibule - (25.6 SQM)	Not Applicable	Circulation or storage space.
B00L - R0004 - Movement - (48.2 SQM)	Not Applicable	Circulation or storage space.
B00L - R0005 - Interview - (13.26 SQM)	Office (3)	
B00L - R0006 - Principal - (16.67 SQM)	Office (4)	
B00L - R0007 - Clerical Office - (12.37 SQM)	Office (3)	
B00L - R0008 - Deputy Principal - (13.15 SQM)	Office (3)	
B00L - R0009 - Staff Kitchen - (8.21 SQM)	Office (2)	
B00L - R0010 - Staff Room - (57.41 SQM)	Office (14)	
B00L - R0012 - Deputy Principal - (16.33 SQM)	Office (4)	
B00L - R0013 - Student Waiting - (8.62 SQM)	Not Applicable	Circulation or storage space.
B00L - R0022 - Sick Bay - (10.1 SQM)	Student Space (4)	
B00L - R0024 - Clerical Office - (26.15 SQM)	Office (6)	
B00L - R0025 - Public Reception - (39.61 SQM)	Not Applicable	Circulation or storage space.
B00L - R1003 - Withdrawal Space - 1hb - (58.71 SQM)	Student Space (27)	
B00L - R1004 - Practical Activities - (12.49 SQM)	Student Space (5)	
B00L - R1005 - Home Base - (70.25 SQM) - Teaching Space: 1	Student Space (32)	
B00L - R1006 - Home Base - (69.56 SQM) - Teaching Space: 1	Student Space (32)	
B00L - R1007 - Seminar - Type 1 - (29.05 SQM)	Office (7)	
B00L - R1008 - Home Base - (66.94 SQM) - Teaching Space: 1	Student Space (31)	
NS 220 13416 - NS 220 13416 - Science Learning/Preparation Space - (95 SQM)	Not Applicable	Circulation or storage space.
OS 520 10596 - OS 520 10596 - Staff Study - (57 SQM)	Office (14)	
OS 600 10464 - OS 600 10464 - Learning Unit - Small - (57 SQM)	Student Space (26)	
OS 600 10543 - OS 600 10543 - Learning Unit - Small - (57 SQM)	Student Space (26)	
OS 600 11565 - OS 600 11565 - Learning Unit - Small - (57 SQM)	Student Space (26)	
OS 600 14738 - OS 600 14738 - Learning Unit - Small - (57 SQM)	Student Space (26)	

Entity Location	Audit Condition Classification (Capacity)	Comment
OS 600 15647 - OS 600 15647 - Learning Unit - Small - (57 SQM)	 Student Space (26)	
OS 600 17663 - OS 600 17663 - Learning Unit - Small - (57 SQM)	 Student Space (26)	
OS 600 17711 - OS 600 17711 - Learning Unit - Small - (57 SQM)	 Student Space (26)	
OS 600 19314 - OS 600 19314 - Learning Unit - Small - (57 SQM)	 Student Space (26)	
OS 600 19618 - OS 600 19618 - Learning Unit - Small - (57 SQM)	 Student Space (26)	
OS 601 14233 - OS 601 14233 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 19436 - OS 601 19436 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 602 10161 - OS 602 10161 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 10188 - OS 602 10188 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 11283 - OS 602 11283 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 11776 - OS 602 11776 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 12420 - OS 602 12420 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 12670 - OS 602 12670 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 16271 - OS 602 16271 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 700 10836 - OS 700 10836 - Art Learning Space/Workshop/Store - (114 SQM)	Not Applicable	Circulation or storage space.
OS 700 12247 - OS 700 12247 - Art Learning Space/Workshop/Store - (114 SQM)	Not Applicable	Circulation or storage space.