


VENTILATION AUDIT REPORT

SCHOOL:	John Edmondson High School (8290)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Liverpool
LOCAL GOVERNMENT AREA:	Liverpool

8290 - John Edmondson High School
Site Plan (03085)



1:1,343

Printed: 14-Sep-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0003 - Movement - (28.9 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - General Learning Space - Type 2 - (65.71 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R0006 - Shared Learning Space - (43.56 SQM)	● Student Space (20)	
B00A - R0007 - General Learning Space - Type 1 - (60.35 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R0008 - Movement - (90.12 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - General Learning Space - Type 1 - (59.92 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R0012 - General Learning Space - Type 1 - (59.16 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R0013 - Seminar - Type 1 - (24.58 SQM)	● Office (6)	
B00A - R0014 - General Learning Space - Type 1 - (59.42 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R0015 - General Learning Space - Type 1 - (59.5 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R1004 - Movement - (95.92 SQM)	Not Applicable	Circulation or storage space.
B00A - R1005 - Movement - (6 SQM)	Not Applicable	Circulation or storage space.
B00A - R1007 - General Learning Space - Type 2 - (65.37 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R1008 - Shared Learning Space - (43.49 SQM)	● Student Space (20)	
B00A - R1009 - General Learning Space - Type 1 - (60.35 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R1012 - General Learning Space - Type 1 - (59.83 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R1013 - General Learning Space - Type 1 - (59.16 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R1014 - Seminar - Type 1 - (24.55 SQM)	● Office (6)	
B00A - R1015 - General Learning Space - Type 1 - (59.26 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R1016 - General Learning Space - Type 1 - (59.27 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R0001 - Movement - (236.79 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - General Learning Space - Type 1 - (60.35 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R0004 - Shared Learning Space - (42.3 SQM)	● Student Space (19)	
B00B - R0005 - General Learning Space - Type 2 - (65.54 SQM) - Teaching Space: 1	● Student Space (30)	
B00B - R0010 - Movement - (105.21 SQM)	Not Applicable	Circulation or storage space.
B00B - R0013 - General Learning Space - Type 1 - (58.94 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R0014 - General Learning Space - Type 1 - (59.88 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R0015 - Seminar - Type 1 - (24.88 SQM)	● Office (6)	
B00B - R0016 - General Learning Space - Type 1 - (59.88 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R0017 - General Learning Space - Type 1 - (60.55 SQM) - Teaching Space: 1	● Student Space (28)	
B00B - R1001 - Movement - (196.28 SQM)	Not Applicable	Circulation or storage space.
B00B - R1003 - General Learning Space - Type 1 - (60.58 SQM) - Teaching Space: 1	● Student Space (28)	
B00B - R1004 - Shared Learning Space - (43.8 SQM)	● Student Space (20)	
B00B - R1005 - General Learning Space - Type 2 - (65.21 SQM) - Teaching Space: 1	● Student Space (30)	
B00B - R1008 - Movement - (107.53 SQM)	Not Applicable	Circulation or storage space.
B00B - R1009 - General Learning Space - Type 1 - (59.25 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R1010 - General Learning Space - Type 1 - (59.43 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R1011 - Seminar - Type 1 - (24.82 SQM)	● Office (6)	
B00B - R1012 - General Learning Space - Type 1 - (59.43 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R1013 - General Learning Space - Type 1 - (60.41 SQM) - Teaching Space: 1	● Student Space (28)	
B00C - R0001 - Movement - (182.56 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - General Learning Space - Type 1 - (59.42 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R0003 - Fitness Laboratory - (97.67 SQM)	● Student Space (45)	
B00C - R0004 - Seminar - Type 1 - (19.66 SQM)	● Office (4)	
B00C - R0011 - General Learning Space - Type 1 - (58.68 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R0002 - General Learning Space - Type 3 - (59.59 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R0003 - Movement - (17.8 SQM)	Not Applicable	Circulation or storage space.
B00D - R0005 - Movement - (121.21 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R0007 - Seminar - Type 2 - (19.77 SQM)	Office (4)	
B00D - R0008 - Movement - (83.65 SQM)	Not Applicable	Circulation or storage space.
B00D - R0009 - Movement - (37.63 SQM)	Not Applicable	Circulation or storage space.
B00D - R0010 - Movement - (13.17 SQM)	Not Applicable	Circulation or storage space.
B00D - R0012 - General Learning Space - Type 3 - (59.68 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0013 - General Learning Space - Type 3 - (59.5 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0016 - Preparation - Science - (73.03 SQM)	Not Applicable	Circulation or storage space.
B00D - R0019 - General Learning Space - Type 3 - (59.93 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0020 - Science Laboratory - (50.81 SQM)	Student Space (23)	
B00D - R0021 - Science Laboratory - (50.51 SQM)	Student Space (23)	
B00D - R0022 - Science Laboratory - (50.81 SQM)	Student Space (23)	
B00D - R0023 - Science Laboratory - (50.42 SQM)	Student Space (23)	
B00D - R1001 - Staff Study - (200.48 SQM)	Office (50)	
B00D - R1003 - Movement - (5.3 SQM)	Not Applicable	Circulation or storage space.
B00D - R1004 - Interview/Meeting - (14.4 SQM)	Office (3)	
B00D - R1005 - Interview/Meeting - (14.43 SQM)	Office (3)	
B00D - R1007 - Interview/Meeting - (12.84 SQM)	Office (3)	
B00D - R1008 - Interview/Meeting - (12.8 SQM)	Office (3)	
B00D - R1010 - Movement - (12.94 SQM)	Not Applicable	Circulation or storage space.
B00D - R1011 - Movement - (89.83 SQM)	Not Applicable	Circulation or storage space.
B00D - R1012 - Staff Study - (201.27 SQM)	Office (50)	
B00D - R1013 - Movement - (30.34 SQM)	Not Applicable	Circulation or storage space.
B00D - R1014 - Staff Lounge - (108.61 SQM)	Office (27)	
B00E - R0001 - Movement - (52.23 SQM)	Not Applicable	Circulation or storage space.
B00E - R0006 - Interview/Office - Type 1 - (11.97 SQM)	Office (2)	
B00E - R0007 - Interview/Office - Type 1 - (13.21 SQM)	Office (3)	
B00E - R0008 - Public Reception - (39.92 SQM)	Not Applicable	Circulation or storage space.
B00E - R0009 - Visitors Office - (13.62 SQM)	Office (3)	
B00E - R0010 - Administration - Clerical - (96.3 SQM)	Office (24)	
B00E - R0012 - Student Reception - (50.69 SQM)	Not Applicable	Circulation or storage space.
B00E - R0013 - Interview/Office - Type 2 - (13.36 SQM)	Office (3)	
B00E - R0014 - Clinic - Boys - (12.95 SQM)	Office (3)	
B00E - R0016 - Clinic - Girls - (13.44 SQM)	Office (3)	
B00E - R0017 - Deputy Principal Office - (13.16 SQM)	Office (3)	
B00E - R0018 - Deputy Principal Office - (13.2 SQM)	Office (3)	
B00E - R0020 - Tea Room - (5.09 SQM)	Not Applicable	Circulation or storage space.
B00E - R0022 - Movement - (7.54 SQM)	Not Applicable	Circulation or storage space.
B00E - R0023 - Principal Office - (19.14 SQM)	Office (4)	
B00E - R0024 - Movement - (215.94 SQM)	Not Applicable	Circulation or storage space.
B00F - R0003 - Computer Learning Space - (64.65 SQM) - Teaching Space: 1	Student Space (29)	
B00F - R0004 - Main Area - (429.75 SQM)	Not Applicable	Circulation or storage space.
B00F - R0009 - Main Entry - (23.46 SQM)	Not Applicable	Circulation or storage space.
B00F - R0010 - Movement - (195.5 SQM)	Not Applicable	Circulation or storage space.
B00F - R0011 - Senior Study - (63.14 SQM)	Office (15)	
B00F - R0012 - General Learning Space - Type 2 - (65.38 SQM) - Teaching Space: 1	Student Space (30)	
B00F - R0013 - Movement - (16.35 SQM)	Not Applicable	Circulation or storage space.
B00F - R0014 - Shared Learning Space - (43.53 SQM)	Student Space (20)	
B00F - R0015 - General Learning Space - Type 1 - (60.2 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0017 - Movement - (98.83 SQM)	Not Applicable	Circulation or storage space.
B00F - R0018 - General Learning Space - Type 1 - (59.75 SQM) - Teaching Space: 1	Student Space (27)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R0019 - General Learning Space - Type 1 - (59.16 SQM) - Teaching Space: 1	● Student Space (27)	
B00F - R0020 - Seminar - Type 1 - (24.53 SQM)	● Office (6)	
B00F - R0021 - General Learning Space - Type 1 - (59.32 SQM) - Teaching Space: 1	● Student Space (27)	
B00F - R0022 - General Learning Space - Type 1 - (59.24 SQM) - Teaching Space: 1	● Student Space (27)	
B00F - R0027 - Seminar - Type 3 - (12.99 SQM)	● Office (3)	
B00F - R0028 - Seminar - Type 3 - (12.96 SQM)	● Office (3)	
B00F - R0029 - Seminar - Type 3 - (12.88 SQM)	● Office (3)	
B00F - R0031 - Movement - (45.8 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Movement - (200.6 SQM)	Not Applicable	Circulation or storage space.
B00G - R0005 - General Learning Space - Type 6 - (59.35 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0006 - General Learning Space - Type 7 - (59.56 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0007 - Seminar - Type 2 - (19.72 SQM)	● Office (4)	
B00G - R0008 - General Learning Space - Type 6 - (59.73 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0009 - General Learning Space - Type 7 - (59.5 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0012 - Kitchen - Type 1 - (99.71 SQM)	● Student Space (46)	
B00G - R0013 - Preparation - Materials - (29.55 SQM)	Not Applicable	Circulation or storage space.
B00G - R0017 - Kitchen - Type 1 - (100.27 SQM)	● Student Space (46)	
B00H - R0001 - Movement - (371.06 SQM)	Not Applicable	Circulation or storage space.
B00H - R0004 - Materials Workshop - Type 2 - (173.59 SQM)	● Student Space (80)	
B00H - R0007 - Materials Workshop - Type 2 - (173.37 SQM)	● Student Space (80)	
B00H - R0008 - Outdoor Workshop - (92.26 SQM)	Not Applicable	Circulation or storage space.
B00H - R0011 - Welding/Hot Metals Area - (7.21 SQM)	Not Applicable	Circulation or storage space.
B00H - R0015 - General Learning Space - Type 9 - (61.03 SQM) - Teaching Space: 1	● Student Space (28)	
B00H - R0016 - General Learning Space - Type 8 - (61.03 SQM) - Teaching Space: 1	● Student Space (28)	
B00H - R0017 - General Learning Space - Type 9 - (61.03 SQM) - Teaching Space: 1	● Student Space (28)	
B00H - R0018 - General Learning Space - Type 8 - (60.97 SQM) - Teaching Space: 1	● Student Space (28)	
B00H - R0019 - Movement - (30.05 SQM)	Not Applicable	Circulation or storage space.
B00I - R0003 - Movement - (87.72 SQM)	Not Applicable	Circulation or storage space.
B00I - R1002 - Movement - (49.18 SQM)	Not Applicable	Circulation or storage space.
B00J - R0001 - Movement - (411.72 SQM)	Not Applicable	Circulation or storage space.
B00J - R0004 - Student Canteen - (53.18 SQM)	Not Applicable	Circulation or storage space.
B00J - R0005 - General Learning Space - Type 1 - (59.17 SQM) - Teaching Space: 1	● Student Space (27)	
B00J - R0006 - General Learning Space - Type 1 - (60.01 SQM) - Teaching Space: 1	● Student Space (27)	
B00J - R0007 - General Learning Space - Type 5 - (60.77 SQM) - Teaching Space: 1	● Student Space (28)	
B00J - R0008 - General Learning Space - Type 4 - (60.78 SQM) - Teaching Space: 1	● Student Space (28)	
B00J - R0009 - Dark Room - (28.08 SQM)	● Office (7)	
B00J - R0014 - Visual Arts Workshop - (152.59 SQM)	● Student Space (70)	
B00J - R0016 - Practice/Seminar - (19.84 SQM)	Not Applicable	Circulation or storage space.
B00J - R0018 - Performance Workshop - (98.53 SQM)	● Student Space (45)	
B00K - R0001 - Movement - (377.02 SQM)	Not Applicable	Circulation or storage space.
B00K - R0007 - Movement - (17.7 SQM)	Not Applicable	Circulation or storage space.
B00K - R0009 - Stage - (95.7 SQM)	Not Applicable	Circulation or storage space.
B00K - R0011 - Gymnasium - (619.69 SQM)	● Student Space (287)	
B00K - R0016 - General Assistants - (11.15 SQM)	● Office (2)	
B00K - R0025 - Movement - (67.54 SQM)	Not Applicable	Circulation or storage space.