


VENTILATION AUDIT REPORT

SCHOOL:	John Purchase Public School (4572)
AMU REGION:	Northern Sydney
STATE ELECTORATE:	Epping
LOCAL GOVERNMENT AREA:	Hornsby



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Entry Vestibule - (9.06 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Clerical Office - (14.39 SQM)	Office (3)	
B00A - R0004 - Sick Bay - (8.93 SQM)	Student Space (4)	
B00A - R0005 - Clerical/Printing - (21.55 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Staff Room Annexe - (19.17 SQM)	Office (4)	
B00A - R0015 - Deputy Principal - (12.56 SQM)	Office (3)	
B00A - R0016 - Principal - (17.35 SQM)	Office (4)	
B00A - R0018 - Clerical Office - (14.36 SQM)	Office (3)	
B00A - R0019 - Movement - (10.46 SQM)	Not Applicable	Circulation or storage space.
B00A - R0020 - Movement - (39.76 SQM)	Not Applicable	Circulation or storage space.
B00A - R0023 - Staff Room - (39.07 SQM)	Office (9)	
B00A - R0024 - Staff Kitchen - (6.97 SQM)	Office (1)	
B00B - R0001 - Withdrawal Space - 2hb - (11.96 SQM)	Student Space (5)	
B00B - R0002 - Home Base - (59.53 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0004 - Practical Activities - 2hb - (35.78 SQM)	Student Space (16)	
B00B - R0008 - Home Base - (59.51 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0002 - Withdrawal Space - 2hb - (11.92 SQM)	Student Space (5)	
B00C - R0003 - Home Base - (59.6 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0005 - Practical Activities - 2hb - (35.57 SQM)	Student Space (16)	
B00C - R0006 - Home Base - (59.6 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0012 - Home Base - (59.67 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0013 - Practical Activities - 2hb - (35.66 SQM)	Student Space (16)	
B00C - R0015 - Home Base - (59.53 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0017 - Withdrawal Space - 2hb - (12.03 SQM)	Student Space (5)	
B00D - R0006 - Movement - (20.49 SQM)	Not Applicable	Circulation or storage space.
B00D - R0007 - Reading Area - (148.75 SQM)	Student Space (69)	
B00E - R0002 - Withdrawal Space - 2hb - (11.92 SQM)	Student Space (5)	
B00E - R0003 - Home Base - (59.6 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0007 - Practical Activities - 2hb - (35.66 SQM)	Student Space (16)	
B00E - R0009 - Home Base - (59.47 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0002 - Withdrawal Space - 2hb - (11.99 SQM)	Student Space (5)	
B00F - R0003 - Home Base - (59.51 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0007 - Practical Activities - 2hb - (35.54 SQM)	Student Space (16)	
B00F - R0009 - Home Base - (59.37 SQM) - Teaching Space: 1	Student Space (27)	
B00G - R0003 - Movement - (5.86 SQM)	Not Applicable	Circulation or storage space.
B00G - R0006 - Staff Kitchen - (9.04 SQM)	Office (2)	
B00G - R0011 - Movement - (7.33 SQM)	Not Applicable	Circulation or storage space.
B00G - R0017 - Movement - (7.41 SQM)	Not Applicable	Circulation or storage space.
B00G - R0029 - Communal Space - (135.4 SQM)	Student Space (62)	
B00G - R0030 - Raised Platform - (34.34 SQM)	Not Applicable	Circulation or storage space.
B00G - R0043 - Communal Space - (56.69 SQM)	Student Space (26)	
B00G - R0044 - Communal Space - (56.79 SQM)	Student Space (26)	
B00H - R0001 - Canteen - (28.63 SQM)	Not Applicable	Circulation or storage space.
B00L - R0002 - Withdrawal Space - 1hb - (5.3 SQM)	Student Space (2)	
B00L - R0006 - Practical Activities - 1hb - (22.62 SQM)	Student Space (10)	
B00L - R0007 - Practical Activities - 1hb - (22.62 SQM)	Student Space (10)	
B00L - R0010 - Withdrawal Space - 1hb - (5.38 SQM)	Student Space (2)	
B00L - R0012 - Home Base - (56.04 SQM) - Teaching Space: 1	Student Space (26)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00L - R0013 - Home Base - (56.04 SQM) - Teaching Space: 1	● Student Space (26)	
B00M - R0008 - Home Base - (55.85 SQM) - Teaching Space: 1	● Student Space (25)	
B00M - R0009 - Home Base - (55.85 SQM) - Teaching Space: 1	● Student Space (25)	
B00M - R0010 - Practical Activities - 1hb - (22.7 SQM)	● Student Space (10)	
B00M - R0011 - Practical Activities - 1hb - (22.7 SQM)	● Student Space (10)	
B00M - R0014 - Withdrawal Space - 1hb - (5.36 SQM)	● Student Space (2)	
B00N - R0001 - Movement - (5.59 SQM)	Not Applicable	Circulation or storage space.
B00N - R0003 - Computer Room - (64.93 SQM)	● Student Space (30)	
B00O - R0001 - Home Base - (57.85 SQM) - Teaching Space: 1	● Student Space (26)	
B00O - R0002 - Home Base - (61.06 SQM) - Teaching Space: 1	● Student Space (28)	
B00O - R0003 - Home Base - (60.88 SQM) - Teaching Space: 1	● Student Space (28)	
B00O - R0004 - Practical Activities - 1hb - (20.62 SQM)	● Student Space (9)	
B00O - R0005 - Withdrawal Space - 1hb - (8.97 SQM)	● Student Space (4)	
B00O - R0008 - Practical Activities - 1hb - (18.79 SQM)	● Student Space (8)	
B00O - R0009 - Withdrawal Space - 2hb - (11.62 SQM)	● Student Space (5)	
B00O - R0010 - Practical Activities - 1hb - (18.73 SQM)	● Student Space (8)	
OS 602 10520 - OS 602 10520 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 11139 - OS 602 11139 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 13298 - OS 602 13298 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 13784 - OS 602 13784 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 14061 - OS 602 14061 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 14363 - OS 602 14363 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 15085 - OS 602 15085 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 16265 - OS 602 16265 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 750 11313 - OS 750 11313 - Learning Unit - ESL - (38 SQM)	● Student Space (17)	