

VENTILATION AUDIT REPORT

| | |
|-------------------------------|-----------------------------------------|
| SCHOOL: | Johns River Public School (2243) |
| AMU REGION: | North Coast |
| STATE ELECTORATE: | Port Macquarie |
| LOCAL GOVERNMENT AREA: | Mid-Coast |

2243 - Johns River Public School
Site Plan (12554)








1:620

Printed: 20-Mar-2020

Ventilation Audit Key

| Category | Description |
|-----------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
|  | Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings. |
|  | Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces. |

| Entity Location | Audit Condition Classification (Capacity) | Comment |
|---------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------|-------------------------------|
| B00A - R0001 - Principal - (14.73 SQM) |  Office (3) | |
| B00A - R0002 - Clerical Office - (12.29 SQM) |  Office (3) | |
| B00A - R0004 - Entry Vestibule - (9.48 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0005 - Movement - (23.7 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0007 - Home Base - (57.4 SQM) - Teaching Space: 1 |  Student Space (26) | |
| B00B - R0001 - Movement - (11.01 SQM) | Not Applicable | Circulation or storage space. |
| B00G - R0002 - Canteen - (25.29 SQM) | Not Applicable | Circulation or storage space. |
| B00H - R0001 - Reading Area - (59.94 SQM) |  Student Space (27) | |
| OS 503 15599 - OS 503 15599 - Admin Lib Staff/Principal/Clerk/Store - (152 SQM) |  Office (38) | |