


VENTILATION AUDIT REPORT

SCHOOL:	Junee High School (8179)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Cootamundra
LOCAL GOVERNMENT AREA:	Junee

8179 - Junee High School
Site Plan (11074)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - General Learning Space - (54.22 SQM) - Teaching Space: 1	● Student Space (25)	
B00A - R0002 - General Learning Space - (53.7 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0006 - Staff Study - (22.95 SQM)	● Office (5)	
B00A - R0008 - Movement - (52.55 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Commonroom - (75.83 SQM)	● Office (18)	
B00A - R0015 - Interview/Office - Type 1 - (18.96 SQM)	● Office (4)	
B00A - R0016 - General Learning Space - (53.5 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0017 - General Learning Space - (53.65 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0018 - Staff Study - (24.02 SQM)	● Office (6)	
B00A - R0021 - General Learning Space - (53.36 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0023 - Deputy Principal Office - (23.47 SQM)	● Office (5)	
B00A - R0024 - Clinic - (11.15 SQM)	● Office (2)	
B00A - R0027 - Administration - Clerical - (25.89 SQM)	● Office (6)	
B00A - R0028 - Duplicating Workroom - (17.96 SQM)	● Office (4)	
B00A - R0029 - Principal Office - (24.45 SQM)	● Office (6)	
B00A - R0030 - Seminar - (20.85 SQM)	● Office (5)	
B00A - R0036 - Movement - (9.88 SQM)	Not Applicable	Circulation or storage space.
B00A - R0037 - Movement - (11.88 SQM)	Not Applicable	Circulation or storage space.
B00A - R0039 - Study Space - (13.95 SQM)	Not Applicable	Circulation or storage space.
B00A - R0042 - Public Entry - (29.07 SQM)	Not Applicable	Circulation or storage space.
B00A - R0046 - Movement - (136.05 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Laboratory L.S. - (92.58 SQM) - Teaching Space: 1	● Student Space (42)	
B00A - R1002 - Preparation - (26.38 SQM)	Not Applicable	Circulation or storage space.
B00A - R1006 - Staff Study - (23.84 SQM)	● Office (5)	
B00A - R1007 - General Learning Space - (59.1 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R1010 - Laboratory L.S. - (95.19 SQM) - Teaching Space: 1	● Student Space (44)	
B00A - R1011 - Laboratory L.S. - (87.46 SQM) - Teaching Space: 1	● Student Space (40)	
B00A - R1012 - Staff Study - (27.55 SQM)	● Office (6)	
B00A - R1013 - General Learning Space - (51.18 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R1014 - General Learning Space - (55.26 SQM) - Teaching Space: 1	● Student Space (25)	
B00A - R1015 - Audio Visual Workroom - (33.37 SQM)	● Student Space (15)	
B00A - R1016 - Main Area - (163.63 SQM)	Not Applicable	Circulation or storage space.
B00A - R1019 - Senior Study - (13.11 SQM)	● Office (3)	
B00A - R1021 - Movement - (101.03 SQM)	Not Applicable	Circulation or storage space.
B00A - R1024 - Movement - (99.48 SQM)	Not Applicable	Circulation or storage space.
B00A - R1025 - Study Space - (41.27 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Wood Technology Bay - (26.46 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Materials Technology L.S. - (91.21 SQM) - Teaching Space: 1	● Student Space (42)	
B00B - R0007 - Welding Area - (13.94 SQM)	Not Applicable	Circulation or storage space.
B00B - R0008 - Materials Technology L.S. - (91.01 SQM) - Teaching Space: 1	● Student Space (42)	
B00B - R0009 - Metal Technology Bay - (26.54 SQM)	Not Applicable	Circulation or storage space.
B00B - R0011 - Darkroom Space - (34.22 SQM)	● Office (8)	
B00B - R0012 - Staff Study - (28.64 SQM)	● Office (7)	
B00B - R0013 - Staff Study - (40.28 SQM)	● Office (10)	
B00B - R0015 - Practice/Seminar - (14.11 SQM)	Not Applicable	Circulation or storage space.
B00B - R0017 - Music Learning Space - (78.05 SQM) - Teaching Space: 1	● Student Space (36)	
B00B - R0018 - Workshop - (37.05 SQM)	● Student Space (17)	
B00B - R0019 - Art Learning Space - (62.6 SQM) - Teaching Space: 1	● Student Space (29)	
B00B - R0021 - Senior Study - (18.32 SQM)	● Office (4)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R0023 - General Learning Space - (48.22 SQM) - Teaching Space: 1	● Student Space (22)	
B00B - R0024 - Computer Room - (56.92 SQM)	● Student Space (26)	
B00C - R0001 - Computer Learning Space - (60.6 SQM) - Teaching Space: 1	● Student Space (28)	
B00C - R0005 - Pupil Entry - (5.04 SQM)	Not Applicable	Circulation or storage space.
B00C - R0006 - General Learning Space - (51.08 SQM) - Teaching Space: 1	● Student Space (23)	
B00C - R0007 - Study Space - (20.42 SQM)	Not Applicable	Circulation or storage space.
B00C - R0009 - Entry - (7.37 SQM)	Not Applicable	Circulation or storage space.
B00D - R0009 - Student Canteen - (32.67 SQM)	Not Applicable	Circulation or storage space.
B00D - R0020 - Student Canteen - (72.66 SQM)	Not Applicable	Circulation or storage space.
B00E - R0007 - Materials Technology L.S. - (63.79 SQM) - Teaching Space: 1	● Student Space (29)	
B00E - R0008 - Movement - (29.65 SQM)	Not Applicable	Circulation or storage space.
B00E - R0009 - Staff Kitchen - (10.49 SQM)	● Office (2)	
B00E - R0013 - Staff Kitchen - (19.9 SQM)	● Office (4)	
B00E - R0016 - Food Technology L.S. - (105.9 SQM) - Teaching Space: 1	● Student Space (49)	
B00E - R0017 - Food/Research Space - (15.53 SQM)	Not Applicable	Circulation or storage space.
B00E - R0018 - Preparation - Materials - (8.81 SQM)	Not Applicable	Circulation or storage space.
B00F - R0013 - Staff Kitchen - (14.38 SQM)	● Office (3)	
B00F - R0015 - Staff Study - (11.79 SQM)	● Office (2)	
B00F - R0017 - Multi-Purpose Space - (460.85 SQM)	● Student Space (213)	
B00F - R0019 - Stage - (63.04 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - General Learning Space - Type 10 - (59.85 SQM) - Teaching Space: 0.5	● Student Space (27)	
B00L - R0002 - Science Laboratory - (60.08 SQM)	● Student Space (27)	
B00L - R0003 - Preparation - Science - (30.23 SQM)	Not Applicable	Circulation or storage space.
B00L - R0004 - Staff Study - (21.07 SQM)	● Office (5)	
B00L - R0007 - Movement - (6.4 SQM)	Not Applicable	Circulation or storage space.