

VENTILATION AUDIT REPORT

SCHOOL:	Junee Public School (2247)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Cootamundra
LOCAL GOVERNMENT AREA:	Junee

2247 - Junee Public School
Site Plan (11849)



1:814

Printed: 10-Jul-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Home Base - (49.19 SQM) - Teaching Space: 1	 Student Space (22)	
B00A - R0003 - Home Base - (44.81 SQM) - Teaching Space: 1	 Student Space (20)	
B00A - R0004 - Home Base - (50.2 SQM) - Teaching Space: 1	 Student Space (23)	
B00A - R0005 - Staff Room Annexe - (13.29 SQM)	 Office (3)	
B00A - R0007 - Home Base - (43.62 SQM) - Teaching Space: 1	 Student Space (20)	
B00A - R0008 - Home Base - (43.75 SQM) - Teaching Space: 1	 Student Space (20)	
B00A - R0010 - Duplicating Workroom - (12.76 SQM)	 Office (3)	
B00A - R0011 - Movement - (11.13 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Movement - (6.47 SQM)	Not Applicable	Circulation or storage space.
B00A - R0016 - Home Base - (40.8 SQM) - Teaching Space: 1	 Student Space (18)	
B00A - R0017 - Practical Activities - 1hb - (39.77 SQM)	 Student Space (18)	
B00A - R0018 - Practical Activities - 1hb - (26.33 SQM)	 Student Space (12)	
B00C - R0002 - Practical Activities - 1hb - (9.75 SQM)	 Student Space (4)	
B00C - R0004 - Withdrawal Space - 1hb - (5.64 SQM)	 Student Space (2)	
B00C - R0005 - Home Base - (83.71 SQM) - Teaching Space: 1	 Student Space (38)	
B00C - R0007 - Movement - (11.51 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Home Base - (48.99 SQM) - Teaching Space: 1	 Student Space (22)	
B00D - R0003 - Home Base - (48.92 SQM) - Teaching Space: 1	 Student Space (22)	
B00D - R0004 - Home Base - (48.97 SQM) - Teaching Space: 1	 Student Space (22)	
B00D - R0005 - Home Base - (72.56 SQM) - Teaching Space: 1	 Student Space (33)	
B00D - R0011 - Staff Room Annexe - (14.56 SQM)	 Office (3)	
B00E - R0002 - Canteen - (27.89 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Raised Platform - (38.54 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Communal Space - (151.43 SQM)	 Student Space (70)	
B00G - R0003 - Reading Area - (167.58 SQM)	 Student Space (77)	
B00G - R0011 - Special Programs Room - (32.61 SQM)	 Student Space (15)	
B00H - R0001 - Staff Kitchen - (12.24 SQM)	 Office (3)	
B00H - R0005 - Home Base - (44.99 SQM) - Teaching Space: 1	 Student Space (20)	
B00H - R0007 - Withdrawal Space - 1hb - (11.93 SQM)	 Student Space (5)	
B00H - R0009 - Withdrawal Space - 1hb - (13.15 SQM)	 Student Space (6)	
B00H - R0012 - Home Base - (53.62 SQM) - Teaching Space: 1	 Student Space (24)	
B00H - R0014 - Movement - (5.22 SQM)	Not Applicable	Circulation or storage space.
B00I - R0001 - Staff Room - (34.04 SQM)	 Office (8)	
B00I - R0004 - Principal - (17.97 SQM)	 Office (4)	
B00I - R0009 - Clerical Office - (17.62 SQM)	 Office (4)	
B00I - R0010 - Entry Vestibule - (15.85 SQM)	Not Applicable	Circulation or storage space.
B00I - R0011 - Sick Bay - (5.61 SQM)	 Student Space (2)	
B00I - R0015 - Entry Vestibule - (11.01 SQM)	Not Applicable	Circulation or storage space.
B00I - R0016 - Movement - (8.78 SQM)	Not Applicable	Circulation or storage space.
B00I - R0017 - Sick Bay - (7.2 SQM)	 Student Space (3)	
B00I - R0018 - Clerical Office - (12.07 SQM)	 Office (3)	
B00I - R0019 - Clerical Office - (33.64 SQM)	 Office (8)	
B00I - R0022 - Staff Room - (44.34 SQM)	 Office (11)	
B00I - R0023 - Staff Kitchen - (16.5 SQM)	 Office (4)	
B00I - R0025 - Staff Room Annexe - (7.66 SQM)	 Office (1)	
B00I - R0026 - Deputy Principal - Type 1 - (11.31 SQM)	 Office (2)	