

VENTILATION AUDIT REPORT

SCHOOL:	Kalinda School (5699)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Murray
LOCAL GOVERNMENT AREA:	Griffith

5699 - Kalinda School
Site Plan (10406)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R0004 - Special Programs Room - (31.88 SQM)	● Student Space (14)	
B00C - R0005 - Communal Space - (59.59 SQM)	● Student Space (27)	
B00D - R0002 - Home Base - P - (69.38 SQM) - Teaching Space: 1	● Student Space (32)	
B00D - R0003 - Practical Activities - P - 2hb - (39.91 SQM)	● Student Space (18)	
B00D - R0008 - Home Base - P - (68.88 SQM) - Teaching Space: 1	● Student Space (31)	
B00E - R0005 - Hydrotherapy - Pool - (181.92 SQM)	Not Applicable	Circulation or storage space.
B00E - R0006 - Movement - (7.96 SQM)	Not Applicable	Circulation or storage space.
B00E - R0007 - Movement - (15.96 SQM)	Not Applicable	Circulation or storage space.
B00E - R0008 - Staff Room Annexe - (12.64 SQM)	● Office (3)	
B00F - R0001 - Staff Room Annexe - (18.63 SQM)	● Office (4)	
B00F - R0002 - Staff Room - (47.29 SQM)	● Office (11)	
B00F - R0003 - Interview - (16.83 SQM)	● Office (4)	
B00F - R0005 - Principal - (16.91 SQM)	● Office (4)	
B00F - R0006 - Interview - (12.95 SQM)	● Office (3)	
B00F - R0007 - Entry Vestibule - (19.02 SQM)	Not Applicable	Circulation or storage space.
B00F - R0008 - Clerical Office - (31.95 SQM)	● Office (7)	
B00F - R0009 - Sick Bay - (5.78 SQM)	● Student Space (2)	
B00F - R0014 - Movement - (60.27 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Home Base - M - (68.18 SQM) - Teaching Space: 1	● Student Space (31)	
B00G - R0003 - Practical Activities - M - 2hb - (39.62 SQM)	● Student Space (18)	
B00G - R0008 - Home Base - M - (68.15 SQM) - Teaching Space: 1	● Student Space (31)	
B00G - R0011 - Home Base - M - (68.13 SQM) - Teaching Space: 1	● Student Space (31)	
B00G - R0013 - Practical Activities - M - 2hb - (39.76 SQM)	● Student Space (18)	
B00G - R0018 - Home Base - M - (68.49 SQM) - Teaching Space: 1	● Student Space (31)	
B00G - R0024 - Reading Area - (69.67 SQM)	● Student Space (32)	