

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Kambora Public School (4515)</b>
<b>AMU REGION:</b>	<b>Northern Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Davidson</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Northern Beaches</b>

4515 - Kambora Public School  
Site Plan (10634)













1:1,022

Printed: 13-Jan-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - M0001 - Withdrawal Space - 1hb - (11.32 SQM)	Student Space (5)	
B00A - M0003 - Staff Room - (51.09 SQM)	Office (12)	
B00A - M0006 - Movement - (9.76 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Movement - (11.61 SQM)	Not Applicable	Circulation or storage space.
B00A - R0008 - Seminar/Study - (8.94 SQM)	Office (2)	
B00A - R0014 - Movement - (30.78 SQM)	Not Applicable	Circulation or storage space.
B00A - R0015 - Movement - (24.71 SQM)	Not Applicable	Circulation or storage space.
B00A - R0016 - Reading Area - (173.82 SQM)	Student Space (80)	
B00A - R0022 - Practical Activities - 1hb - (35.91 SQM)	Student Space (16)	
B00A - R0025 - Home Base - (56.74 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0026 - Movement - (35.53 SQM)	Not Applicable	Circulation or storage space.
B00A - R0027 - Withdrawal Space - 1hb - (12.32 SQM)	Student Space (5)	
B00A - R0028 - Movement - (11.88 SQM)	Not Applicable	Circulation or storage space.
B00A - R0029 - Movement - (28.53 SQM)	Not Applicable	Circulation or storage space.
B00A - R0030 - Movement - (140.79 SQM)	Not Applicable	Circulation or storage space.
B00A - R0031 - Movement - (26.83 SQM)	Not Applicable	Circulation or storage space.
B00A - R0034 - Practical Activities - 1hb - (37.47 SQM)	Student Space (17)	
B00A - R0037 - Movement - (36.83 SQM)	Not Applicable	Circulation or storage space.
B00A - R0038 - Home Base - (57.1 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0039 - Withdrawal Space - 1hb - (12.25 SQM)	Student Space (5)	
B00A - R0041 - Movement - (31.31 SQM)	Not Applicable	Circulation or storage space.
B00A - R0046 - Raised Platform - (47.51 SQM)	Not Applicable	Circulation or storage space.
B00A - R0047 - Communal Space - (156.24 SQM)	Student Space (72)	
B00A - R0053 - Movement - (25.65 SQM)	Not Applicable	Circulation or storage space.
B00A - R0054 - Canteen - (28.03 SQM)	Not Applicable	Circulation or storage space.
B00A - R0059 - Movement - (16.91 SQM)	Not Applicable	Circulation or storage space.
B00A - R0065 - Deputy Principal - (11.83 SQM)	Office (2)	
B00A - R0066 - Clerical Office - (24.85 SQM)	Office (6)	
B00A - R0067 - Sick Bay - (9.94 SQM)	Student Space (4)	
B00A - R0068 - Duplicating Workroom - (18.6 SQM)	Office (4)	
B00A - R0069 - Movement - (24.11 SQM)	Not Applicable	Circulation or storage space.
B00A - R0070 - Entry Vestibule - (24.96 SQM)	Not Applicable	Circulation or storage space.
B00A - R0072 - Principal - (21.63 SQM)	Office (5)	
B00A - R0073 - Movement - (31.17 SQM)	Not Applicable	Circulation or storage space.
B00A - R0074 - Movement - (15.15 SQM)	Not Applicable	Circulation or storage space.
B00A - R0077 - Movement - (8.06 SQM)	Not Applicable	Circulation or storage space.
B00A - R0078 - Deputy Principal - (12.25 SQM)	Office (3)	
B00A - R0091 - Practical Activities - 1hb - (34.53 SQM)	Student Space (16)	
B00A - R0092 - Movement - (27.62 SQM)	Not Applicable	Circulation or storage space.
B00A - R0093 - Home Base - (54.73 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R0096 - Home Base - (56.28 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0097 - Withdrawal Space - 1hb - (11.31 SQM)	Student Space (5)	
B00A - R0098 - Movement - (80.14 SQM)	Not Applicable	Circulation or storage space.
B00A - R0099 - Practical Activities - 1hb - (37.63 SQM)	Student Space (17)	
B00A - R0102 - Home Base - (55.79 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R0103 - Withdrawal Space - 1hb - (12.25 SQM)	Student Space (5)	
B00A - R0104 - Home Base - (57.84 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0105 - Movement - (27.68 SQM)	Not Applicable	Circulation or storage space.
B00A - R0112 - Withdrawal Space - 1hb - (17.64 SQM)	Student Space (8)	
B00A - R0113 - Practical Activities - 1hb - (37.72 SQM)	Student Space (17)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0116 - Home Base - (55.58 SQM) - Teaching Space: 1	 Student Space (25)	
B00A - R0117 - Movement - (27.53 SQM)	Not Applicable	Circulation or storage space.
B00A - R0118 - Home Base - (55.76 SQM) - Teaching Space: 1	 Student Space (25)	
B00A - R0119 - Withdrawal Space - 1hb - (11.34 SQM)	 Student Space (5)	
B00A - R0122 - Movement - (19.15 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Movement - (16.71 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Movement - (7.26 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Home Base - (60.76 SQM) - Teaching Space: 1	 Student Space (28)	
B00D - R0002 - Home Base - (60.8 SQM) - Teaching Space: 1	 Student Space (28)	
B00D - R0007 - Practical Activities - 1hb - (18.61 SQM)	 Student Space (8)	
B00D - R0008 - Withdrawal Space - 2hb - (11.34 SQM)	 Student Space (5)	
B00D - R0009 - Practical Activities - 1hb - (18.49 SQM)	 Student Space (8)	
OS 606 18302 - OS 606 18302 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	
OS 606 19055 - OS 606 19055 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	