

VENTILATION AUDIT REPORT

SCHOOL:	Kapooka Public School (3923)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Wagga Wagga
LOCAL GOVERNMENT AREA:	Wagga Wagga

3923 - Kapooka Public School
Site Plan (13176)













1:499

Printed: 04-Sep-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Home Base - (65.8 SQM) - Teaching Space: 1	 Student Space (30)	
B00A - R0004 - Home Base - (67.35 SQM) - Teaching Space: 1	 Student Space (31)	
B00A - R0006 - Clerical Office - (8.21 SQM)	 Office (2)	
B00A - R0008 - Principal - (15.06 SQM)	 Office (3)	
B00A - R0009 - Entry Vestibule - (14.75 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Movement - (14.66 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Movement - (18.81 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Reading Area - (92.51 SQM)	 Student Space (42)	
B00D - R0005 - Movement - (32.96 SQM)	Not Applicable	Circulation or storage space.
OS 503 14396 - OS 503 14396 - Admin Lib Staff/Principal/Clerk/Store - (152 SQM)	 Office (38)	
OS 531 12434 - OS 531 12434 - Library - (76 SQM)	 Student Space (35)	
OS 602 13474 - OS 602 13474 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 14149 - OS 602 14149 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 14761 - OS 602 14761 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	