


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Karabar High School (8524)</b>
<b>AMU REGION:</b>	<b>Southern NSW</b>
<b>STATE ELECTORATE:</b>	<b>Monaro</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Queanbeyan-Palerang</b>

8524 - Karabar High School  
Site Plan (12560)






## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Interview/Office - Type 1 - (16.1 SQM)	Office (4)	
B00A - R0007 - Administration - Clerical - (28.83 SQM)	Office (7)	
B00A - R0008 - Duplicating Workroom - (23.87 SQM)	Office (5)	
B00A - R0011 - Commonroom - (117.73 SQM)	Office (29)	
B00A - R0015 - Gymnasium - (92.74 SQM)	Student Space (43)	
B00A - R0022 - Interview/Office - Type 1 - (12.78 SQM)	Office (3)	
B00A - R0023 - Clinic - Boys - (12.95 SQM)	Office (3)	
B00A - R0025 - Movement - (5.31 SQM)	Not Applicable	Circulation or storage space.
B00A - R0028 - Movement - (12.98 SQM)	Not Applicable	Circulation or storage space.
B00A - R0032 - Darkroom Space - (31.62 SQM)	Office (7)	
B00A - R0040 - Entry - (18 SQM)	Not Applicable	Circulation or storage space.
B00A - R0042 - Pupil Entry - (7.89 SQM)	Not Applicable	Circulation or storage space.
B00A - R0043 - Administration - Clerical - (52 SQM)	Office (13)	
B00A - R0045 - Deputy Principal Office - (18.73 SQM)	Office (4)	
B00A - R0046 - Movement - (58.86 SQM)	Not Applicable	Circulation or storage space.
B00A - R0047 - Principal Office - (24.8 SQM)	Office (6)	
B00A - R0048 - Movement - (25.59 SQM)	Not Applicable	Circulation or storage space.
B00A - R0049 - Movement - (67.7 SQM)	Not Applicable	Circulation or storage space.
B00A - R0052 - Movement - (82.86 SQM)	Not Applicable	Circulation or storage space.
B00A - R0055 - Preparation - Science - (39.49 SQM)	Not Applicable	Circulation or storage space.
B00A - R0057 - Laboratory L.S. - (84.95 SQM) - Teaching Space: 1	Student Space (39)	
B00A - R0058 - Laboratory L.S. - (84.56 SQM) - Teaching Space: 1	Student Space (39)	
B00A - R1001 - General Learning Space - (53.34 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1002 - General Learning Space - (52.59 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1004 - Staff Study - (33.62 SQM)	Office (8)	
B00A - R1005 - General Learning Space - (52.84 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1006 - General Learning Space - (52.75 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1007 - Staff Study - (26.01 SQM)	Office (6)	
B00A - R1008 - Computer Learning Space - (53.13 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1009 - Computer Learning Space - (52.43 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1010 - General Learning Space - (52.76 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1011 - General Learning Space - (52.82 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1018 - Preparation - (46.69 SQM)	Not Applicable	Circulation or storage space.
B00A - R1020 - Staff Study - (8.24 SQM)	Office (2)	
B00A - R1021 - Staff Study - (22.27 SQM)	Office (5)	
B00A - R1023 - Staff Study - (30.36 SQM)	Office (7)	
B00A - R1030 - Staff Study - (21.7 SQM)	Office (5)	
B00A - R1031 - Movement - (180.27 SQM)	Not Applicable	Circulation or storage space.
B00A - R1032 - Movement - (93.13 SQM)	Not Applicable	Circulation or storage space.
B00A - R1034 - Laboratory L.S. - (85.12 SQM) - Teaching Space: 1	Student Space (39)	
B00A - R1035 - Laboratory L.S. - (85.02 SQM) - Teaching Space: 1	Student Space (39)	
B00B - R0001 - Multi-Purpose Space - (453.37 SQM)	Student Space (210)	
B00B - R0003 - Staff Study - (11.22 SQM)	Office (2)	
B00B - R0004 - Staff Study - (11.21 SQM)	Office (2)	
B00B - R0006 - Movement - (14.2 SQM)	Not Applicable	Circulation or storage space.
B00B - R0011 - Staff Study - (20.02 SQM)	Office (5)	
B00B - R0018 - Welding Area - (9.77 SQM)	Not Applicable	Circulation or storage space.
B00B - R0021 - Art Learning Space - (62.53 SQM) - Teaching Space: 1	Student Space (29)	
B00B - R0022 - Art Learning Space - (64.99 SQM) - Teaching Space: 1	Student Space (30)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R0033 - Staff Study - (34.77 SQM)	Office (8)	
B00B - R0039 - Movement - (98.79 SQM)	Not Applicable	Circulation or storage space.
B00B - R0040 - Movement - (209.66 SQM)	Not Applicable	Circulation or storage space.
B00B - R0041 - Movement - (29.16 SQM)	Not Applicable	Circulation or storage space.
B00B - R0044 - Computer Room - (9.47 SQM)	Student Space (4)	
B00B - R0046 - Art Learning Space - (64.61 SQM) - Teaching Space: 1	Student Space (29)	
B00B - R0048 - Movement - (13.17 SQM)	Not Applicable	Circulation or storage space.
B00B - R0052 - Movement - (10.32 SQM)	Not Applicable	Circulation or storage space.
B00B - R0053 - Workshop Area - (119.64 SQM)	Student Space (55)	
B00B - R0055 - General Learning Space - Type 6 - (73.62 SQM) - Teaching Space: 1	Student Space (34)	
B00B - R0056 - Metal Technology Bay - (107.82 SQM)	Not Applicable	Circulation or storage space.
B00B - R0058 - Student Canteen - (49.24 SQM)	Not Applicable	Circulation or storage space.
B00B - R1001 - Food Technology L.S. - (100.49 SQM) - Teaching Space: 1	Student Space (46)	
B00B - R1006 - Food Technology L.S. - (99.4 SQM) - Teaching Space: 1	Student Space (46)	
B00B - R1007 - Music Learning Space - (77.99 SQM) - Teaching Space: 1	Student Space (36)	
B00B - R1011 - Music Learning Space - (80.38 SQM) - Teaching Space: 1	Student Space (37)	
B00B - R1019 - Design L.S. - (66.15 SQM) - Teaching Space: 1	Student Space (30)	
B00B - R1022 - Darkroom Space - (10.74 SQM)	Office (2)	
B00B - R1024 - Design L.S. - (66.16 SQM) - Teaching Space: 1	Student Space (30)	
B00B - R1026 - Staff Study - (39.86 SQM)	Office (9)	
B00B - R1028 - Design L.S. - (52.76 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1029 - Study Space - (17.95 SQM)	Not Applicable	Circulation or storage space.
B00B - R1031 - Design L.S. - (53.33 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1032 - Materials Technology L.S. - (177.26 SQM) - Teaching Space: 1	Student Space (82)	
B00B - R1035 - Movement - (11.94 SQM)	Not Applicable	Circulation or storage space.
B00B - R1036 - Movement - (304.09 SQM)	Not Applicable	Circulation or storage space.
B00B - R1037 - Movement - (28.52 SQM)	Not Applicable	Circulation or storage space.
B00B - R1038 - Movement - (7.4 SQM)	Not Applicable	Circulation or storage space.
B00B - R1041 - Movement - (5.57 SQM)	Not Applicable	Circulation or storage space.
B00B - R1042 - Preparation - (23.26 SQM)	Not Applicable	Circulation or storage space.
B00B - R1043 - Food/Research Space - (14.86 SQM)	Not Applicable	Circulation or storage space.
B00C - M0005 - Main Area - (92.27 SQM)	Not Applicable	Circulation or storage space.
B00C - M0006 - Computer Room - (95.26 SQM)	Student Space (44)	
B00C - M0007 - Computer Room - (48.09 SQM)	Student Space (22)	
B00C - R0002 - Seminar - (12.49 SQM)	Office (3)	
B00C - R0006 - Audio Visual Workroom - (24.58 SQM)	Student Space (11)	
B00C - R0007 - Workroom - (22.53 SQM)	Office (5)	
B00C - R0013 - Seminar - (8.86 SQM)	Office (2)	
B00C - R0016 - Computer Room - (47.4 SQM)	Student Space (21)	
B00C - R0017 - Main Area - (234.95 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - General Assistants - (16.78 SQM)	Office (4)	
B00J - R0001 - Study Space - (23.99 SQM)	Not Applicable	Circulation or storage space.
B00J - R0006 - Commonroom - (8.29 SQM)	Office (2)	
B00J - R0009 - Movement - (55.88 SQM)	Not Applicable	Circulation or storage space.
B00J - R0010 - Movement - (23.52 SQM)	Not Applicable	Circulation or storage space.
B00L - R0002 - Senior Study - (13.94 SQM)	Office (3)	
B00L - R0005 - Computer Learning Space - (35.9 SQM) - Teaching Space: 1	Student Space (16)	
B00N - R0001 - Performance Workshop - (159.81 SQM)	Student Space (74)	
B00N - R0004 - General Learning Space - Type 13 - (46.5 SQM) - Teaching Space: 1	Student Space (21)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00Q - R0001 - General Learning Space - (60.83 SQM) - Teaching Space: 1	Student Space (28)	
B00Q - R0002 - Staff Study - (57.29 SQM)	Office (14)	
B00Q - R0003 - Pupil Entry - (11.11 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0004 - Isolation Space - (61.65 SQM)	Office (15)	
B00Q - R0008 - Movement - (22.14 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0015 - General Learning Space - (58.73 SQM) - Teaching Space: 1	Student Space (27)	
B00Q - R0016 - General Learning Space - (58.89 SQM) - Teaching Space: 1	Student Space (27)	
B00Q - R0017 - Movement - (33.98 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0018 - Seminar - Type 1 - (28.33 SQM)	Office (7)	
B00Q - R0019 - Study Space - (8.17 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0021 - Movement - (14.97 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0022 - Movement - (98.42 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0023 - General Learning Space - (69.39 SQM) - Teaching Space: 1	Student Space (32)	
B00Q - R0024 - Movement - (16.79 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0025 - General Learning Space - (62.78 SQM) - Teaching Space: 1	Student Space (29)	
B00Q - R0026 - General Learning Space - (57.8 SQM) - Teaching Space: 1	Student Space (26)	
B00Q - R0027 - General Learning Space - (59.89 SQM) - Teaching Space: 1	Student Space (27)	
B00Q - R0031 - Tiered Learning Area - (80.8 SQM)	Student Space (37)	
B00Q - R1001 - Tiered Learning Area - (104.7 SQM)	Student Space (48)	
B0D1 - R0001 - Interview/Office - Type 1 - (12.67 SQM)	Office (3)	
B0D1 - R0002 - Interview/Office - Type 1 - (12.27 SQM)	Office (3)	
B0D1 - R0005 - General Learning Space - (47.56 SQM) - Teaching Space: 1	Student Space (22)	
B0D1 - R0006 - General Learning Space - (47.84 SQM) - Teaching Space: 1	Student Space (22)	
B0D1 - R0007 - Movement - (39.86 SQM)	Not Applicable	Circulation or storage space.
B0D1 - R1001 - Staff Study - (25.84 SQM)	Office (6)	
B0D1 - R1004 - Staff Study - (48.79 SQM)	Office (12)	
B0D1 - R1005 - General Learning Space - (46.18 SQM) - Teaching Space: 1	Student Space (21)	
B0D1 - R1006 - Movement - (36.57 SQM)	Not Applicable	Circulation or storage space.
B0D2 - R0001 - General Learning Space - (48.08 SQM) - Teaching Space: 1	Student Space (22)	
B0D2 - R0003 - Staff Study - (42.72 SQM)	Office (10)	
B0D2 - R0004 - Staff Study - (30.16 SQM)	Office (7)	
B0D2 - R0008 - Movement - (56.03 SQM)	Not Applicable	Circulation or storage space.
B0D2 - R1001 - General Learning Space - (50.8 SQM) - Teaching Space: 1	Student Space (23)	
B0D2 - R1002 - General Learning Space - (45.62 SQM) - Teaching Space: 1	Student Space (21)	
B0D2 - R1004 - Staff Study - (24.95 SQM)	Office (6)	
B0D2 - R1008 - Movement - (60.21 SQM)	Not Applicable	Circulation or storage space.
B0D3 - R0006 - Movement - (42.15 SQM)	Not Applicable	Circulation or storage space.
B0D3 - R0007 - Laboratory L.S. - (77.24 SQM) - Teaching Space: 1	Student Space (35)	
B0D3 - R0008 - Preparation - Science - (48.94 SQM)	Not Applicable	Circulation or storage space.
B0D3 - R0009 - Laboratory L.S. - (77.4 SQM) - Teaching Space: 1	Student Space (35)	
B0D3 - R1003 - General Learning Space - (47.35 SQM) - Teaching Space: 1	Student Space (21)	
B0D3 - R1004 - General Learning Space - (47.35 SQM) - Teaching Space: 1	Student Space (21)	
B0D3 - R1005 - General Learning Space - (48.21 SQM) - Teaching Space: 1	Student Space (22)	
B0D3 - R1006 - Teachers Aides - (8.46 SQM)	Office (2)	
B0D3 - R1007 - Movement - (80.78 SQM)	Not Applicable	Circulation or storage space.
OS 600 11402 - OS 600 11402 - Learning Unit - Small - (57 SQM)	Student Space (26)	
OS 601 11667 - OS 601 11667 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 11668 - OS 601 11668 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 11726 - OS 601 11726 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	

Entity Location	Audit Condition Classification (Capacity)	Comment
OS 601 13478 - OS 601 13478 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 13672 - OS 601 13672 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 602 11189 - OS 602 11189 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	