


VENTILATION AUDIT REPORT

SCHOOL:	Kariong Public School (4580)
AMU REGION:	Hunter/Central Coast
STATE ELECTORATE:	Gosford
LOCAL GOVERNMENT AREA:	Central Coast

4580 - Kariong Public School
Site Plan (13054)



Printed: 30-Mar-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0005 - Principal - (19.21 SQM)	Office (4)	
B00A - R0011 - Seminar/Study - (19.8 SQM)	Office (4)	
B00A - R0013 - Interview - (14.48 SQM)	Office (3)	
B00A - R0016 - Deputy Principal - (12.19 SQM)	Office (3)	
B00A - R0017 - Staff Room Annexe - (12.19 SQM)	Office (3)	
B00A - R0018 - Sick Bay - (12.19 SQM)	Student Space (5)	
B00A - R0023 - Movement - (108.36 SQM)	Not Applicable	Circulation or storage space.
B00A - R0024 - Entry Vestibule - (11.61 SQM)	Not Applicable	Circulation or storage space.
B00A - R0025 - Clerical Office - (38.54 SQM)	Office (9)	
B00A - R0026 - Duplicating Workroom - (21.22 SQM)	Office (5)	
B00A - R0027 - Movement - (54.18 SQM)	Not Applicable	Circulation or storage space.
B00A - R0028 - Staff Room - (80.54 SQM)	Office (20)	
B00A - R1002 - Home Base - (58.33 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1003 - Practical Activities - 1hb - (20 SQM)	Student Space (9)	
B00A - R1005 - Practical Activities - 1hb - (20.05 SQM)	Student Space (9)	
B00A - R1006 - Home Base - (58.41 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1013 - Movement - (104.03 SQM)	Not Applicable	Circulation or storage space.
B00A - R1015 - Practical Activities - 1hb - (19.94 SQM)	Student Space (9)	
B00A - R1016 - Home Base - (58.79 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1017 - Home Base - (58.94 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1018 - Withdrawal Space - 1hb - (14.75 SQM)	Student Space (6)	
B00A - R1019 - Practical Activities - 1hb - (19.9 SQM)	Student Space (9)	
B00A - R1020 - Interview - (8.12 SQM)	Office (2)	
B00B - R0001 - Special Programs Room - (31.54 SQM)	Student Space (14)	
B00B - R0006 - Home Base - (58.79 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0007 - Practical Activities - 1hb - (20 SQM)	Student Space (9)	
B00B - R0008 - Withdrawal Space - 1hb - (13.24 SQM)	Student Space (6)	
B00B - R0009 - Practical Activities - 1hb - (20 SQM)	Student Space (9)	
B00B - R0010 - Home Base - (58.79 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0015 - Home Base - (58.56 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0016 - Practical Activities - 1hb - (19.35 SQM)	Student Space (8)	
B00B - R0017 - Withdrawal Space - 1hb - (13.2 SQM)	Student Space (6)	
B00B - R0018 - Practical Activities - 1hb - (19.42 SQM)	Student Space (9)	
B00B - R0019 - Home Base - (58.8 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0021 - Movement - (146.61 SQM)	Not Applicable	Circulation or storage space.
B00B - R1004 - Home Base - (58.56 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R1005 - Practical Activities - 1hb - (20.05 SQM)	Student Space (9)	
B00B - R1006 - Withdrawal Space - 1hb - (13.19 SQM)	Student Space (6)	
B00B - R1007 - Home Base - (58.56 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R1008 - Practical Activities - 1hb - (20.04 SQM)	Student Space (9)	
B00B - R1014 - Home Base - (58.72 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R1015 - Practical Activities - 1hb - (19.35 SQM)	Student Space (8)	
B00B - R1017 - Practical Activities - 1hb - (19.35 SQM)	Student Space (8)	
B00B - R1018 - Home Base - (58.72 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R1020 - Movement - (142.94 SQM)	Not Applicable	Circulation or storage space.
B00C - R0012 - Communal Space - (156.7 SQM)	Student Space (72)	
B00C - R0013 - Raised Platform - (52.63 SQM)	Not Applicable	Circulation or storage space.
B00C - R0016 - Movement - (11.53 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R0017 - Movement - (42.27 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Canteen - (27.72 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Practical Activities - 1hb - (19.97 SQM)	● Student Space (9)	
B00F - R0003 - Home Base - (58.4 SQM) - Teaching Space: 1	● Student Space (27)	
B00F - R0006 - Practical Activities - 1hb - (19.97 SQM)	● Student Space (9)	
B00F - R0007 - Home Base - (58.4 SQM) - Teaching Space: 1	● Student Space (27)	
B00F - R0010 - Movement - (62.54 SQM)	Not Applicable	Circulation or storage space.
B00F - R1003 - Practical Activities - 1hb - (19.97 SQM)	● Student Space (9)	
B00F - R1004 - Home Base - (58.4 SQM) - Teaching Space: 1	● Student Space (27)	
B00F - R1005 - Withdrawal Space - 2hb - (13.2 SQM)	● Student Space (6)	
B00F - R1006 - Practical Activities - 1hb - (19.97 SQM)	● Student Space (9)	
B00F - R1007 - Home Base - (58.41 SQM) - Teaching Space: 1	● Student Space (27)	
B00F - R1009 - Movement - (58.46 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Practical Activities - 1hb - (14.98 SQM)	● Student Space (6)	
B00G - R0004 - Home Base - (60.65 SQM) - Teaching Space: 1	● Student Space (28)	
B00G - R0005 - Withdrawal Space - 2hb - (11.65 SQM)	● Student Space (5)	
B00G - R0006 - Home Base - (60.41 SQM) - Teaching Space: 1	● Student Space (28)	
B00G - R0009 - Practical Activities - 1hb - (14.95 SQM)	● Student Space (6)	
B00G - R0010 - Withdrawal Space - 1hb - (9.19 SQM)	● Student Space (4)	
B00G - R0012 - Home Base - (58.74 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0014 - Practical Activities - 1hb - (15.48 SQM)	● Student Space (7)	
B00G - R1001 - Practical Activities - 1hb - (14.94 SQM)	● Student Space (6)	
B00G - R1004 - Home Base - (60.19 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R1005 - Withdrawal Space - 2hb - (11.54 SQM)	● Student Space (5)	
B00G - R1006 - Home Base - (60.34 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R1009 - Practical Activities - 1hb - (14.67 SQM)	● Student Space (6)	
B00G - R1010 - Practical Activities - 1hb - (17.76 SQM)	● Student Space (8)	
B00G - R1012 - Withdrawal Space - 1hb - (9.95 SQM)	● Student Space (4)	
B00G - R1013 - Home Base - (57.35 SQM) - Teaching Space: 1	● Student Space (26)	
B00H - R0001 - Home Base - (58.86 SQM) - Teaching Space: 1	● Student Space (27)	
B00H - R0002 - Practical Activities - 1hb - (27.04 SQM)	● Student Space (12)	
B00H - R0003 - Withdrawal Space - 1hb - (5.71 SQM)	● Student Space (2)	
B00H - R0005 - Movement - (20.62 SQM)	Not Applicable	Circulation or storage space.
B00H - R1001 - Home Base - (58.71 SQM) - Teaching Space: 1	● Student Space (27)	
B00H - R1002 - Practical Activities - 1hb - (26.83 SQM)	● Student Space (12)	
B00H - R1003 - Withdrawal Space - 1hb - (5.65 SQM)	● Student Space (2)	
B00H - R1006 - Movement - (25.68 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Special Programs Room - (33.48 SQM)	● Student Space (15)	
B00L - R0002 - Reading Area - (188.13 SQM)	● Student Space (87)	
B00L - R0005 - Special Programs Room - (24.54 SQM)	● Student Space (11)	
B00L - R0008 - Movement - (54.06 SQM)	Not Applicable	Circulation or storage space.
OH 045 17002 - OH 045 17002 - OSHC Hub 45 - (SQM)	● Student Space ()	